

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012401672
DATE : 22.04.2024
REQ No : 1012401482
REQ TITLE : Transmitter 1012401482
DELIVERY LOCATION : 0015 - K STORE-SPAR&CHE
CLOSING DATE : 30.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1	2100001697		TRANSMITTER_PRESSURE; INPUT RANGE: 14 TO 63BAR; SUPPLY RATING: 11 TO35VDC; OUTPUT RATING: 4 TO 20MA; SIZE/CONNECTION: 1/2IN BSPPT TYPE:2-WIRE; CALIBRATION RANGE: 0 TO 40BAR; CONNECTION MATERIAL: 1.4401 SS;MATERIAL: DIE CAST AL; ELECTRICAL CONNECTION: PG 13.5 SC R EWED GLAND;COMMUNICATION PROTOCOL: HART; ENCLOSURE: IP65; MFR: SIEMENS LTD: MPN:7MF4010-1EA00-1AA5-Z-A01+Y01+Y20: ADDITIONAL INFO : SITRANS P; MAX: 1.4TO 63BAR; MEASURING CELL FILLING: SILICONE OIL; MEASURING CELL CLEANING:NORMAL; SEAL DIAPHRAGM: SS; W/O EXPLO SIO N PROTECTION; HOUSING COVERW/ANALOG INDICATOR -SCALE AS SPECIFIED; MOUNTING BRACKET: STL; MEASURINGRANGE TO BE SET -SPECIFY IN PLAIN TEXT; CUSTOMER-SPECIFIC SCALE FORANALOG INDICATOR; SPECIFY IN PLAIN TEXT	6	EA				
2	2700031046		TRANSMITTER_DIFFERENTIAL PRESSURE; INPUT RANGE: 20.08 TO 2008IN H2O;SUPPLY RATING: 10.5	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012401672
DATE : 22.04.2024
REQ No : 1012401482
REQ TITLE : Transmitter 1012401482
DELIVERY LOCATION : 0015 - K STORE-SPAR&CHE
CLOSING DATE : 30.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TO 45VDC; OUTPUT RATING: 4 TO 20MA; WORKING PRESSURE: 2320PSI; SIZE/CONNECTION: 1/4IN-18 FNPT; TYPE: 2-WIRE, FLOW; CONNECTION MATERIAL: SS; ELECTRICAL CONNECTION: PG 13.5 SCRE W ED GLAND; COMMUNICATION PROTOCOL: HART; TEMPERATURE RATING: -40 TO 85DEG C; MATERIAL: DIE CAST AL; ENCLOSURE: IP65; MFR: SIEMENS LT D: MPN: 7MF4433-1GB02-1AA6-Z-B11+Y01: ADDITIONAL INFO: CALIBRATION RANGE: 0 TO 1200MBAR; MEASURING CELL CLEANING: STD; MEASURING CELL F ILLING: SILICONE OIL; MODEL: SITRANS P; PROCESS FLANGE SCREWS: SS; PARTS OF MEASURING CELL: SS; SEAL DIAPHRAGM: HASTELLOY; VERSION: S TD; W/O EXPLOSION PROTECTION; W/VISIBLE DIGITAL INDICATION; RATING PLATE INSCRIPTION: ENGLISH; MEASURING RANGE TO BE SET-SPECIFY IN P LAIN TEXT W/LINEAR CHARACTERISTIC (MAX 5 DIGITS); APPLICATION: GT AREA						
3	2100008209		TRANSMITTER, PRESSURE; INPUT RANGE: 9.14 TO	3	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012401672
DATE : 22.04.2024
REQ No : 1012401482
REQ TITLE : Transmitter 1012401482
DELIVERY LOCATION : 0015 - K STORE-SPAR&CHE
CLOSING DATE : 30.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			914PSI; SUPPLY RATING: 10.5TO 45VDC; OUTPUT RATING: 4 TO 20MA; SIZE/CONNECTION: 1/2IN BS PP; TYPE:2-WIRE, FLOW; CALIBRATION RANGE: 0 TO 30BAR; CONNECTION MATERIAL: SS;MATERIAL: DIE CAST AL; ELECTRICAL CONNECTION: M20 X 1.5 SCREWED GLAND;COMMUNICATION PROTOCOL: HART; ENCLOSURE: IP65; MFR: SIEMENS LTD: MPN:7MF4033-1EA00-1EB1-Z-Y01+C11: ADDITIONAL IN FO: MEASUREMENT TYPE: GAGE;MEASURING CELL FILLING: SILICONE OIL; MODEL: SITRANS P; SEAL DIAPHRAGMMATERIAL: SS; SERIES: DSIII; W/O INDIC ATOR; APPLICATION: GT PILOT GASSKI; FAB: N1-F128-9000066						
4	2100001669		TRANSMITTER_PRESSURE; INPUT RANGE: 2.1 TO 63BAR; SUPPLY RATING: 10.5 TO45VDC; OUTPUT RATING: 4 TO 20MA; SIZE/CONNECTION: 1/2IN BSPP ; TYPE:2-WIRE; CALIBRATION RANGE: 0 TO 25BAR; CONNECTION MATERIAL: 1.4401 SS;MATERIAL: DIE CAST AL; ELECTRICAL CONNECTION: PG 13.5 SCREWED GLAND;COMMUNICATION PROTOCOL: HART; ENCLOSURE: IP65; MFR: SIEMENS LTD:	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012401672
DATE : 22.04.2024
REQ No : 1012401482
REQ TITLE : Transmitter 1012401482
DELIVERY LOCATION : 0015 - K STORE-SPAR&CHE
CLOSING DATE : 30.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MPN:7MF4013-1EA00-1AA6-Z-B11+Y01: MFR: SIEMENS LTD : MPN: A2A50232451:ADDITIONAL INFO: MEASURING CELL FILLING: NORMAL; MEASURING CELL FILLING:SILICONE OIL; PARTS OF MEASURING CELL: SS; RATING PLATE INSCRIPTION:ENGLISH; SEAL DIAPHRAGM: SS; HOUSING COVER W/WINDOW AND DIGITAL DISPLAY;MEASURING RANGE TO BE SET -SP ECIFY IN PLAIN TEXT; W/O EXPLOSIONPROTECTION; SITRANS T; APPLICATION: GT AREA						
5	2100001657		TRANSMITTER_PRESSURE; INPUT RANGE: 2.1 TO 63BAR; SUPPLY RATING: 10.5 TO45VDC; OUTPUT RATING: 4 TO 20MA; SIZE/CONNECTION: 1/2IN BSPP ; TYPE:2-WIRE; CONNECTION MATERIAL: 1.4401 SS; MATERIAL: DIE CAST AL;ELECTRICAL CONNECTION: PG 13.5 SCREWED GLAND; COMMUNICATION P R OTOCOL:HART; ENCLOSURE: IP65; MFR: SIEMENS LTD: MPN:7MF4013-1EA00-1EA7-Z-B11+Y01+Y21+C11+C14: ADDITIONAL INFO: NG CONDENSATE SKID ;	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012401672
DATE : 22.04.2024
REQ No : 1012401482
REQ TITLE : Transmitter 1012401482
DELIVERY LOCATION : 0015 - K STORE-SPAR&CHE
CLOSING DATE : 30.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MEASURING CELL FILLING: SILICONE OIL; MEASURING CELL FILLING: NORMAL; SEAL DIAPHRAGM: SS; PARTS OF MEASURING CELL: SS;EXPLOSION PRO TECTION: CENELEC; N (ZONE 2); W/INDICATOR (DIGITAL DISPLAYVISIBLE; SETTING AS SPECIFIED); RATING PLATE INSCRIPTION: ENGLISH; MEASURI NG RANGE TO BE SET -SPECIFY IN PLAIN TEXT; SETTING FOR DIGITALDISPLAY IN PRESSURE UNITS; SPECIFY IN PLAIN TEXT (STD SETTING: MA) ;MA NUFACTURER'S TEST CERTIFICATE M TO DIN 55 350; PART 18 AND TO ISO8402; FACTORY CERTIFICATE TO DIN EN 10 204-2.2						
6	2100001661		TRANSMITTER_PRESSURE; INPUT RANGE: -14.7 TO 800PSI; SUPPLY RATING: 10.5TO 42.4VDC; OUTPUT RATING: 4 TO 20MA; SIZE/CONNECTION: 1/2IN MALE BSPP;TYPE: INLINE, GAUGE; CONNECTION MATERIAL: 316L SS; COMMUNICATIONPROTOCOL: DIGITAL HART; ENCLOSURE: NEMA 4X, IP65/66/68; MFR: ROSEMOUNTINC: MPN: 3051TG3A2C21CB4N1M5P1Q4: ADDITIONAL INFO: DISPLAY: LCD;MOUNTING BRACKET: BRACKET FOR	3	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012401672
DATE : 22.04.2024
REQ No : 1012401482
REQ TITLE : Transmitter 1012401482
DELIVERY LOCATION : 0015 - K STORE-SPAR&CHE
CLOSING DATE : 30.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			2IN PIPE OR PANEL MOUNTING; PRODUCT CERTIFICATIONS: ATEX TYPE N CERTIFICATION AND DUST; SENSOR FILL FLUID: SILICONE; ISOLATING DIAPHRAGM: 316L SS; ALL SS; HYDROSTATIC TESTING W/CERTIFICATE; W/CALIBRATION CERTIFICATE; APPLICATION: FOSKID						
7	2100001660		TRANSMITTER_PRESSURE; INPUT RANGE: -14.7 TO 4000PSI; SUPPLY RATING: 10.5 TO 42.4VDC; OUTPUT RATING: 4 TO 20MA; SIZE/CONNECTION: 1/2IN MALE BSPP; TYPE: INLINE, GAUGE; CONNECTION MATERIAL: 316L SS; MATERIAL: AL; ELECTRICAL CONNECTION: M20 X 1.5; COMMUNICATION PROTOCOL: DIGITAL HART; ENCLOSURE: NEMA 4X, IP65/66/68; MFR: ROSEMOUNT INC; MPN: 3051TG4A2C21CB4N1M5P1Q4; ADDITIONAL INFO: FOSKID	2	EA				

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2012401672
DATE	: 22.04.2024
REQ No	: 1012401482
REQ TITLE	: Transmitter 1012401482
DELIVERY LOCATION	: 0015 - K STORE-SPAR&CHE
CLOSING DATE	: 30.04.2024
CLOSING TIME	: 10:00:00

Spares

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP