



RFQ NUMBER : 2332400815

DATE : 25.03.2024 **REQ No** : 1032401259

REQ TITLE : E#STATION ENERGY FOG

DELIVERY LOCATION

CLOSING DATE : 03.04.2024

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAI PRICE
1		ITEM-00001	SCOPE OF WORKS1.#PROVIDING NEW SUCTION	1	EA				
			HEADER FOR THE FOGGING PUMPS OF GTE#1						
			ANDGTE#3#FABRICATE NEW HEADER FOGGING						
			PUMPS USING 6#						
			SS316L, SCH-10 OR BETTER#THE HEADER TO BE						
			PROVIDED WITH SUCTION NOZZLES FOR EACH						
			PUMP AS PERTHE EXISTING FOGGING PUMP						
			ARRANGEMENT.						
			-#EXISTING SUCTION ISOLATION VALVES COULD						
			BE RE-USED FOR THE NEWHEADER#HEADER						
			SHALL BE PROVIDED WITH NEW ½# VENT AND						
			DRAIN WITH IS						
			OLATIONVALVES ROUTED TO SKID						
			DRAINS#RE-ERECT THE NEW HEADER PARALLEL						
			TO THE EXISTING SUCTION HEADER ANDCONNECT						
		IT TO THE EXISTING							
		PUMP SUCTION PIPING AND OTHER							
		INSTRUMENTS#DISCONNECT EXISTING PUMP							
			SUCTION HEADER FROM THE DM WATER SUPPLY						
			LINEAND RE-CONNECT THE						
		NEW HEADER#HYDRO TEST NEW HEADER AT							
		10BARG#ALL PIPING, FITTINGS, FLANGES,							
			VALVES, BLINDS REQUIRED FOR THE JOBSHALL BE						





RFQ NUMBER : 2332400815

DATE : 25.03.2024 **REQ No** : 1032401259

REQ TITLE : E#STATION ENERGY FOG

DELIVERY LOCATION

CLOSING DATE : 03.04.2024

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MADE OF SS 316L MATERIAL AND NEEDS TO BE PROVIDED BY CONTRACTOREXCEPT FOR THE SUCTION ISOLATION VALVES WHICH CAN BE RE-USED FROMEXISTING HEADER#AN 1# NOZZLE WITH ISOLATION FOR FUTURE CONNECTION#RATING OF ALL FITTINGS TO BE NOT LESS THAN #150LBS-#CLEANING AND RE-PAINTING OF THE FOGGING PUMP SKID INCLUDING ALLPIPING AND EQUIPMENT#S AS APPLICABLE#FLUSH & CLEAN PIPING INTERNALLY.2.#ALL MANPOWER, ENGINE ERING, SUPERVISING REQUIRED FOR THE ABOVE JOBSINCLUDING ALL TOOLS, TACKLES, AND EQUIPMENT#S.3.#ALL PIPING USED FOR THE ABOVE WOKS SH ALL BE SS316L SEAM LESS PIPEAND STRUCTURAL STEEL SHALL BE HOT DIP GALVANIZED CARBON STEEL.						
2		ITEM-00001	SCOPE OF WORKS1.#PROVIDING NEW SUCTION HEADER FOR THE FOGGING PUMPS OF GTE#1 ANDGTE#3#FABRICATE NEW HEADER FOGGING	1	EA				





RFQ NUMBER : 2332400815

DATE : 25.03.2024 **REQ No** : 1032401259

REQ TITLE : E#STATION ENERGY FOG

DELIVERY LOCATION

CLOSING DATE : 03.04.2024

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PUMPS USING 6#						
			SS316L, SCH-10 OR BETTER#THE HEADER TO BE						
			PROVIDED WITH SUCTION NOZZLES FOR EACH						
			PUMP AS PERTHE EXISTING FOGGING PUMP						
			ARRANGEMENT.						
			-#EXISTING SUCTION ISOLATION VALVES COULD						
			BE RE-USED FOR THE NEWHEADER#HEADER						
			SHALL BE PROVIDED WITH NEW 1/2# VENT AND						
			DRAIN WITH IS						
			OLATIONVALVES ROUTED TO SKID						
			DRAINS#RE-ERECT THE NEW HEADER PARALLEL						
			TO THE EXISTING SUCTION HEADER ANDCONNECT						
			IT TO THE EXISTING						
			PUMP SUCTION PIPING AND OTHER						
			INSTRUMENTS#DISCONNECT EXISTING PUMP						
			SUCTION HEADER FROM THE DM WATER SUPPLY						
			LINEAND RE-CONNECT THE						
			NEW HEADER#HYDRO TEST NEW HEADER AT						
			10BARG#ALL PIPING, FITTINGS, FLANGES,						
			VALVES, BLINDS REQUIRED FOR THE JOBSHALL BE						
			MADE OF SS						
			316L MATERIAL AND NEEDS TO BE PROVIDED BY						
			CONTRACTOREXCEPT FOR THE SUCTION			1			





RFQ NUMBER : 2332400815

DATE : 25.03.2024 **REQ No** : 1032401259

REQ TITLE : E#STATION ENERGY FOG

DELIVERY LOCATION

CLOSING DATE : 03.04.2024

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ISOLATION VALVES WHICH CAN BE RE-USED						
			FROMEXISTING HEADER						
			#AN 1# NOZZLE WITH ISOLATION FOR FUTURE						
			CONNECTION#RATING OF ALL FITTINGS TO BE						
			NOT LESS THAN #150LBS-#CLEANING AND						
			RE-PAINTING						
			OF THE FOGGING PUMP SKID INCLUDING						
			ALLPIPING AND EQUIPMENT#S AS						
			APPLICABLE#FLUSH & CLEAN PIPING						
			INTERNALLY.2.#ALL MANPOWER, ENGINE						
			ERING, SUPERVISING REQUIRED FOR THE ABOVE						
			JOBSINCLUDING ALL TOOLS, TACKLES, AND						
			EQUIPMENT#S.3.#ALL PIPING USED FOR THE						
			ABOVE WOKS SH						
			ALL BE SS316L SEAM LESS PIPEAND STRUCTURAL						
			STEEL SHALL BE HOT DIP GALVANIZED CARBON						
			STEEL.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:





RFQ NUMBER : 2332400815

DATE : 25.03.2024 **REQ No** : 1032401259

REQ TITLE: E#STATION ENERGY FOG

DELIVERY LOCATION

CLOSING DATE : 03.04.2024

CLOSING TIME : 10:00:00

E#STATION ENERGY FOG SKID HEADER REPLACEMENT FOR TWO UNIT RE-ERECT THE NEW HEADER PARALLEL TO THE EXISTING SUCTION HEADER AND CONNECT IT TO THE EXISTING PUMP SUCTION PIPING AND OTHER INSTRUMENTS ALSO.

BIDDERS SHOULD PROVIDE TECHNICAL DATA SHEET, MATERIAL CATALOGUE, WITHOUT CERTIFED DOCCUMENTS, OFFER ARE NOT ACCEPTBLE.

FOR FURTHER DETAILS, PLEASE CONTACT ASM MYNUDDIN (0503620814)

MYNUDDIN.HOSSAIN@DEWA.GOV.AE /MARWAN AL MHEIRI (0501136322) (MARWAN.AL MHEIRI@DEWA.GOV.AE)

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

Page5 of 6





RFQ NUMBER : 2332400815

DATE : 25.03.2024 **REQ No** : 1032401259

REQ TITLE : E#STATION ENERGY FOG

DELIVERY LOCATION

CLOSING DATE : 03.04.2024 : 10:00:00

CLOSING TIME

SUPPLIER'S REMARKS:

SUPPLIER'S SIGNATURE AND STAMP