

هيئة كـهـرباء وميـاه دبـي Dubai Electricity&Water Authority



RFQ NUMBER	: 2332400849
DATE	: 28.03.2024
REQ No	: 1032401264
REQ TITLE	: SAND BLAST COATING PUMP
DELIVERY LOCATION	
CLOSING DATE	: 03.04.2024
CLOSING TIME	: 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	FIRE WATER ELECTRICAL PUMP NO. 02 CASING INTERNAL AND EXTERNAL SANDBLASTING AND COATING APPLICATION.PUMP DETAIL:PUMP TYPE: HGT1-200. 500PPUMP SERIAL NUMBER: 42697CAPACITY: 568M3/HRDISCHARGE PRESSURE: 10.8 BARSPEED:1490 RPMDETAIL WORK SCOPE.1.SAND BLASTING AND CORRO SION REMOVAL FOR FIREWATER PUMP CASING OF TWOSPLIT HALVES. WHITE METAL SURFACE FINISHES ACCORDING TO SA-3 GRADESTANDARD.2.DAMAGED / PITTED PORTION OF THE PUMP INTERNAL CASING TO BE FILLED WITHMETAL AND LEVELLED TO PUMP CASING INTERNAL SURFACE STRUCTURE TO FORMEXCE LLENT ADHESION ON PUMP CASING.3.UPON SURFACE PREPARATION, APPLICATION OF EPOXY COATING ON PUMPINTERNAL CASING STRUCTURE TO FORM HARD BONDING WITH PUMP BASE METAL.4.EPOXY SHOULD HAVE GOOD LEVELLING AND GOOD CHEMICAL RESISTANTPROPERTIES AGAINST	1	SET				



هيئة كـهـرباء وميـاه دبـي Dubai Electricity&Water Authority



RFQ NUMBER	: 2332400849
DATE	: 28.03.2024
REQ No	: 1032401264
REQ TITLE	: SAND BLAST COATING PUMP
DELIVERY LOCATION	
CLOSING DATE	: 03.04.2024
CLOSING TIME	: 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SERVICE WATER.5.SHOUL						
			D HAVE VERY HIGH ABRASION, EROSION AND						
			CORROSION RESISTANCE.6.IT SHOULD HAVE						
			EXCELLENT ADHESION OF PUMP CASING AND						
			SHOULD NOT AFFECT						
			WITH WORKING MEDIA OF SERVICE						
			WATER.7.WARRANTY OF 1 YEAR FOR THE PUMP						
			COATING AND WORKMANSHIP.8.PUMP EXTERNAL						
			CASING TO BE SAND BLAS						
			TED AND PAINTED WITH RED COLOR.9. A FINAL						
			REPORT CONTAINING PHOTOGRAPH OF SAND						
			BLASTING AND COATINGAPPLICATION FOR EACH						
			OMPLETION AND WITH RECOMMENDATION						
			FORNEXT PUMP CASING OVERHAUL.FOR WORK EXECUTION / TECHNICAL DETAIL PLEASE CONTACT						
			ZAMIR ALWARE ONZ						
			AMIR ALWARE ONZ AMIR ALWARE@DEWA.GOV.AE / 04-8140304 OR						
			050-9152946 ORSUMIT MEHTA ON						
			SUMIT.MEHTA@DEWA.GOV.AE 052-1052809 OR						
			04-8140306FIRE WATER ELE						
			CTRICAL PUMP NO. 02 CASING INTERNAL AND						
			EXTERNAL SANDBLASTING AND COATING						

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.



هيئة كـهـرباء وميـاه دبـي Dubai Electricity&Water Authority



RFQ NUMBER	: 2332400849
DATE	: 28.03.2024
REQ No	: 1032401264
REQ TITLE	: SAND BLAST COATING PUMP
DELIVERY LOCATION	
CLOSING DATE	: 03.04.2024
CLOSING TIME	: 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			APPLICATION.PUMP DETAIL:PUMP TYPE:						
			HGT1-200.500PPUMP SERIA						
			L NUMBER: 42697CAPACITY: 568M3/HRDISCHARGE						
			PRESSURE: 10.8 BARSPEED:1490 RPMDETAIL						
			WORK SCOPE.1. SAND BLASTING AND CORROSION						
			REMOVAL						
			FOR FIREWATER PUMP CASING OF TWOSPLIT						
			HALVES. WHITE METAL SURFACE FINISHES						
			ACCORDING TO SA-3						
			GRADESTANDARD.2.#DAMAGED / PITTED PORTI						
			ON OF THE PUMP INTERNAL CASING TO BE						
			FILLEDWITH METAL AND LEVELLED TO PUMP						
			CASING INTERNAL SURFACE STRUCTURE TOFORM						
			EXCELLENT ADHESI						
			ON ON PUMP CASING.3.#UPON SURFACE						
			PREPARATION, APPLICATION OF EPOXY COATING						
			ON PUMPINTERNAL CASING STRUCTURE TO FORM						
			TH PUMP BASE METAL.4.#EPOXY SHOULD HAVE						
			GOOD LEVELLING AND GOOD CHEMICAL						
			RESISTANTPROPERTIES AGAINST SERVICE						
			WATER.5.#SHOULD HAVE VE						
			RY HIGH ABRASION, EROSION AND CORROSION						

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.



هيئة كـهـربـاء وميـاه دبـي Dubai Electricity&Water Authority



RFQ NUMBER	: 2332400849
DATE	: 28.03.2024
REQ No	: 1032401264
REQ TITLE	: SAND BLAST COATING PUMP
DELIVERY LOCATION	
CLOSING DATE	: 03.04.2024
CLOSING TIME	: 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RESISTANCE.6.#IT SHOULD HAVE EXCELLENT ADHESION OF PUMP CASING AND SHOULD NOTAFFECT WITH WOR KING MEDIA OF SERVICE WATER.7.#WARRANTY OF 1 YEAR FOR THE PUMP COATING AND WORKMANSHIP.8.#PUMP EXTERNAL CASING TO BE SAND BLASTED AN D PAINTED WITH RED COLOR.9. A FINAL REPORT CONTAINING PHOTOGRAPH OF SAND BLASTING AND COATINGAPPLICATION FOR EACH STAGE UPON COMPLET ION AND WITH RECOMMENDATION FORNEXT PUMP CASING OVERHAUL.FOR WORK EXECUTION / TECHNICAL DETAIL PLEASE CONTACT ZAMIR ALWARE ONZAMIR.A LWARE@DEWA.GOV.AE / 04-8140304 OR 050-9152946 ORSUMIT MEHTA ON SUMIT.MEHTA@DEWA.GOV.AE 052-1052809 OR 04-8140306						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

SAND BLAST COATING PUMP

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page4 of 5



هيئة كـهـربـاء وميـاه دبـي Dubai Electricity&Water Authority



RFQ NUMBER	: 2332400849
DATE	: 28.03.2024
REQ No	: 1032401264
REQ TITLE	: SAND BLAST COATING PUMP
DELIVERY LOCATION	
CLOSING DATE	: 03.04.2024
CLOSING TIME	: 10:00:00

STANDARD TERMS & CONDITIONS

1) Prices should be 'DDP' delivery duty paid at DEWA stores.

2) Quotation to be submitted only in local currency U.A.E Dirhams

3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material

4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP