

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	1. THE SCOPE OF WORKSCOPE WORKS FOR THE AIR INTAKE DUCT ARE LIMITED TO DUCTS OUTSIDE THE GTHALL FOR ONE GAS TURBINES UNIT OF D-REPO WERING.ON SUCCESSFUL COMPLETION REPEAT ORDER MAY BE CONSIDERED UNDER DEWADISCRETION.2.1 INSPECTION AND CONDITION ASSESSMENT; THE CONTRACTOR IS EXPECTED TOCARRY OUT THE A DETAILED INSPECTION OF THE AIR INTAKE FILTER HOUSING,CONNECTING DUCTS AND ITS SUPPORTING STRUCTURE OUTSIDE THE D REP GT HALLTO STUDY THE IMPACT OF CORROSION AND TO IDENTIFY THE SERIOUSLY CORRODEDSTRUCTURAL MEMBERS AND ITS JOIN TS. THE ASSESSMENT SHALL BE DONE BY AQUALIFIED AND EXPERIENCED STRUCTURAL ENGINEER BASED ON RELEVANTINTERNATIONAL STANDARDS.THE DATA REQUIRED FOR ASSESSMENT SHALL BE OBTAINED BY THE CONTRACTOR BYPHYSICAL INSPECTION OF THE SITES AND NON-	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DESTRUCTIVE EXAMINATIONS (N DE)LIKE, ULTRASONIC SCANNING, DYE PENETRATION TESTS, MAGNETIC PARTICLE TESTETC. DESIGN INFORMATION COULD BE PROVIDED BY DEWA AS FAR AS AVAILABLE.CONTRACTOR IS EXPECTED TO MAKE HIS ENGINEERING JUDGEMENT TO UNDERSTANDTHE MISSING DESIGN INFORMATION#S IF ANY. BASED ON THE INSPECTION AND NDERESULTS CONTRACTOR SHALL ASSESS THE STRUCTURAL INTEGRITY AND RECOMMENDCORRECTIVE MEASURES REQUIRED TO ENSURE RELIABLE LIFE UNTIL THE SCHEDULEDDE-COMMISSIONING OF THE PLANT. THE NUMBER OF SAMPLING POINTS FOR NDT FORTHE ASSESSMENT OF THE STRUC TURE INTEGRITY SHALL BE BASED RELEVANTINTERNATIONAL STANDARDS AND SHALL BE APPROVED BY DEWA.2.2 REPAIR WORKS BASED ON THE INTEGRITY ASSESSMENT CONTRACTOR SHALLCARRY OUT ALL RECOMMENDED REPAIR WORKS TO RESTORE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE INTEGRITY OF THE FILTER HOUSE ASSEMBLY, DUCT AND SUP</p> <p>PORTING STRUCTURES. THE NATURE OF THEREPAIR SHALL BE TO REPLACE ALL SERIOUSLY CORRODED STRUCTURAL & DUCTPARTS MEMBERS THAT AFFECT IN TEGRITY OF THE AIR INTAKE SYSTEM. WHEREVERDEFECTS ARE MINOR MUTUALLY AGREED REPAIR SOLUTION CAN BE ADOPTED. THEREPAIR/REPLACEMENT SH</p> <p>ALL BE APPLICABLE TO BELOW MEMBERS OF THE FILTERHOUSING , STRUCTURE AND DUCTS BUT NOT LIMITED TO ; # STEEL STRUCTURALMEMBERS LIKE BE</p> <p>AMS, COLUMNS, BRACING. TIE-RODS ETC. THAT WEAKENSSTRUCTURAL INTEGRITY WITH EQUIVALENT OR SUPERIOR STEEL STRUCTURALMEMBERS. ALL STEEL STRUCTURAL MEMBERS SEVERELY PITTED WITH CRACKS ANDCORROSION HOLES SHALL BE REPLACED IRRESPECTIVE OF INTEGRITY ASSESSMENTFINDING. #</p> <p>ALL CORRODED GUSSET PLATES, JOINTS, NUTS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AND BOLTS # ALLCORRODED HANDRAILS # ALL CORRODED GRATINGS. ALL GRATING TO BE TACKWELDED TO SUPPORT BEAMS AT A FEW PLACES IN ADDITION TO GRATING CLIPS. #WHEREVER REPLACEMENT IS PRACTICALLY NOT POSSIBLE, NATURE OF THE REPAIRS HALL BE MUTUALLY AGREED AND DISCUSSED. # REPAIR OF THE DUCTS AND FILTERHOUSE WALLS SHALL BE DONE BY REPLACING AFFECTED PART BY PATCH WORKS WITHSIMILAR MATERIAL OF SIMILAR THICKNESS OR HIGHER AS MUTUALLY AGREED. #WHILE REPLACING THE CRITICAL STRUCTURAL MEMBERS IT I S NECESSARY TOPROVIDE SUITABLE TEMPORARY SUPPORTS TO ENSURE SAFETY OF REMAININGSTRUCTURES. SUCH TEMPORARY SUPPORTS SHALL BE SUITABLY DESIGNED TO TAKEALL APPLICABLE STATIC AND DYNAMIC LOADS. TEMPORARY SUPPORT DRAWINGSSHALL BE SUBMITTED FOR PRIOR APPROVAL OF DEWA. #						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ALL STEEL STRUCTURESUSED FOR THE REPLACEMENT SHALL HOT DIP GALVANIZED CARBON STEELEQUIVALENT TO EXISTING MATERIAL OR SUPERIOR. DEWA PRIOR APPROVAL ISNECESSARY FOR ALL REPLACEMENT MATERIALS# ALL SCAFFOLDING REQUIRED FOR THE WORKS ARE IN THE CONTRACTOR SCOPE. #ALL FIELD QUALITY TESTS REQUIRED TO CONFIRM THE COMPLIANCE OF THE WORKSARE INCLUDED IN THE CONTRACTOR SCOPE. #BIDDERS MAY PLEASE NOTE TH AT THEQUANTITY OF REPLACEMENT WORKS TO BE FINALIZED BASED ON INSPECTIONFINDING AND RECOMMENDATIONS APPROVED BY DEWA. AS SUCH BIDDER NEEDS TOQUOTE FOR THE REPAIR WORKS UNDER THIS CLAUSE WITH AN ESTIMATED QUANTITYAND UNIT RATES IN KILOGRAM BASIS FOR THE DESIGN, FABRICATION, HOT DIPGALVANIZING, SUPPLY AND INSTALLATION SCOPE OF WORKS.THE PAYMENT FOR THE REPAIR WORKS WILL BE BASED ON THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ACTUAL REP LACEMENTWORKS PERFORMED AS CERTIFIED BY DEWA.2.3 SURFACE CLEANING AND PAINTING THE SURFACE CLEANING AND PAINTINGSHALL BE TO WITHSTAN D THE CORROSION CATEGORY ACCORDING TO ISO 12944-2:C5-M: COASTAL AREA WITH HIGH SALINITY. ACCORDING TO ISO12944-5 THEEXPECTED DURABIL ITY OF THE PAINTING IS: HIGH (H): >15 YEARS. ADJACENTPLANTS AND EQUIPMENT SHALL BE PROTECTED DURING PAINTING WORKS WITHAPPROPRIATE C OVERS LIKE TARPULIN. THE EXTERIOR SURFACES OF THE FILTERHOUSE, DUCTS AND SUPPORTING STRUCTURE SHALL BE THOROUGHLY BLAST CLEANEDTO R EMOVE ALL OLD PAINTING AND CORROSION AND TO EXPOSE THE BASE METALPRIOR TO THE PAINTING. THE BLASTED SURFACES SHALL BE CLEANED ACCORD ANCEWITH EN ISO 8501-1 OR SSPC -VIS1 RESPECTIVELY TO GRADE SA 2 ½ OR SP10.THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONTRACTOR SHALL PROTECT ALL ADJACENT EQUIPMENT#S AND PLANTS DURINGTHE BLASTING OPERATION. OPEN BLASTING IS NOT ALLOWED. EXTREME CARE SHALLBE TAKEN TO ENSURE THAT NO ABRASIVE PARTICLE OR FLUID AS PASSING TO THEAIR INTAKE PASSAGE OF GAS TURBINE. FOLLOWING THE SURFACE CLEANING THEPAINTING THE COMPLETE EXTERIOR SHALL BE PAINTED FOR TOTAL A DRY FILMTHICKNESS OF 320#M WHICH INCLUDES INORGANIC ZINC PRIMER COAT FOLLOWED BY2 LAYERS OF EPOXY POLYAMIDE AND ONE COAT OF TOUCH UP. THE DETAILED SPECIFICATION ON SURFACE CLEANING & PAINTING IS THE PAINTING SHALL BEPERFORMED BY PROFESSIONAL PA INTING CONTRACTORS AND THE CONTRACTOR SHALLPREPARE HIS OWN PAINTING SPECIFICATION AND SUBMIT FOR DEWA APPROVALPRIOR TO THE APPLICATI ON. THE COLOR SCHEME SHALL BE LIKE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			EXISTINGSTRUCTURAL AND DUCT PAINTING. ONLY PAINTING REPAIR WORKS ARE ENVISAGEDFOR THE INTERIOR SU RFACES OF FILTER HOUSE AND DUCT.CONTRACTOR SHALL PROVIDE A SEPARATE RECTIFICATION PROCEDURE FOR THEINTERIOR SURFACES.3. DOCUMENTS RE QUIRED BEFORE STARTING THE WORK PRIOR TO COMMENCEMENT OFWORK, SUCCESSFUL BIDDER SHALL SUBMIT THE MINIMUM FOLLOWING DOCUMENTSINDIVIDU ALLY FOR EACH GAS TURBINE AND GET IT APPROVED BY DEWA: I.COMPLETION OF THE CONTRACTUAL FORMALITIES II. INTEGRITY ASSESSMENTPROCEDURE . III. INTEGRITY ASSESSMENT DOCUMENT WITH REPAIR PROCEDURES.IV. REPAIR/ REPLACEMENT PROCEDURE. V. MATERIAL QUALITY CERTIFICATES. VI. TEMPORARY SUPPORT ARRANGEMENT WITH SUPPORTING CALCULATIONS. VII. SURFACECLEANING AND PAINTING SPECIFICATION VIII. WORK PLAN IX. METH						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OD OF STATEMENTS X. RISK ASSESSMENT XI. DRAWING/DOCUMENTS AS NECESSARY TO WORK EXECUTION XII. SITE QUALITY INSPECTION PROTOCOLS. 4. OBLIGATIONS OF THE CONTRACTOR # THE CONTRACTOR IS EXPECTED TO SUBMIT A MASTER PROGRAM COVERING THE FULL SCOPE THIS PRIOR TO COMMENCEMENT OF HIS WORK CLEARLY INDICATING THE PROPOSED #START# AND #FINISH# DATES OF EACH ACTIVITY IN BAR CHART. # DUE TO PLANT OPERATIONAL NEEDS, IT IS LIKELY THAT DEWA RESERVE THE RIGHT TO CHANGE THE SHUTDOWN SCHEDULE WITH A VERY SHORT NOTICE, IN THAT CASE THE CONTRACTOR IS REQUIRED TO REVISE HIS INSPECTION PROGRAM IN CONSULTATION WITH DEWA ENGINEER CONCERNED. HOWEVER, THE CONTRACTOR IS NOT ENTITLED TO PAYMENT OF ANY COMPENSATION WHATSOEVER FROM DEWA BECAUSE OF SUCH WAITING TIME OR DELAY. # CONTRACTOR SHALL TRY HIS BEST TO</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DELIVER THE QUALITY JOB IN ACCORDANCE WITH A WORLD-CLASS LEVEL OF EXCELLENCE AND ACCORDING TO THE SCHEDULE SET FORTH BY DEWA. # CONTRACTOR SHALL TAKE NECESSARY PRECAUTION TO AVOID ANY DAMAGE OF THE PLANT EQUIPMENT#S WHILE CARRYING OUT THE WORK. # CONTRACTOR SHALL COMPLETE ALL ACTIVITIES WITHIN SCHEDULE, SO THAT OUTAGE EXTENSION IN ANY CASE SHALL BE AVOIDED. 5. DURATION OF WORK # THE WORK SHALL BE EXECUTED IN THE YEAR 2024-25 AS PER OUR DEWA OUTAGE SCHEDULE. THE INTEGRITY ASSESSMENT MAY BE PERMITTED PRIOR TO THE ACTUAL OUTAGE OF THE UNITS. TOTAL DURATION OF THE WORK THAT REQUIRE OUTAGE OF THE GAS TURBINE SHALL NOT EXCEED 4 WEEKS. # THE CONTRACTOR WILL BE PROVIDED THE TENTATIVE OUTAGE SCHEDULE OF THE UNITS AT THE TIME OF AWARD OF CONTRACT. 6. REPORTS AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DOCUMENTS TO BE SUBMITTED BY THE BIDDER: BIDDER SHALL SUBMIT FOLLOWING DOCUMENTS ALONG WITH THEIR BID PROPOSAL #ORGANIZATIONAL CHART FOR THE PROJECT EXECUTION SHOWING DIVISION OF RESPONSIBILITY, LIST OF NAMES, TITLES, DUTIES, AND JOB DESCRIPTIONS FOR KEY PERSONNEL. THE JOB DESCRIPTION SHALL STATE THE EXPERIENCE, LICENSES, AND CERTIFICATIONS FOR EACH POSITION. # DETAILS OF						
2		ITEM-00001	1. THE SCOPE OF WORKS SCOPE WORKS FOR THE AIR INTAKE DUCT ARE LIMITED TO DUCTS OUTSIDE THE GTHALL FOR ONE GAS TURBINES UNIT OF D-REPO WORKING. ON SUCCESSFUL COMPLETION REPEAT ORDER MAY BE CONSIDERED UNDER DEWA DISCRETION. 2.1 INSPECTION AND CONDITION ASSESSMENT; THE CONTRACTOR IS EXPECTED TO CARRY OUT THE A DETAILED INSPECTION OF THE AIR INTAKE FILTER HOUSING, CONNECTING DUCTS AND ITS	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SUPPORTING STRUCTURE OUTSIDE THE D REP GT HALL TO STUDY THE IMPACT OF CORROSION AND TO IDENTIFY THE SERIOUSLY CORRODED STRUCTURAL MEMBERS AND ITS JOINTS. THE ASSESSMENT SHALL BE DONE BY A QUALIFIED AND EXPERIENCED STRUCTURAL ENGINEER BASED ON RELEVANT INTERNATIONAL STANDARDS. THE DATA REQUIRED FOR ASSESSMENT SHALL BE OBTAINED BY THE CONTRACTOR BY PHYSICAL INSPECTION OF THE SITES AND NON-DESTRUCTIVE EXAMINATIONS (NDE) LIKE, ULTRASONIC SCANNING, DYE PENETRATION TESTS, MAGNETIC PARTICLE TEST ETC. DESIGN INFORMATION COULD BE PROVIDED BY DEWA AS FAR AS AVAILABLE. CONTRACTOR IS EXPECTED TO MAKE HIS ENGINEERING JUDGEMENT TO UNDERSTAND THE MISSING DESIGN INFORMATION#S IF ANY. BASED ON THE INSPECTION AND NDE RESULTS CONTRACTOR SHALL ASSESS THE STRUCTURAL INTEGRITY AND						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RECOMMENDCORRECTIVE MEASURES REQUIRED TO ENSURE RELIABLE LIFE UNTIL THE SCHEDULEDDE-COMMISSIONING OF THE PLANT. THE NUMBER OF SAMPLING POINTS FOR NDT FORTHE ASSESSMENT OF THE STRUC TURE INTEGRITY SHALL BE BASED RELEVANTINTERNATIONAL STANDARDS AND SHALL BE APPROVED BY DEWA.2.2 REPAIR WORKS BASED ON THE INTEGRITY ASSESSMENT CONTRACTOR SHALLCARRY OUT ALL RECOMMENDED REPAIR WORKS TO RESTORE THE INTEGRITY OF THEFILTER HOUSE ASSEMBLY, DUCT AND SUP PORTING STRUCTURES. THE NATURE OF THEREPAIR SHALL BE TO REPLACE ALL SERIOUSLY CORRODED STRUCTURAL & DUCTPARTS MEMBERS THAT AFFECT IN TEGRITY OF THE AIR INTAKE SYSTEM. WHEREVERDEFECTS ARE MINOR MUTUALLY AGREED REPAIR SOLUTION CAN BE ADOPTED. THEREPAIR/REPLACEMENT SH ALL BE APPLICABLE TO BELOW MEMBERS OF THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FILTERHOUSING , STRUCTURE AND DUCTS BUT NOT LIMITED TO ; # STEEL STRUCTURALMEMBERS LIKE BEAMS, COLUMNS, BRACING. TIE-RODS ETC. THAT WEAKENSSTRUCTURAL INTEGRITY WITH EQUIVALENT OR SUPERIOR STEEL STRUCTURALMEMBERS. ALL STEEL STRUCTURAL MEMBERS SEVERELY PITTED WITH CRACKS ANDCORROSION HOLES SHALL BE REPLACED IRRESPECTIVE OF INTEGRITY ASSESSMENTFINDING. # ALL CORRODED GUSSET PLATES, JOINTS, NUTS AND BOLTS # ALLCORRODED HANDRAILS # ALL CORRODED GRATINGS. ALL GRATING TO BE TACKWELDED TO SUPPORT BEAMS AT A FEW PLACES IN ADDITION TO GRATING CLIPS. #WHEREVER REPLACEMENT IS PRACTICALLY NOT POSSIBLE, NATURE OF THE REPAIRS SHALL BE MUTUALLY AGREED AND DISCUSSED. # REPAIR OF THE DUCTS AND FILTERHOUSE WALLS SHALL BE DONE BY REPLACING AFFECTED PART BY PATCH						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WORKS WITHSIMILAR MATERIAL OF SIMILAR THICKNESS OR HIGHER AS MUTUALLY AGREED. #WHILE REPLACING THE CRITICAL STRUCTURAL MEMBERS IT I S NECESSARY TOPROVIDE SUITABLE TEMPORARY SUPPORTS TO ENSURE SAFETY OF REMAININGSTRUCTURES. SUCH TEMPORARY SUPPORTS SHALL BE SUITABLY DESIGNED TO TAKEALL APPLICABLE STATIC AND DYNAMIC LOADS. TEMPORARY SUPPORT DRAWINGSShall BE SUBMITTED FOR PRIOR APPROVAL OF DEWA. # ALL STEEL STRUCTURESUSED FOR THE REPLACEMENT SHALL HOT DIP GALVANIZED CARBON STEELEQUIVALENT TO EXISTING MATERIAL OR SUPERIOR. DEWA PRIOR APPROVAL ISNECESSARY FOR ALL REPLACEMENT MATERIALS# ALL SCAFFOLDING REQUIRED FOR THE WORKS ARE IN THE CONTRACTOR SCOPE. #ALL FIELD QUALITY TESTS REQUIRED TO CONFIRM THE COMPLIANCE OF THE WORKSARE INCLUDED IN THE CONTRACTOR SCOPE. #BIDDERS MAY PLEASE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NOTE TH AT THEQUANTITY OF REPLACEMENT WORKS TO BE FINALIZED BASED ON INSPECTIONFINDING AND RECOMMENDATIONS APPROVED BY DEWA. AS SUCH BIDDER NEEDS TOQUOTE FOR THE REPAIR WORKS UNDER THIS CLAUSE WITH AN ESTIMATED QUANTITYAND UNIT RATES IN KILOGRAM BASIS FOR THE DESIGN, FABR ICATION, HOT DIPGALVANIZING, SUPPLY AND INSTALLATION SCOPE OF WORKS.THE PAYMENT FOR THE REPAIR WORKS WILL BE BASED ON THE ACTUAL REP LACEMENTWORKS PERFORMED AS CERTIFIED BY DEWA.2.3 SURFACE CLEANING AND PAINTING THE SURFACE CLEANING AND PAINTINGSHALL BE TO WITHSTAN D THE CORROSION CATEGORY ACCORDING TO ISO 12944-2:C5-M: COASTAL AREA WITH HIGH SALINITY. ACCORDING TO ISO12944-5 THEEXPECTED DURABIL ITY OF THE PAINTING IS: HIGH (H): >15 YEARS. ADJACENTPLANTS AND EQUIPMENT SHALL BE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PROTECTED DURING PAINTING WORKS WITHAPPROPRIATE C OVERS LIKE TARPAULIN. THE EXTERIOR SURFACES OF THE FILTERHOUSE, DUCTS AND SUPPORTING STRUCTURE SHALL BE THOROUGHLY BLAST CLEANEDTO R EMOVE ALL OLD PAINTING AND CORROSION AND TO EXPOSE THE BASE METALPRIOR TO THE PAINTING. THE BLASTED SURFACES SHALL BE CLEANED ACCORD ANCEWITH EN ISO 8501-1 OR SSPC -VIS1 RESPECTIVELY TO GRADE SA 2 ½ OR SP10.THE CONTRACTOR SHALL PROTECT ALL ADJACENT EQUIPMENT#S AND PLANTS DURINGTHE BLASTING OPERATION. OPEN BLASTING IS NOT ALLOWED. EXTREME CARE SHALLBE TAKEN TO ENSURE THAT NO ABRASIVE PARTICLE OR FLUID AS PASSING TO THEAIR INTAKE PASSAGE OF GAS TURBINE. FOLLOWING THE SURFACE CLEANING THEPAINTING THE COMPLETE EXTERIOR SHALL BE PAINTED FOR TOTAL A DRY FILMTHICKNESS OF</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			320#M WHICH INCLUDES INORGANIC ZINC PRIMER COAT FOLLOWED BY 2 LAYERS OF EPOXY POLYAMIDE AND ONE COAT OF TOUCH UP. THE DETAILED SPECIFICATION ON SURFACE CLEANING & PAINTING IS THE PAINTING SHALL BE PERFORMED BY PROFESSIONAL PAINTING CONTRACTORS AND THE CONTRACTOR SHALL PREPARE HIS OWN PAINTING SPECIFICATION AND SUBMIT FOR DEWA APPROVAL PRIOR TO THE APPLICATION. THE COLOR SCHEME SHALL BE LIKE EXISTING STRUCTURAL AND DUCT PAINTING. ONLY PAINTING REPAIR WORKS ARE ENVISAGED FOR THE INTERIOR SURFACES OF FILTER HOUSE AND DUCT. CONTRACTOR SHALL PROVIDE A SEPARATE RECTIFICATION PROCEDURE FOR THE INTERIOR SURFACES. 3. DOCUMENTS REQUIRED BEFORE STARTING THE WORK PRIOR TO COMMENCEMENT OF WORK, SUCCESSFUL BIDDER SHALL SUBMIT THE MINIMUM FOLLOWING DOCUMENTS INDIVIDUALLY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ALLY FOR EACH GAS TURBINE AND GET IT APPROVED BY DEWA: I.COMPLETION OF THE CONTRACTUAL FORMALITIES II. INTEGRITY ASSESSMENTPROCEDURE . III. INTEGRITY ASSESSMENT DOCUMENT WITH REPAIR PROCEDURES.IV. REPAIR/ REPLACEMENT PROCEDURE. V. MATERIAL QUALITY CERTIFICATES. VI. TEMPORARY SUPPORT ARRANGEMENT WITH SUPPORTING CALCULATIONS. VII. SURFACECLEANING AND PAINTING SPECIFICATION VIII. WORK PLAN IX. METH OD OFSTATEMENTS X. RISK ASSESSMENT XI. DRAWING/DOCUMENTS AS NECESSARY TO WORKEXECUTION XII. SITE QUALITY INSPECTION PROTOCOLS.4. OBL IGATIONS OF THE CONTRACTOR # THE CONTRACTOR IS EXPECTED TO SUBMITA MASTER PROGRAM COVERING THE FULL SCOPE THIS POPRIOR TO COMMENCEME NT OFHIS WORK CLEARLY INDICATING THE PROPOSED #START# AND #FINISH# DATES OFEACH ACTIVITY IN BAR CHART. # DUE TO PLANT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OPERATIONAL NE EDS, IT IS LIKELY THAT DEWA RESERVE THE RIGHT TO CHANGE THE SHUTDOWN SCHEDULE WITH A VERY SHORT NOTICE, IN THAT CASE THE CONTRACTOR IS REQUIRED TO REVISE HIS INSPECTION PROGRAM IN CONSULTATION WITH DEWA ENGINEER CONCERNED. HOWEVER, THE CONTRACTOR IS NOT ENTITLED TO PA YMENT OF ANY COMPENSATION WHATSOEVER FROM DEWA BECAUSE OF SUCH WAITING TIME OR DELAY. # CONTRACTOR SHALL TRY HIS BEST TO DELIVER THE Q UALITY JOB IN ACCORDANCE WITH A WORLD-CLASS LEVEL OF EXCELLENCE AND ACCORDING TO THE SCHEDULE SET FORTH BY DEWA. # CONTRACTOR SHALL TA KE NECESSARY PRECAUTION TO AVOID ANY DAMAGE OF THE PLANT EQUIPMENT#S WHILE CARRYING OUT THE WORK. # CONTRACTOR SHALL COMPLETE ALL ACTI VITIES WITHIN SCHEDULE, SO THAT OUTAGE EXTENSION IN ANY CASE SHALL BE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AVOIDED.5. DURATION OF WORK # THE WORK SHALL BE EXECUTED IN THE YEAR 2024-25 ASPER OUR DEWA OUTAGE SCHEDULE. THE INTEGRITY ASSESSMENT MAY BE PERMITTEDPRIOR TO THE ACTUAL OUTAGE OF THE UNITS. TOTA</p> <p>L DURATION OF THE WORKSTHAT REQUIRE OUTAGE OF THE GAS TURBINE SHALL NOT EXCEED 4 WEEKS. # THECONTRACTOR WILL BE PROVIDED THE TENTATI</p> <p>VE OUTAGE SCHEDULE OF THE UNITSAT THE TIME OF AWARD OF CONTRACT.6. REPORTS AND DOCUMENTS TO BE SUBMITTED BY THE BIDDER: BIDDER SHALL</p> <p>SUBMIT FOLLOWING DOCUMENTS ALONG WITH THEIR BID PROPOSAL #ORGANIZATIONAL CHART FOR THE PROJECT EXECUTION SHOWING DIVISION OFRESPONSI</p> <p>BILITY, LIST OF NAMES, TITLES, DUTIES, AND JOB DESCRIPTIONS FORKEY PERSONNEL. THE JOB DESCRIPTION SHALL STATE THE EXPERIENCE, LICENS</p> <p>ES,AND CERTIFICATIONS FOR EACH POSITION. #</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DETAILS OF						
3		ITEM-00001	<p>1. THE SCOPE OF WORKSCOPE WORKS FOR THE AIR INTAKE DUCT ARE LIMITED TO DUCTS OUTSIDE THE GTHALL FOR ONE GAS TURBINES UNIT OF D-REPO</p> <p>WERING.ON SUCCESSFUL COMPLETION REPEAT ORDER MAY BE CONSIDERED UNDER DEWADISCRETION.2.1 INSPECTION AND CONDITION ASSESSMENT; THE CONTRACTOR IS EXPECTED TOCARRY OUT THE A DETAILED INSPECTION OF THE AIR INTAKE FILTER HOUSING,CONNECTING DUCTS AND ITS SUPPORTING STRUC</p> <p>TURE OUTSIDE THE D REP GT HALLTO STUDY THE IMPACT OF CORROSION AND TO IDENTIFY THE SERIOUSLY CORRODEDSTRUCTURAL MEMBERS AND ITS JOIN</p> <p>TS. THE ASSESSMENT SHALL BE DONE BY AQUALIFIED AND EXPERIENCED STRUCTURAL ENGINEER BASED ON RELEVANTINTERNATIONAL STANDARDS.THE DATA</p> <p>REQUIRED FOR ASSESSMENT SHALL BE OBTAINED BY THE CONTRACTOR BYPHYSICAL</p>	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INSPECTION OF THE SITES AND NON-DESTRUCTIVE EXAMINATIONS (NDE) LIKE, ULTRASONIC SCANNING, DYE PENETRATION TESTS, MAGNETIC PARTICLE TEST ETC. DESIGN INFORMATION COULD BE PROVIDED BY DEWA AS FAR AS AVAILABLE. CONTRACTOR IS EXPECTED TO MAKE HIS ENGINEERING JUDGEMENT TO UNDERSTAND THE MISSING DESIGN INFORMATION#S IF ANY. BASED ON THE INSPECTION AND NDE RESULTS CONTRACTOR SHALL ASSESS THE STRUCTURAL INTEGRITY AND RECOMMEND CORRECTIVE MEASURES REQUIRED TO ENSURE RELIABLE LIFE UNTIL THE SCHEDULED DE-COMMISSIONING OF THE PLANT. THE NUMBER OF SAMPLING POINTS FOR NDT FOR THE ASSESSMENT OF THE STRUCTURE INTEGRITY SHALL BE BASED ON RELEVANT INTERNATIONAL STANDARDS AND SHALL BE APPROVED BY DEWA. 2.2 REPAIR WORKS BASED ON THE INTEGRITY ASSESSMENT CONTRACTOR SHALL CARRY OUT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ALL RECOMMENDED REPAIR WORKS TO RESTORE THE INTEGRITY OF THE FILTER HOUSE ASSEMBLY, DUCT AND SUPPORTING STRUCTURES. THE NATURE OF THE REPAIR SHALL BE TO REPLACE ALL SERIOUSLY CORRODED STRUCTURAL & DUCT PARTS MEMBERS THAT AFFECT THE INTEGRITY OF THE AIR INTAKE SYSTEM. WHEREVER DEFECTS ARE MINOR MUTUALLY AGREED REPAIR SOLUTION CAN BE ADOPTED. THE REPAIR/REPLACEMENT SHALL ALL BE APPLICABLE TO BELOW MEMBERS OF THE FILTER HOUSING, STRUCTURE AND DUCTS BUT NOT LIMITED TO ; # STEEL STRUCTURAL MEMBERS LIKE BEAMS, COLUMNS, BRACING, TIE-RODS ETC. THAT WEAKEN STRUCTURAL INTEGRITY WITH EQUIVALENT OR SUPERIOR STEEL STRUCTURAL MEMBERS. ALL STEEL STRUCTURAL MEMBERS SEVERELY PITTED WITH CRACKS AND CORROSION HOLES SHALL BE REPLACED IRRESPECTIVE OF INTEGRITY ASSESSMENT FINDING. #</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ALL CORRODED GUSSET PLATES, JOINTS, NUTS AND BOLTS # ALLCORRODED HANDRAILS # ALL CORRODED GRATINGS. ALL GRATING TO BE TACKWELDED TO SUPPORT BEAMS AT A FEW PLACES IN ADDITION TO GRATING CLIPS. #WHEREVER REPLACEMENT IS PRACTICALLY NOT POSSIBLE, NATURE OF THE REPAIRS SHALL BE MUTUALLY AGREED AND DISCUSSED. # REPAIR OF THE DUCTS AND FILTERHOUSE WALLS SHALL BE DONE BY REPLACING AFFECTED PART BY PATCH</p> <p>WORKS WITHSIMILAR MATERIAL OF SIMILAR THICKNESS OR HIGHER AS MUTUALLY AGREED. #WHILE REPLACING THE CRITICAL STRUCTURAL MEMBERS IT I</p> <p>S NECESSARY TOPROVIDE SUITABLE TEMPORARY SUPPORTS TO ENSURE SAFETY OF REMAININGSTRUCTURES. SUCH TEMPORARY SUPPORTS SHALL BE SUITABLY DESIGNED TO TAKEALL APPLICABLE STATIC AND DYNAMIC LOADS. TEMPORARY SUPPORT DRAWINGSSHALL BE SUBMITTED FOR PRIOR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>APPROVAL OF DEWA. #</p> <p>ALL STEEL STRUCTURESUSED FOR THE REPLACEMENT SHALL HOT DIP GALVANIZED CARBON STEELEQUIVALENT TO EXISTING MATERIAL OR SUPERIOR. DEWA</p> <p>PRIOR APPROVAL ISNECESSARY FOR ALL REPLACEMENT MATERIALS# ALL SCAFFOLDING REQUIRED FOR THE WORKS ARE IN THE CONTRACTOR SCOPE. #ALL</p> <p>FIELD QUALITY TESTS REQUIRED TO CONFIRM THE COMPLIANCE OF THE WORKSARE INCLUDED IN THE CONTRACTOR SCOPE. #BIDDERS MAY PLEASE NOTE TH</p> <p>AT THEQUANTITY OF REPLACEMENT WORKS TO BE FINALIZED BASED ON INSPECTIONFINDING AND RECOMMENDATIONS APPROVED BY DEWA. AS SUCH BIDDER</p> <p>NEEDS TOQUOTE FOR THE REPAIR WORKS UNDER THIS CLAUSE WITH AN ESTIMATED QUANTITYAND UNIT RATES IN KILOGRAM BASIS FOR THE DESIGN, FABR</p> <p>ICATION, HOT DIPGALVANIZING, SUPPLY AND INSTALLATION SCOPE OF WORKS.THE PAYMENT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FOR THE REPAIR WORKS WILL BE BASED ON THE ACTUAL REPLACEMENT WORKS PERFORMED AS CERTIFIED BY DEWA.2.3 SURFACE CLEANING AND PAINTING THE SURFACE CLEANING AND PAINTING SHALL BE TO WITHSTAND THE CORROSION CATEGORY ACCORDING TO ISO 12944-2:C5-M: COASTAL AREA WITH HIGH SALINITY. ACCORDING TO ISO 12944-5 THE EXPECTED DURABILITY OF THE PAINTING IS: HIGH (H): >15 YEARS. ADJACENT PLANTS AND EQUIPMENT SHALL BE PROTECTED DURING PAINTING WORKS WITH APPROPRIATE COVERINGS LIKE TARPULIN. THE EXTERIOR SURFACES OF THE FILTERHOUSE, DUCTS AND SUPPORTING STRUCTURE SHALL BE THOROUGHLY BLAST CLEANED TO REMOVE ALL OLD PAINTING AND CORROSION AND TO EXPOSE THE BASE METAL PRIOR TO THE PAINTING. THE BLASTED SURFACES SHALL BE CLEANED ACCORDANCE WITH EN ISO 8501-1 OR SSPC -VIS1</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RESPECTIVELY TO GRADE SA 2 ½ OR SP10.THE CONTRACTOR SHALL PROTECT ALL ADJACENT EQUIPMENT#S AND PLANTS DURINGTHE BLASTING OPERATION. OPEN BLASTING IS NOT ALLOWED. EXTREME CARE SHALLBE TAKEN TO ENSURE THAT NO ABRASIVE PARTICLE OR FLUID AS PASSING TO THEAIR INTAKE PASSAGE OF GAS TURBINE. FOLLOWING THE SURFACE CLEANING THEPAINTING THE COMPLETE EXTERIOR SHALL BE PAINTED FOR TOTAL A DRY FILMTHICKNESS OF 320#M WHICH INCLUDES INORGANIC ZINC PRIMER COAT FOLLOWED BY2 LAYERS OF EPOXY POLYAMIDE AND ONE COAT OF TOUCH UP. THE DETAILED SPECIFICATION ON SURFACE CLEANING & PAINTING IS THE PAINTING SHALL BEPERFORMED BY PROFESSIONAL PA INTING CONTRACTORS AND THE CONTRACTOR SHALLPREPARE HIS OWN PAINTING SPECIFICATION AND SUBMIT FOR DEWA APPROVALPRIOR TO THE APPLICATI</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ON. THE COLOR SCHEME SHALL BE LIKE EXISTINGSTRUCTURAL AND DUCT PAINTING. ONLY PAINTING REPAIR WORKS ARE ENVISAGEDFOR THE INTERIOR SU RFACES OF FILTER HOUSE AND DUCT.CONTRACTOR SHALL PROVIDE A SEPARATE RECTIFICATION PROCEDURE FOR THEINTERIOR SURFACES.3. DOCUMENTS REQUIRED BEFORE STARTING THE WORK PRIOR TO COMMENCEMENT OFWORK, SUCCESSFUL BIDDER SHALL SUBMIT THE MINIMUM FOLLOWING DOCUMENTSINDIVIDU ALLY FOR EACH GAS TURBINE AND GET IT APPROVED BY DEWA: I.COMPLETION OF THE CONTRACTUAL FORMALITIES II. INTEGRITY ASSESSMENTPROCEDURE . III. INTEGRITY ASSESSMENT DOCUMENT WITH REPAIR PROCEDURES.IV. REPAIR/ REPLACEMENT PROCEDURE. V. MATERIAL QUALITY CERTIFICATES. VI. TEMPORARY SUPPORT ARRANGEMENT WITH SUPPORTING CALCULATIONS. VII. SURFACECLEANING AND PAINTING SPECIFICATION</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>VIII. WORK PLAN IX. METH OD OF STATEMENTS X. RISK ASSESSMENT XI. DRAWING/DOCUMENTS AS NECESSARY TO WORK EXECUTION XII. SITE QUALITY INSPECTION PROTOCOLS. 4. OBL IGATIONS OF THE CONTRACTOR # THE CONTRACTOR IS EXPECTED TO SUBMIT A MASTER PROGRAM COVERING THE FULL SCOPE THIS POPRIOR TO COMMENCEME NT OF HIS WORK CLEARLY INDICATING THE PROPOSED #START# AND #FINISH# DATES OF EACH ACTIVITY IN BAR CHART. # DUE TO PLANT OPERATIONAL NE EDS, IT IS LIKELY THAT DEWA RESERVE THE RIGHT TO CHANGE THE SHUTDOWN SCHEDULE WITH A VERY SHORT NOTICE, IN THAT CASE THE CONTRACTOR IS REQUIRED TO REVISE HIS INSPECTION PROGRAM IN CONSULTATION WITH DEWA ENGINEER CONCERNED. HOWEVER, THE CONTRACTOR IS NOT ENTITLED TO PA YMENT OF ANY COMPENSATION WHATSOEVER FROM DEWA BECAUSE OF SUCH WAITING TIME OR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DELAY. # CONTRACTORSHALL TRY HIS BEST TO DELIVER THE Q UALITY JOB IN ACCORDANCE WITH A WORLD-CLASS LEVEL OF EXCELLENCE AND ACCORDING TO THE SCHEDULE SET FORTH BY DEWA. # CONTRACTOR SHALL TAKE NECESSARY PRECAUTION TO AVOID ANY DAMAGE OF THE PLANT EQUIPMENT#S WHILE CARRYING OUT THE WORK. #CONTRACTOR SHALL COMPLETE ALL ACTIVITIES WITHIN SCHEDULE, SO THAT OUTAGE EXTENSION IN ANY CASE SHALL BE AVOIDED. 5. DURATION OF WORK # THE WORK SHALL BE EXECUTED IN THE YEAR 2024-25 AS PER OUR DEWA OUTAGE SCHEDULE. THE INTEGRITY ASSESSMENT MAY BE PERMITTED PRIOR TO THE ACTUAL OUTAGE OF THE UNITS. TOTAL DURATION OF THE WORKS THAT REQUIRE OUTAGE OF THE GAS TURBINE SHALL NOT EXCEED 4 WEEKS. # THE CONTRACTOR WILL BE PROVIDED THE TENTATIVE OUTAGE SCHEDULE OF THE UNITS AT THE TIME						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OF AWARD OF CONTRACT.6. REPORTS AND DOCUMENTS TO BE SUBMITTED BY THE BIDDER: BIDDER SHALL SUBMIT FOLLOWING DOCUMENTS ALONG WITH THEIR BID PROPOSAL #ORGANIZATIONAL CHART FOR THE PROJECT EXECUTION SHOWING DIVISION OF RESPONSIBILITY, LIST OF NAMES, TITLES, DUTIES, AND JOB DESCRIPTIONS FOR KEY PERSONNEL. THE JOB DESCRIPTION SHALL STATE THE EXPERIENCE, LICENSES, AND CERTIFICATIONS FOR EACH POSITION. # DETAILS OF						
4		ITEM-00001	1. THE SCOPE OF WORKSCOPE WORKS FOR THE AIR INTAKE DUCT ARE LIMITED TO DUCTS OUTSIDE THE GTHALL FOR ONE GAS TURBINES UNIT OF D-REPO WORKING.ON SUCCESSFUL COMPLETION REPEAT ORDER MAY BE CONSIDERED UNDER DEWA DISCRETION.2.1 INSPECTION AND CONDITION ASSESSMENT; THE CONTRACTOR IS EXPECTED TO CARRY OUT THE A DETAILED INSPECTION OF THE AIR INTAKE FILTER	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			HOUSING,CONNECTING DUCTS AND ITS SUPPORTING STRUC TURE OUTSIDE THE D REP GT HALLTO STUDY THE IMPACT OF CORROSION AND TO IDENTIFY THE SERIOUSLY CORRODEDSTRUCTURAL MEMBERS AND ITS JOIN TS. THE ASSESSMENT SHALL BE DONE BY AQUALIFIED AND EXPERIENCED STRUCTURAL ENGINEER BASED ON RELEVANTINTERNATIONAL STANDARDS.THE DATA REQUIRED FOR ASSESSMENT SHALL BE OBTAINED BY THE CONTRACTOR BYPHYSICAL INSPECTION OF THE SITES AND NON-DESTRUCTIVE EXAMINATIONS (N DE)LIKE, ULTRASONIC SCANNING, DYE PENETRATION TESTS, MAGNETIC PARTICLE TESTETC. DESIGN INFORMATION COULD BE PROVIDED BY DEWA AS FAR AS AVAILABLE.CONTRACTOR IS EXPECTED TO MAKE HIS ENGINEERING JUDGEMENT TO UNDERSTANDTHE MISSING DESIGN INFORMATION#S IF ANY. BASED ON THE INSPECTION AND NDERESULTS CONTRACTOR						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SHALL ASSESS THE STRUCTURAL INTEGRITY AND RECOMMEND CORRECTIVE MEASURES REQUIRED TO ENSURE RELIABLE LIFE UNTIL THE SCHEDULED DE-COMMISSIONING OF THE PLANT. THE NUMBER OF SAMPLING POINTS FOR NDT FOR THE ASSESSMENT OF THE STRUCTURE INTEGRITY SHALL BE BASED ON RELEVANT INTERNATIONAL STANDARDS AND SHALL BE APPROVED BY DEWA. 2.2 REPAIR WORKS BASED ON THE INTEGRITY ASSESSMENT CONTRACTOR SHALL CARRY OUT ALL RECOMMENDED REPAIR WORKS TO RESTORE THE INTEGRITY OF THE FILTER HOUSE ASSEMBLY, DUCT AND SUPPORTING STRUCTURES. THE NATURE OF THE REPAIR SHALL BE TO REPLACE ALL SERIOUSLY CORRODED STRUCTURAL & DUCT PARTS MEMBERS THAT AFFECT THE INTEGRITY OF THE AIR INTAKE SYSTEM. WHEREVER DEFECTS ARE MINOR MUTUALLY AGREED REPAIR SOLUTION CAN BE ADOPTED. THE REPAIR/REPLACEMENT SHALL						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ALL BE APPLICABLE TO BELOW MEMBERS OF THE FILTERHOUSING , STRUCTURE AND DUCTS BUT NOT LIMITED TO ; # STEEL STRUCTURALMEMBERS LIKE BE AMS, COLUMNS, BRACING. TIE-RODS ETC. THAT WEAKENSSTRUCTURAL INTEGRITY WITH EQUIVALENT OR SUPERIOR STEEL STRUCTURALMEMBERS. ALL STEEL STRUCTURAL MEMBERS SEVERELY PITTED WITH CRACKS ANDCORROSION HOLES SHALL BE REPLACED IRRESPECTIVE OF INTEGRITY ASSESSMENTFINDING. # ALL CORRODED GUSSET PLATES, JOINTS, NUTS AND BOLTS # ALLCORRODED HANDRAILS # ALL CORRODED GRATINGS. ALL GRATING TO BE TACKWELDED TO SUPPORT BEAMS AT A FEW PLACES IN ADDITION TO GRATING CLIPS. #WHEREVER REPLACEMENT IS PRACTICALLY NOT POSSIBLE, NATURE OF THE REPAIRS HALL BE MUTUALLY AGREED AND DISCUSSED. # REPAIR OF THE DUCTS AND FILTERHOUSE WALLS SHALL BE DONE BY REPLACING AFFECTED PART						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BY PATCH WORKS WITHSIMILAR MATERIAL OF SIMILAR THICKNESS OR HIGHER AS MUTUALLY AGREED. #WHILE REPLACING THE CRITICAL STRUCTURAL MEMBERS IT I S NECESSARY TOPROVIDE SUITABLE TEMPORARY SUPPORTS TO ENSURE SAFETY OF REMAININGSTRUCTURES. SUCH TEMPORARY SUPPORTS SHALL BE SUITABLY DESIGNED TO TAKEALL APPLICABLE STATIC AND DYNAMIC LOADS. TEMPORARY SUPPORT DRAWINGSSHALL BE SUBMITTED FOR PRIOR APPROVAL OF DEWA. # ALL STEEL STRUCTURESUSED FOR THE REPLACEMENT SHALL HOT DIP GALVANIZED CARBON STEELEQUIVALENT TO EXISTING MATERIAL OR SUPERIOR. DEWA PRIOR APPROVAL ISNECESSARY FOR ALL REPLACEMENT MATERIALS# ALL SCAFFOLDING REQUIRED FOR THE WORKS ARE IN THE CONTRACTOR SCOPE. #ALL FIELD QUALITY TESTS REQUIRED TO CONFIRM THE COMPLIANCE OF THE WORKSARE INCLUDED IN						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE CONTRACTOR SCOPE. #BIDDERS MAY PLEASE NOTE TH AT THEQUANTITY OF REPLACEMENT WORKS TO BE FINALIZED BASED ON INSPECTIONFINDING AND RECOMMENDATIONS APPROVED BY DEWA. AS SUCH BIDDER NEEDS TOQUOTE FOR THE REPAIR WORKS UNDER THIS CLAUSE WITH AN ESTIMATED QUANTITYAND UNIT RATES IN KILOGRAM BASIS FOR THE DESIGN, FABR ICATION, HOT DIPGALVANIZING, SUPPLY AND INSTALLATION SCOPE OF WORKS.THE PAYMENT FOR THE REPAIR WORKS WILL BE BASED ON THE ACTUAL REP LACEMENTWORKS PERFORMED AS CERTIFIED BY DEWA.2.3 SURFACE CLEANING AND PAINTING THE SURFACE CLEANING AND PAINTINGSHALL BE TO WITHSTAN D THE CORROSION CATEGORY ACCORDING TO ISO 12944-2:C5-M: COASTAL AREA WITH HIGH SALINITY. ACCORDING TO ISO12944-5 THEEXPECTED DURABIL ITY OF THE PAINTING IS: HIGH (H): >15 YEARS.						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ADJACENT PLANTS AND EQUIPMENT SHALL BE PROTECTED DURING PAINTING WORKS WITH APPROPRIATE COVERS LIKE TARPULIN. THE EXTERIOR SURFACES OF THE FILTERHOUSE, DUCTS AND SUPPORTING STRUCTURE SHALL BE THOROUGHLY BLAST CLEANED TO REMOVE ALL OLD PAINTING AND CORROSION AND TO EXPOSE THE BASE METAL PRIOR TO THE PAINTING. THE BLASTED SURFACES SHALL BE CLEANED ACCORDANCE WITH EN ISO 8501-1 OR SSPC -VIS1 RESPECTIVELY TO GRADE SA 2 ½ OR SP10. THE CONTRACTOR SHALL PROTECT ALL ADJACENT EQUIPMENT#S AND PLANTS DURING THE BLASTING OPERATION. OPEN BLASTING IS NOT ALLOWED. EXTREME CARE SHALL BE TAKEN TO ENSURE THAT NO ABRASIVE PARTICLE OR FLUID AS PASSING TO THE AIR INTAKE PASSAGE OF GAS TURBINE. FOLLOWING THE SURFACE CLEANING THE PAINTING THE COMPLETE EXTERIOR SHALL BE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PAINTED FOR TOTAL A DRY FILMTHICKNESS OF 320#M WHICH INCLUDES INORGANIC ZINC PRIMER COAT FOLLOWED BY2 LAYERS OF EPOXY POLYAMIDE AND ONE COAT OF TOUCH UP. THE DETAILED SPECIFICATION ON SURFACE CLEANING & PAINTING IS THE PAINTING SHALL BE PERFORMED BY PROFESSIONAL PAINTING CONTRACTORS AND THE CONTRACTOR SHALL PREPARE HIS OWN PAINTING SPECIFICATION AND SUBMIT FOR DEWA APPROVAL PRIOR TO THE APPLICATION. THE COLOR SCHEME SHALL BE LIKE EXISTING STRUCTURAL AND DUCT PAINTING. ONLY PAINTING REPAIR WORKS ARE ENVISAGED FOR THE INTERIOR SURFACES OF FILTER HOUSE AND DUCT. CONTRACTOR SHALL PROVIDE A SEPARATE RECTIFICATION PROCEDURE FOR THE INTERIOR SURFACES. 3. DOCUMENTS REQUIRED BEFORE STARTING THE WORK PRIOR TO COMMENCEMENT OF WORK, SUCCESSFUL BIDDER SHALL SUBMIT THE MINIMUM FOLLOWING</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DOCUMENTS INDIVIDUALLY FOR EACH GAS TURBINE AND GET IT APPROVED BY DEWA: I. COMPLETION OF THE CONTRACTUAL FORMALITIES II. INTEGRITY ASSESSMENT PROCEDURE . III. INTEGRITY ASSESSMENT DOCUMENT WITH REPAIR PROCEDURES. IV. REPAIR/ REPLACEMENT PROCEDURE. V. MATERIAL QUALITY CERTIFICATES. VI. TEMPORARY SUPPORT ARRANGEMENT WITH SUPPORTING CALCULATIONS. VII. SURFACE CLEANING AND PAINTING SPECIFICATION VIII. WORK PLAN IX. METHOD OF STATEMENTS X. RISK ASSESSMENT XI. DRAWING/DOCUMENTS AS NECESSARY TO WORK EXECUTION XII. SITE QUALITY INSPECTION PROTOCOLS. 4. OBLIGATIONS OF THE CONTRACTOR # THE CONTRACTOR IS EXPECTED TO SUBMIT A MASTER PROGRAM COVERING THE FULL SCOPE THIS PRIOR TO COMMENCEMENT OF HIS WORK CLEARLY INDICATING THE PROPOSED #START# AND #FINISH# DATES						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OF EACH ACTIVITY IN BAR CHART. # DUE TO PLANT OPERATIONAL NEEDS, IT IS LIKELY THAT DEWA RESERVE THE RIGHT TO CHANGE THE SHUTDOWN SCHEDULE WITH A VERY SHORT NOTICE, IN THAT CASE THE CONTRACTOR IS REQUIRED TO REVISE HIS INSPECTION PROGRAM IN CONSULTATION WITH DEWA ENGINEER CONCERNED. HOWEVER, THE CONTRACTOR IS NOT ENTITLED TO PAYMENT OF ANY COMPENSATION WHATSOEVER FROM DEWA BECAUSE OF SUCH WAITING TIME OR DELAY. # CONTRACTOR SHALL TRY HIS BEST TO DELIVER THE QUALITY JOB IN ACCORDANCE WITH A WORLD-CLASS LEVEL OF EXCELLENCE AND ACCORDING TO THE SCHEDULE SET FORTH BY DEWA. # CONTRACTOR SHALL TAKE NECESSARY PRECAUTION TO AVOID ANY DAMAGE OF THE PLANT EQUIPMENT#S WHILE CARRYING OUT THE WORK. # CONTRACTOR SHALL COMPLETE ALL ACTIVITIES WITHIN SCHEDULE, SO THAT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OUTAGEEXTENSION IN ANY CASE SHALL BE AVOIDED.5. DURATION OF WORK # THE WORK SHALL BE EXECUTED IN THE YEAR 2024-25 ASPER OUR DEWA OUTAGE SCHEDULE. THE INTEGRITY ASSESSMENT MAY BE PERMITTEDPRIOR TO THE ACTUAL OUTAGE OF THE UNITS. TOTA</p> <p>L DURATION OF THE WORKSTHAT REQUIRE OUTAGE OF THE GAS TURBINE SHALL NOT EXCEED 4 WEEKS. # THECONTRACTOR WILL BE PROVIDED THE TENTATI</p> <p>VE OUTAGE SCHEDULE OF THE UNITSAT THE TIME OF AWARD OF CONTRACT.6. REPORTS AND DOCUMENTS TO BE SUBMITTED BY THE BIDDER: BIDDER SHALL</p> <p>SUBMIT FOLLOWING DOCUMENTS ALONG WITH THEIR BID PROPOSAL #ORGANIZATIONAL CHART FOR THE PROJECT EXECUTION SHOWING DIVISION OFRESPONSI</p> <p>BILITY, LIST OF NAMES, TITLES, DUTIES, AND JOB DESCRIPTIONS FORKEY PERSONNEL. THE JOB DESCRIPTION SHALL STATE THE EXPERIENCE, LICENS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ES,AND CERTIFICATIONS FOR EACH POSITION. # DETAILS OF						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

D-Rep Air intake filter house renovation works. .please contact Mr. Eisa 0502706066 or Mr.Laikot 0558085126 for any clarification

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400854
DATE : 29.03.2024
REQ No : 1032401280
REQ TITLE : 1-1032401280 D-Rep Air intake
DELIVERY LOCATION
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP