

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2492400186
DATE : 27.03.2024
REQ No : 1172400128
REQ TITLE : Delta test kit 1172400128
DELIVERY LOCATION : 0051 - CENTR STROE(TRN)
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1	7000000013		PORTABLE AUTOMATIC CAPACITANCE AND DISSIPATION FACTOR TEST SET FOR TESTING LARGE CAPACITY POWER TRANSFORMERS/REACTORS AND HIGH VOLTAGE CONDENSER BUSHINGS, COMPLETE WITH HV SOURCE, CONTROL AND MEASUREMENT UNIT, MEASURING LEADS AND OTHER REQUIRED ACCESSORIES HAVING FOLLOWING FEATURES. 2.0 TECHNICAL SPECIFICATIONS: 1 WORKING VOLTAGE 230 +/- 10 % VOLTS, 50 HZ, 1 PHASE 2 TEST VOLTAGE UP TO 10 KV, SELECTABLE 3 TEST FREQUENCY 50 HZ 4 CAPACITANCE RANGE 0 TO 100 #F, 0.01 PF RESOLUTION 5 DISSIPATION FACTOR 0 - 100, 0.001% 6 WATT LOSS 0-1 KW 7 ACCURACY CAPACITANCE: +/- (0.5% OF READING) +1 PF, DISSIPATION FACTOR: +/- (0.5% OF READING) +0.02%, WATT LOSS: +/- (1% OF READING) + 1 MW 8 TEST MODES GROUNDING SPECIMEN TESTING (GST), UNGROUNDING SPECIMEN TESTING (UST) AND GUARD MODES. 9 MEASUREMENT METHODS FULLY	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2492400186
DATE : 27.03.2024
REQ No : 1172400128
REQ TITLE : Delta test kit 1172400128
DELIVERY LOCATION : 0051 - CENTR STROE(TRN)
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AUTOMATIC (APPLICA TION OF TEST VOLTAGE, BALANCING,INTERFERENCE COMPENSATION, MEASUREMENT ON BOTH POLARITIES)10 CONTROL CONTROLS USING SEPARATE COMPUTE R11 TEST LEADS HV LEAD AND MEASUREMENT LEADS SHALL BE 20 M LONG (MIN)12 SAFETYSAFETY INTERLOCKS SWITCHES / STROBE LIGHTS AND BUZZER TO BEPROVIDED13 ENVIRONMENTOPERATING ENVIRONMENT - 0 TO 60 °C, 90% RHSTORAGE TEMPERATURE - 0 TO 70 °C14TRANSPORTATIONCASEINSTRUMENT SHALL BE SUPPLIED IN A RUGGED TRANSPORT CASE TOPROTECT IT FROM DAMAGES WHILE TRANSPORTING TO FIELD, CABLES &ACCESSORIES SHALL BE SUP PLIED IN SEPARATE SOFT CARRY-CASES15 CALIBRATIONCALIBRATION CERTIFICATE VALID FOR A PERIOD OF 12 MONTHS FROMTHE DATE OF DELIVERY16 W ARRANTY 3 YEARS (2 YEARS + 1 YEAR EXTENDED WARRANTY)17 OTHER FEATURES(A) COMPACT AND						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2492400186
DATE : 27.03.2024
REQ No : 1172400128
REQ TITLE : Delta test kit 1172400128
DELIVERY LOCATION : 0051 - CENTR STROE(TRN)
CLOSING DATE : 04.04.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RUGGED DESIGN FOR USE IN HARSH ENVIRONMENT IN FIELD TESTING) PROVIDED WITH INTERFERENCE SUPPRESSORS FOR USING AT HV SUBSTATIONS</p> <p>18 ACCESSORIES) LAPTOP COMPATIBLE WITH WINDOWS 10 PRO</p> <p>OS TO CONTROL AND MONITOR THE TEST INSTRUMENT ALONG WITH LAPTOP BAG</p> <p>SOFTWARE TO ENABLE THE CONTROL & MONITORING OF TEST PROCESS, SAVING & ANALYSIS OF TEST DATA</p> <p>3.0 OTHER REQUIREMENTS (MANDATORY):</p> <p>1. REFERENCE CAPACITOR FOR IN-HOUSE TESTING.</p> <p>2. ON-SITE DEMONSTRATION</p> <p>4.0 PREFERRED BRANDS</p> <p>1. DOBLE, USA</p> <p>2. OMICRON, USA</p> <p>3. HAEFELY AG</p> <p>4. PHOENIX, USA</p> <p>5.0 PREFERRED COUNTRY OF ORIGIN: EUROPE, USA, JAPAN</p>						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Delta test kit

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2492400186
DATE	: 27.03.2024
REQ No	: 1172400128
REQ TITLE	: Delta test kit 1172400128
DELIVERY LOCATION	: 0051 - CENTR STROE(TRN)
CLOSING DATE	: 04.04.2024
CLOSING TIME	: 10:00:00

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP