

REQUEST FOR QUOTATION  
LOCAL PURCHASE SECTION

RFQ NUMBER : 2012302764  
DATE : 13.06.2023  
REQ No : 1012302679  
REQ TITLE : G station Phase # 1 Desalinat  
DELIVERY LOCATION : 0014 - G STORE SPAR&CHE  
CLOSING DATE : 19.06.2023  
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1	3700032213		VALVE BALL, OLTC SYSTEM, DN100, ACTUATOR OPERATED, F TO F DISTANCE: 305 MM, PCD: 180 MM, NO OF HOLES:8, HOLE DIA: 18 MM, TYPE: FULL PORT, MODEL: 84F2, DESIGN TEMPERATURE (MIN/MAX): 19#C / 150#C, DESIGN PRESSURE: 8.5 BAR, MAX WORKING TEMPERATURE: 110#C, MAX WORKING PRESSURE: 7.5 BAR, HYDRO TESTE PRESSURE: SHELL: 31 BAR, SEAT: 19.5 BAR, AIR TEST PRESSURE: SEAT: 7 BAR, MATERIAL OF CONSTRUCTION, B ODY, BALL, GLAND: BS 1400 AB2, STEM: SS 316L, SEAT / SEAL : PTFE, MAKE: GEA BGR ENERGY SYSTEM INDIA LTD OR EQUIVALENT	10	EA				

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

**SPECIAL NOTES / INSTRUCTIONS:**

G station Phase 1 Desalination Plant OLTC system DN100 valves. Contact  
Person: Mohammad Rafi Hosur/ mohammad.hosur@dewa.gov.ae / 04-804-4964

**STANDARD TERMS & CONDITIONS**

1) Prices should be 'DDP' delivery duty paid at DEWA stores.

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

**REQUEST FOR QUOTATION  
LOCAL PURCHASE SECTION**

**RFQ NUMBER** : 2012302764  
**DATE** : 13.06.2023  
**REQ No** : 1012302679  
**REQ TITLE** : G station Phase # 1 Desalinat  
**DELIVERY LOCATION** : 0014 - G STORE SPAR&CHE  
**CLOSING DATE** : 19.06.2023  
**CLOSING TIME** : 10:00:00

- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**