

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012403074
DATE : 15.07.2024
REQ No : 1012403127
REQ TITLE : Fire Alarm System material
DELIVERY LOCATION : 0009 - WF AWEER STORE
CLOSING DATE : 24.07.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1	2700087791		ALARM_TYPE: PHOTAIN SOUNDER ADDRESSABLE; ELECTRICAL RATING: 19.5 TO20.5VDC (LOOP); DECIBEL: 90DB; COLOR: RED; MATERIAL: MOLDED THERM OPLASTIC; SIZE: 120MM DIA, 150MM DP; MPN: ZP755WV-2R; ADDITIONAL INFO:ENCLOSURE: WEATHERPROOF; MOUNT: SURFACE; OPERATING TEMPERATU R E RATING:-25 TO 70DEG C; REGION: UK; W/PLUG-IN BASE	3	EA				
2	2700087805		CALL POINT_RATING: 24VDC 0.8MA; SIZE: 100MM WD, 97MM DP, 45.5MM HT;TYPE: BREAK GLASS, MANUAL; COLOR: RED; MATERIAL: ABS; MFR: SHIELDÂ#FIRESAFETY & SECURITY LTD: MPN: BG-A450: ADDITIONAL INFO: ALARM CURRENTRATING: 2MA; REGION: UNITED KINGDOM	5	EA				
3	2700087806		ALARM_TYPE: ENVIRONMENT, STROBE/SOUNDER; ELECTRICAL RATING: 16 TO 28VAC,24VDC 3MA; DECIBEL: 85DB; MATERIAL: ABS; MFR: SHIELDÂ#FIRE S AFETY &SECURITY LTD: MPN: S-490/L: ADDITIONAL INFO: ENCLOSURE: IP33; REGION:UK; STD: EN 54-3	5	EA				
4	2700087804		DETECTOR_FIRE PROTECTION; TYPE:	5	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012403074
DATE : 15.07.2024
REQ No : 1012403127
REQ TITLE : Fire Alarm System material
DELIVERY LOCATION : 0009 - WF AWEER STORE
CLOSING DATE : 24.07.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ELECTRONICALLY ADDRESSABLE, FIXEDTEMPERATURE, HEAT, RATE OF RISE; TEMPERATURE RATING: -10 TO 50DEG C ;VOLTAGE: 24VDC LOOP; AMPERAGE: 0.8MA (STANDBY), 5MA (ALARM); MFR: SHIELDFIRE SAFETY & SECURITY LTD: MPN: D-A412: ADDITIONAL INFO : RELATIVEHUMIDITY: 95%; REGION: UK; 8 BIT INTELLIGENT PROCESSOR W/A/D CONVERTER						
5	2700087803		DETECTOR_FIRE PROTECTION; TYPE: ELECTRONICALLY ADDRESSABLE, SMOKE,INTELLIGENT PHOTOELECTRIC; TEMPERATURE RATING: -10 TO 50DEG C; VO LTAGE:24VDC LOOP; AMPERAGE: 0.8MA (STANDBY), 5MA (ALARM); MFR: SHIELD FIRESAFETY & SECURITY LTD: MPN: D-A411: ADDITIONAL INFO: ELE C TRONICALLYPROGRAMMING; RELATIVE HUMIDITY: 95%; RI: 5MA; W/BASE; REGION: UK	5	EA				

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012403074
DATE : 15.07.2024
REQ No : 1012403127
REQ TITLE : Fire Alarm System material
DELIVERY LOCATION : 0009 - WF AWEER STORE
CLOSING DATE : 24.07.2024
CLOSING TIME : 10:00:00

Fire Alarm System material

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP