

**REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION**

RFQ NUMBER : 2012600067
DATE : 05.01.2026
REQ No : 1012507075
REQ TITLE : MCB 1012507075
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 09.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1	2700086796		CIRCUIT BREAKER_MINIATURE; VOLTAGE: 400VAC; AMPERAGE: 4A; INTERRUPTINGCAPACITY: 10KA; POLE: 2P; CONNECTION: SCREW TERMINAL; FREQUEN CY RATING:50/60HZ; ENCLOSURE: IP20/40; MOUNT: SNAP-ON; CURVE: C; SIZE: 36MM WD,70MM DP, 90MM HT; MFR: SIEMENS LTD: MPN: 5SY4204-7; APPLICATION: ICT;SIEMENS	2	EA				
2	2700089837		CIRCUIT BREAKER_MINIATURE; VOLTAGE: 400VAC, 440VDC; AMPERAGE: 13A;INTERRUPTING CAPACITY: 10KA; POLE: 2P; CONNECTION: SCREW TERMINAL ;FREQUENCY RATING: 50/60HZ; ENCLOSURE: IP20/40; MOUNT: SNAP-ON; CURVE: C;SIZE: 36MM WD, 70MM DP, 90MM HT; MFR: SIEMENS LTD: MPN: 5 S Y5213-7;ADDITIONAL INFO: REGION: AUSTRIA; APPLICATION: SOCKET SUPPLY; SERIESREACTOR; 400KV 1500MVA; SIEMENS	2	EA				
3	2700089838		CIRCUIT BREAKER_MINIATURE; VOLTAGE: 400VAC, 440VDC; AMPERAGE: 10A;INTERRUPTING CAPACITY: 10KA; POLE: 2P; CONNECTION: SCREW TERMINAL	2	EA				

**REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION**

RFQ NUMBER : 2012600067
DATE : 05.01.2026
REQ No : 1012507075
REQ TITLE : MCB 1012507075
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 09.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			:FREQUENCY RATING: 50/60HZ; ENCLOSURE: IP20/40; MOUNT: SNAP-ON; CURVE: C;SIZE: 36MM WD, 70MM DP, 90MM HT; MFR: SIEMENS LTD: MPN: 5 S Y5210-7:ADDITIONAL INFO: REGION: AUSTRIA; APPLICATION: LUMA SMART SUPPLY SERIESREACTOR; 400KV 1500MVA; SIEMENS						
4	2700089853		CIRCUIT BREAKER_MOLDED CASE; VOLTAGE: 690VAC; AMPERAGE: 100 TO 250A; CONNECTION: SCREW TERMINAL; INTERRUPTING CAPACITY: 55KA; POLE: 3 P; FRAMESIZE: 250A; FREQUENCY RATING: 50/60HZ; PHASE: 3PH; TRIP: THERMALMAGNETIC; MOUNT: FIXED; STANDARD: IEC 60947-1, IEC 60947- 2; MFR:SIEMENS LTD: MPN: 3VL3725-1SS33-0AB1: ADDITIONAL INFO: REGION: AUSTRIA;APPLICATION: NORMAL/EMERGENCY SUPPLY REACTOR; 400KV 1500 MVA; SIEMENS	1	EA				
5	2700089854		CIRCUIT BREAKER_MOLDED CASE; VOLTAGE: 380/415VAC; AMPERAGE: 63 TO 160A; CONNECTION: SCREW TERMINAL; INTERRUPTING CAPACITY: 40KA; POL	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012600067
DATE : 05.01.2026
REQ No : 1012507075
REQ TITLE : MCB 1012507075
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 09.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			E: 3P; FRAME SIZE: 160A; FREQUENCY RATING: 50/60HZ; PHASE: 3PH; TRIP: THERMALMAGNETIC; MOUNT: FIXED; STANDARD: IEC 60947-1, IEC 60947-2-2; MFR: SIEMENS LTD; MPN: 3VL2716-1SS33; ADDITIONAL INFO: REGION: AUSTRIA; APPLICATION: FAN CONTROL; SERIES REACTOR; 400KV 1500MV A; SIEMENS						
6	2700091599		CIRCUIT BREAKER_MINIATURE; VOLTAGE: 230/400VAC; AMPERAGE: 20A; INTERRUPTING CAPACITY: 6KA; POLE: 3P; CONNECTION: SCREW TERMINAL; FREQUENCY RATING: 50/60HZ; ENCLOSURE: IP00/40; MOUNT: 35MM DIN RAIL; CURVE:C; SIZE: 54MM WD, 62MM DP, 90MM HT; MFR: SIEMENS LTD; MPN: 5SX2320-7; ADDITIONAL INFO: W/1NO 1NC AUX CONTACT SWITCH P/N 5SX9100; G1; APPLICATION: ICT MARSHALLING KIOSK; 400KV; HYUNDAI; BRUSHLESS SUBSTATION	2	EA				
7	2700091603		CIRCUIT BREAKER_MINIATURE; VOLTAGE: 230/400VAC; AMPERAGE: 30A; INTERRUPTING CAPACITY: 6KA; POLE: 2P; CONNECTION: SCREW TERMINAL; FREQUENCY RATING: 50/60HZ; ENCLOSURE: IP00/40; MOUNT: 35MM DIN RAIL; CURVE:C; SIZE: 54MM WD, 62MM DP, 90MM HT; MFR: SIEMENS LTD; MPN: 5SX2320-7; ADDITIONAL INFO: W/1NO 1NC AUX CONTACT SWITCH P/N 5SX9100; G1; APPLICATION: ICT MARSHALLING KIOSK; 400KV; HYUNDAI; BRUSHLESS SUBSTATION	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012600067
DATE : 05.01.2026
REQ No : 1012507075
REQ TITLE : MCB 1012507075
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 09.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			UENCY RATING: 50/60HZ; ENCLOSURE: IP00/40; MOUNT: 35MM DIN RAIL; CURVE:C; SIZE: 36MM WD, 62MM DP, 90MM HT; MFR: SIEMENS LTD: MPN: 5SX230-7:ADDITIONAL INFO: W/5SX9100 1NO 1NC AUX CONTACT SWITCH; C1; APPLICATION:ICT MARSHALLING KIOSK PANELS; 400KV; HYUNDAI; BR SH SUBSTATION						
8	2700094212		CIRCUIT BREAKER_MINIATURE; TYPE: AUTO; VOLTAGE: 400VAC; AMPERAGE: 10A; INTERRUPTING CAPACITY: 6KA; POLE: 2P; CONNECTION: SCREW TERMINAL; FREQUENCY RATING: 50/60HZ; ENCLOSURE: IP20/40; MOUNT: SNAP-ON; CURVE: C; SIZE: 36MM WD, 70MM DP, 90MM HT; MFR: SIEMENS LTD: MPN : 5SY6210-7:ADDITIONAL INFO: REGION: GERMANY; APPLICATION: ICT; SIEMENS	2	EA				
9	2700100934		CIRCUIT BREAKER_MINIATURE; VOLTAGE: 230VAC; AMPERAGE: 10A; INTERRUPTINGCAPACITY: 10KA; POLE: 1P+N; CONNECTION: SCREW TERMINAL; FREQUENCY RATING: 50/60HZ; ENCLOSURE: IP20/40; MOUNT: SNAP-ON; CURVE: C; SIZE:36MM WD, 70MM	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012600067
DATE : 05.01.2026
REQ No : 1012507075
REQ TITLE : MCB 1012507075
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 09.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DP, 90MM HT; MFR: SIEMENS LTD: MPN: 5SY4510 - 7: ADDITIONALINFO: REGION: GERMANY; APPLICATION: IDT; SIEMENS DRESDEN; ABRASUBSTATION; DEVICE NO: F5						
10	2700107446		CIRCUIT BREAKER, MAKE: SIEMENS, TYPE: 5SY4210-6 (F16-MK), 10KA, 10A,400/230V AC SINGLE POLE WITH AUXILIARY CONTACTS, , 50HZ, FOR KONCAR POWER TRANSFORMER, CROATIA AT MBRSLAR 400 KV SUBSTATION	2	EA				
11	2700107447		CIRCUIT BREAKER, MAKE: SIEMENS, TYPE: 5SY4302 (F14-PC), THREE POLE WITHAUXILIARY CONTACTS. 2 AMPS, 400V AC, 50HZ, FOR KONCAR POWER TRANSFORMER,CROATIA AT MBRSLAR 400 KV SUBSTATION	3	EA				
12	2700107448		CIRCUIT BREAKER, MAKE: SIEMENS, TYPE: 5SY4206 (F16-PC), 6A, 10KA, 2POLE, FOR KONCAR POWER TRANSFORMER, CROATIA AT MBRSLAR 400 KV SUBSTATION	2	EA				
13	2700107449		CIRCUIT BREAKER, MAKE: SIEMENS, TYPE: 5SY4316 (F17-PC), 3 POLE, 16A FOR KONCAR POWER TRANSFORMER, CROATIA AT MBRSLAR 400 KV SUBSTAT	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012600067
DATE : 05.01.2026
REQ No : 1012507075
REQ TITLE : MCB 1012507075
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 09.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ION						
14	2700107450		CIRCUIT BREAKER, MAKE: SIEMENS, TYPE: 5SY4325 (F18-PC), 3 POLE 25A, FOR KONCAR POWER TRANSFORMER, CROATIA AT MBRSLAR 400 KV SUBSTAT ION	2	EA				
15	2700107451		CIRCUIT BREAKER, MAKE: SIEMENS, TYPE: 5SY4232 (F19-PC), 2 POLE, 32A, 10KA, FOR KONCAR POWER TRANSFORMER, CROATIA AT MBRSLAR 400 KV SUBSTATION	2	EA				
16	2700121034		MCB; MAKE: SIEMENS; MODEL: 5SY5216-7, WITH AUXILIARY CURRENT SWITCH 5ST3010, 1NO + 1NC; 440V AC; 10KA, 2 POLE, C, 16A, T=70MM; FOR KONCAR MAKE ICTS AT DXBJAUB SUBSTATION	2	EA				
17	2700105705		CIRCUIT BREAKER_MINIATURE; VOLTAGE: 400VAC; AMPERAGE: 32A; INTERRUPTINGCAPACITY: 10KA; POLE: 3P; CONNECTION: SCREW TERMINAL; FREQUE NCY RATING: 50/60HZ; ENCLOSURE: IP20/40; MOUNT: SNAP-ON; CURVE: C; SIZE: 54MM WD, 70MM DP, 90MM HT; MFR: SIEMENS LTD; MPN: 5SY4332-7 : ADDITIONAL INFO: REGION: GERMANY	3	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2012600067
DATE	: 05.01.2026
REQ No	: 1012507075
REQ TITLE	: MCB 1012507075
DELIVERY LOCATION	: 0051 - CS WRSN, TRNSMSN
CLOSING DATE	: 09.01.2026
CLOSING TIME	: 10:00:00

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

MCB

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2012600067
DATE	: 05.01.2026
REQ No	: 1012507075
REQ TITLE	: MCB 1012507075
DELIVERY LOCATION	: 0051 - CS WRSN, TRNSMSN
CLOSING DATE	: 09.01.2026
CLOSING TIME	: 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP