

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2012600153  
**DATE** : 07.01.2026  
**REQ No** : 1012507243  
**REQ TITLE** : MCB 1012507243  
**DELIVERY LOCATION** : 0051 - CS WRSN, TRNSMSN  
**CLOSING DATE** : 13.01.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1	2700091281		CIRCUIT BREAKER_MINIATURE; VOLTAGE: 230/400VAC, 48VDC; AMPERAGE: 6A; INTERRUPTING CAPACITY: 10KA; POLE: 1P; FREQUENCY RATING: 50/60HZ; ENCLOSURE: IP20; MOUNT: DIN RAIL; CURVE: C; SIZE: 17.5MM WD, 60MM DP, 80MM HT; MFR: MOELLER; MPN: PLSM-C6; APPLICATION: REACTOR; HRSR SUBSTATION; AREVA	2	EA				
2	2700091282		CIRCUIT BREAKER_MINIATURE; VOLTAGE: 230/400VAC, 48VDC; AMPERAGE: 16A; INTERRUPTING CAPACITY: 10KA; POLE: 1P; FREQUENCY RATING: 50/60HZ; ENCLOSURE: IP20; MOUNT: DIN RAIL; CURVE: C; SIZE: 17.5MM WD, 60MM DP, 80MM HT; MFR: MOELLER; MPN: PLSM-C16; APPLICATION: REACTOR; HRSR SUBSTATION; AREVA	3	EA				
3	2700091598		CIRCUIT BREAKER_MOLDED CASE; VOLTAGE: 380/415VAC; AMPERAGE: 160A; INTERRUPTING CAPACITY: 36KA; POLE: 3P; FRAME SIZE: 160A; FREQUENCY RATING: 50/60HZ; PHASE: 3PH; TRIP: THERMAL	2	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2012600153  
**DATE** : 07.01.2026  
**REQ No** : 1012507243  
**REQ TITLE** : MCB 1012507243  
**DELIVERY LOCATION** : 0051 - CS WRSN, TRNSMSN  
**CLOSING DATE** : 13.01.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MAGNETIC; MOUNT:FIXED/DRAW-OUT; STANDARD: IEC 60947-2; MFR: MERLIN GERIN; ADDITIONAL INFO : MODEL: NS160N; APPLICATION: ICT MARSHALLING KIOSK PANELS; 400KV;HYUNDAI; BRSH SUBSTATION						
4	2700091751		CIRCUIT BREAKER_MOLDED CASE; TYPE: NO FUSE; VOLTAGE: 690VAC, 250VDC;AMPERAGE: 15A; CONNECTION: SCREW TERMINAL; INTERRUPTING CAPACIT Y: 40KA;POLE: 4P; FRAME SIZE: 125A; FREQUENCY RATING: 50/60HZ; TRIP: THERMALMAGNETIC; MOUNT: PANEL; STANDARD: IEC 60947-2; MFR: ME L CO: MPN:NF125-SV-4P-15A-AC; ADDITIONAL INFO: W/AUX CONTACT (52LR); APPLICATION:ICT AT TCGY SUBSTATION; MITSUBISHI ELECTRIC CORP	2	EA				
5	2700091752		CIRCUIT BREAKER_MOLDED CASE; TYPE: NO FUSE; VOLTAGE: 690VAC, 250VDC;AMPERAGE: 250A; CONNECTION: SCREW TERMINAL; INTERRUPTING CAPACI TY:20KA; POLE: 4P; FRAME SIZE: 250A; FREQUENCY RATING: 50/60HZ; TRIP:THERMAL MAGNETIC; MOUNT: PANEL; STANDARD: IEC 60947-2; MFR: M E LCO: MPN:NF250-SV-4P-250A-AC; ADDITIONAL INFO:	2	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2012600153  
**DATE** : 07.01.2026  
**REQ No** : 1012507243  
**REQ TITLE** : MCB 1012507243  
**DELIVERY LOCATION** : 0051 - CS WRSN, TRNSMSN  
**CLOSING DATE** : 13.01.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			W/AUXILIARY CONTACT (52MA);APPLICATION: ICT AT TCGY SUBSTATION; MITSUBISHI ELECTRIC CORP						
6	2700094282		CIRCUIT BREAKER_MOLDED CASE; TYPE: NO FUSE; VOLTAGE: 500/690VAC;AMPERAGE: 200A; CONNECTION: SCREW TERMINAL; INTERRUPTING CAPACITY: 1 5KA;POLE: 4P; FRAME SIZE: 250A; FREQUENCY RATING: 50/60HZ; TRIP: THERMALMAGNETIC; MOUNT: PANEL; STANDARD: IEC 60947-2; MFR: MITSUBISHI ELECTRIC CORP; MPN: NF250-SW	2	EA				
7	2700094285		CIRCUIT BREAKER_MOLDED CASE; TYPE: NO FUSE; VOLTAGE: 500VAC, 250VDC;AMPERAGE: 15A; CONNECTION: SCREW TERMINAL; INTERRUPTING CAPACITY: 2.5KA; POLE: 2P; FRAME SIZE: 32A; FREQUENCY RATING: 50/60HZ; TRIP: THERMAL MAGNETIC; MOUNT: PANEL; STANDARD: IEC 60947-2; MFR: MITSUBISHI ELECTRIC CORP; MPN: NF32-SW-2P-15A-B-AX	2	EA				
8	2700094287		CIRCUIT BREAKER_MOLDED CASE; TYPE: NO FUSE; VOLTAGE: 500VAC, 250VDC;AMPERAGE: 5A;	2	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2012600153  
**DATE** : 07.01.2026  
**REQ No** : 1012507243  
**REQ TITLE** : MCB 1012507243  
**DELIVERY LOCATION** : 0051 - CS WRSN, TRNSMSN  
**CLOSING DATE** : 13.01.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONNECTION: SCREW TERMINAL; INTERRUPTING CAPACITY : 2.5KA; POLE: 2P; FRAME SIZE: 32A; FREQUENCY RATING: 50/60HZ; TRIP: THERMALMAGNETIC; MOUNT: PANEL; STANDARD: IEC 60947-2; MFR: MITSUBISHI ELECTRICCORP; MPN: NF32-SW-2P-5A-B-AX; ADDITIONAL INFO: INSULATION VOLTAGE:600VAC						
9	2700107458		CIRCUIT BREAKER, 3 POLE, MAKE: SCHRACK-GERMANY, TYPE: MC3N-AE400(Q01-PC), FOR KONCAR POWER TRANSFORMER, CROATIA AT MBRSSOLAR 400 KVSU BSTATION	2	EA				
10	2700122427		MCB; MAKE: GE; MODEL: G63C63; ARTICLE NO.: 676303; 3 POLE; 240 # 415V;63A; WITH AUXILIARY CONTACT; CAH; FOR IDT AT AVIATION SUBSTATION	3	EA				

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

<b>RFQ NUMBER</b>	: 2012600153
<b>DATE</b>	: 07.01.2026
<b>REQ No</b>	: 1012507243
<b>REQ TITLE</b>	: MCB 1012507243
<b>DELIVERY LOCATION</b>	: 0051 - CS WRSN, TRNSMSN
<b>CLOSING DATE</b>	: 13.01.2026
<b>CLOSING TIME</b>	: 10:00:00

MCB

### **STANDARD TERMS & CONDITIONS**

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.  
If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements  
The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

<b>RFQ NUMBER</b>	: 2012600153
<b>DATE</b>	: 07.01.2026
<b>REQ No</b>	: 1012507243
<b>REQ TITLE</b>	: MCB 1012507243
<b>DELIVERY LOCATION</b>	: 0051 - CS WRSN, TRNSMSN
<b>CLOSING DATE</b>	: 13.01.2026
<b>CLOSING TIME</b>	: 10:00:00

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**