

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012600352
DATE : 15.01.2026
REQ No : 1012507315
REQ TITLE : Spares 1012507315
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 21.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1	2700015673		SWITCH_VOLTAGE: 600VAC; AMPERAGE: 20A; CONNECTION: SCREW TERMINAL; TYPE:CONTROL; MFR: KRAUS & NAIMER; MPN: 5375 179-2; MFR: KRAUS & NAIMER; MPN:G25373-001; MFR: KRAUS & NAIMER; MPN: CH10 S-1L58-610 E-V; ADDITIONALINFO: W/SCREW; 5 POLE; 3POSITION; APPLICATION: XFMR ; 35/50MVA; JAEPS	2	EA				
2	2700087252		SWITCH_TYPE: DOOR LIGHT; MOUNT: PANEL; MFR: RITTAL GMBH & CO KG; MPN:SZ4315.300	2	EA				
3	2700091759		SWITCH_PUSHBUTTON; ELECTRICAL RATING: 230VAC, 110VDC 3A; CONTACTARRANGEMENT: 2NO 2NC; OPERATOR: MOMENTARY; COLOR: BLACK; ENCLOSURE: IP65; MOUNT: FLUSH; MFR: IDEC CORP; MPN: ABN120B; ADDITIONAL INFO:INSULATION VOLTAGE RATING: 600VAC; APPLICATION: ICT; MITSUBISHI EL ECTRICCORP; TCGY SUBSTATION	2	EA				
4	2700107453		3 POLE CONTACTOR, SIEMENS, TYPE: 3RT1066-6PP35 (K12-PC), 300A, 160KW,400/230V AC. FOR KONCAR POWER TRANSFORMER, CROATIA AT MBRSOLAR	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012600352
DATE : 15.01.2026
REQ No : 1012507315
REQ TITLE : Spares 1012507315
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 21.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			400 KV SUBSTATION						
5	2700107456		THREE POLE CONTACTOR, MAKE: SIEMENS, TYPE: 3RT1024-1AP04 (K29-CCC), C-35.5 KW/400 V, AC 230 V, 50 HZ, 3-POLE, 2 NO + 2 NC, SIZE S0, FOR KONCARPOWER TRANSFORMER, CROATIA AT MBRSLAR 400 KV SUBSTATION	2	EA				
6	3700029159		TIMER RELAY, MAKE: SCHRACK- GERMANY, TYPE: ZR5ER011 (K14-PC), 24-240 VAC/DC 250 AC, 1 CHANGEOVER CONTACT. ON/OFF DELAY, 1 SEC-100 H TIMESETTING. 8 A, 4 KV, 4 VA (1.5 W), -25 TO +55 °C. FOR KONCAR POWERTRANSFORMER, CROATIA AT MBRSLAR 400 KV SUBSTATION	2	EA				
7	3700029160		TIMER RELAY, MAKE: SIEMENS- GERMANY, TYPE: 7LF5300-6 (K77-CCC), 230 VAC, WEEKLY RUN TIMER, 0.85 ... 1.1UC, 50HZ, 1W, 16A, -10 ... + 55 °C, 4KV, FOR KONCAR POWER TRANSFORMER, CROATIA AT MBRSLAR 400 KV SUBSTATION	2	EA				
8	2700122425		CONTACTOR; MAKE: ABB; MODEL: AF30-00-13; PRODCUT ID: 1SBL277001R1300; EAN: 3471523111233; CONTROL VOLTAGE: 100-250V AC/DC; WITH AUXIL	2	EA				

**REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION**

RFQ NUMBER : 2012600352
DATE : 15.01.2026
REQ No : 1012507315
REQ TITLE : Spares 1012507315
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 21.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			IARYCONTACT BLOCK CA4-31E; FOR GE MAKE IDT AT AVIATION SUBSTATION						
9	2700107452		CONTACTOR, 3 POLE. MAKE: SIEMENS, TYPE: 3RT2023-1AP00, WITH AUXILIARYCONTACTS 1 NO+ 1 NC; FOR KONCAR POWER TRANSFORMER, CROATIA AT MBRSLAR40 0 KV SUBSTATION	2	EA				
10	2700105269		CONTACTOR_MOTOR; COIL VOLTAGE: 230V; AMPERAGE: 95A; CONTACT ARRANGEMENT:1NO 1NC; ENCLOSURE: IP20; MFR: ETI; MPN: CEM95.11-230: ADDITIONAL INFO:STARTER; APPLICATION: XFMR OIL FILTRATION PLANT GLOBE CORE MOBILESTATION CMM; 6000L/HR; SERIAL NO: 0923	2	EA				
11	2700107468		MOTOR PROTECTION SWITCH, MAKE: SIEMENS, TYPE: 3RV1041-4JA10 (Q41-CCC);TYPE: 3RV2041-4JA10; 3 PHASE WITH AUXILIARY CONTACTS, SETTING RANGE:45-63A, FOR KONCAR POWER TRANSFORMER, CROATIA AT MBRSLAR 400 KV SUBSTATION	2	EA				
12	2700107467		AUXILIARY SWITCH FOR MOTOR PROTECTION	2	EA				

**REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION**

RFQ NUMBER : 2012600352
DATE : 15.01.2026
REQ No : 1012507315
REQ TITLE : Spares 1012507315
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 21.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SWITCH, MAKE: SIEMENS, TYPE:3RV2901-1E (Q1-CCC), FOR KONCAR POWER TRANSFORMER, CROATIA AT MBR SOLAR400 KV SUBSTATION						
13	2700107466		AUXILIARY SWITCH FOR MOTOR PROTECTION SWITCH, MAKE: SIEMENS, TYPE:3RV2901-1A (Q1-CCC), FOR KONCAR POWER TRANSFORMER, CROATIA AT MBR SOLAR400 KV SUBSTATION	2	EA				
14	2700091210		CONTACTOR_MOTOR; TYPE: MAGNETIC; COIL VOLTAGE: 230VAC; AMPERAGE: 1.5A; LINE VOLTAGE: 500VAC; POLE: 4P; ELECTRICAL RATING: 50HZ; CONTA CTARRANGEMENT: 4NO; ENCLOSURE: IP20; MFR: EATON; MPN: DILA-40+ DILM150-XH122; MFR: MOELLER GMBH; MFR: AREVA; ADDITIONAL INFO: DEVICE NO: K01;W/2NO 2NC AUX CONTACT BLOCK; DILM150-XH122; APPLICATION: ICT MARSHALLINGKIOSK PANELS; 400KV; AREVA; HRSR SUBSTATION	2	EA				
15	2700091211		CONTACTOR_MOTOR; TYPE: MAGNETIC; COIL VOLTAGE: 230VAC; AMPERAGE: 1.5A; LINE	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012600352
DATE : 15.01.2026
REQ No : 1012507315
REQ TITLE : Spares 1012507315
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 21.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			VOLTAGE: 500VAC; POLE: 4P; ELECTRICAL RATING: 50HZ; CONTA CTARRANGEMENT: 3NO 1NC; ENCLOSURE: IP20; MFR: EATON; MPN: DILA-31 + DILAXH122; MFR: MOELLER GMBH; MFR: AREVA; ADDITIONAL INFO: DEVI CE NO: K06; W/2NO 2NC AUX CONTACT BLOCK; DILA XH122; APPLICATION: ICT MARSHALLINGKIOSK PANELS; 400KV; AREVA; HRSR SUBSTATION; REF: XT RE10B31TD						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Spares

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2012600352
DATE	: 15.01.2026
REQ No	: 1012507315
REQ TITLE	: Spares 1012507315
DELIVERY LOCATION	: 0051 - CS WRSN, TRNSMSN
CLOSING DATE	: 21.01.2026
CLOSING TIME	: 10:00:00

4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP