

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012601131
DATE : 10.03.2026
REQ No : 1012601105
REQ TITLE : Purchase of fire water system
DELIVERY LOCATION : 0026 - H4 STORES, AWEER
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1	2300050606		GASKET; MATERIAL: EPDM RUBBER COMPOUND; ASTM D2000; AWWA C606; COLOURCODE : GREEN MARK; SHORE HARDNESS : 65; MINIMUM ELONGATION: 30 0%;REQUIRED FOR SPRINKLER OUTLET; FLUID STYLE 309; SIZE : 2 INCH X 1/2INCH; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE: 35 BAR; ULLISTED; RED PAINTED RAL 3000; MAKE : FLUID FIRE EQUIPMENT; UK/INDIA;APPLICATION : PHASE IV FIRE WATER SYSTEM	1	EA				
2	2300050605		GASKET; MATERIAL: EPDM RUBBER COMPOUND; ASTM D2000; AWWA C606; COLOURCODE : GREEN MARK; SHORE HARDNESS : 65; MINIMUM ELONGATION: 30 0%;REQUIRED FOR TEE; GROOVED; THREADED MECHANICAL; FLUID STYLE 305; SIZE :2 INCH X 1 INCH; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE:35 BAR; UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIRE EQUIPMENT;UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYSTEM	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012601131
DATE : 10.03.2026
REQ No : 1012601105
REQ TITLE : Purchase of fire water system
DELIVERY LOCATION : 0026 - H4 STORES, AWEER
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
3	2300050604		TEE; GROOVED; THREADED MECHANICAL; FLUID STYLE 305; SIZE : 2 INCH X 1INCH; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE: 35 BAR; ULLISTED; RED PAINTED RAL 3000; MAKE : FLUID FIRE EQUIPMENT; UK/INDIA;APPLICATION : PHASE IV FIRE WATER SYSTEM	1	EA				
4	2300050603		FLANGE; GROOVED; SIZE : DN300 X ANSI CLASS 125; FLUID STYLE: 373; FLATFACE; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE: 3 5 BAR; ULLISTED; RED PAINTED RAL 3000; MAKE : FLUID FIRE EQUIPMENT; UK/INDIA;APPLICATION : PHASE IV FIRE WATER SYSTEM	1	EA				
5	2300050602		FLANGE; GROOVED; SIZE : DN250 X ANSI CLASS 125; FLUID STYLE: 373; FLATFACE; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE: 3 5 BAR; ULLISTED; RED PAINTED RAL 3000; MAKE : FLUID FIRE EQUIPMENT; UK/INDIA;APPLICATION : PHASE IV FIRE WATER SYSTEM	1	EA				
6	2300050601		GASKET; MATERIAL: EPDM RUBBER COMPOUND; ASTM D2000; AWWA C606; COLOURCODE : GREEN	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012601131
DATE : 10.03.2026
REQ No : 1012601105
REQ TITLE : Purchase of fire water system
DELIVERY LOCATION : 0026 - H4 STORES, AWEER
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MARK; SHORE HARDNESS : 65; MINIMUM ELONGATION: 30 0%;REQUIRED FOR FLANGE; SPLIT; SIZE : DN200 X ANSI CLASS 125; FLUID STYLE:375; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE : 35 BAR; EPDMRUBBER GASKET; UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIREEQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYSTEM						
7	2300050600		FLANGE; SPLIT; SIZE : DN200 X ANSI CLASS 125; FLUID STYLE: 375;MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE: 35 BAR; EPDM RUBBER GASKET; UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIREEQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYSTEM	1	EA				
8	2300050599		GASKET; MATERIAL: EPDM RUBBER COMPOUND; ASTM D2000; AWWA C606; COLOURCODE : GREEN MARK; SHORE HARDNESS : 65; MINIMUM ELONGATION: 30 0%;REQUIRED FOR FLANGE; SPLIT; SIZE : DN150 X ANSI CLASS 125; FLUID STYLE:375; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE : 35 BAR; EPDMRUBBER GASKET; UL LISTED; RED	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012601131
DATE : 10.03.2026
REQ No : 1012601105
REQ TITLE : Purchase of fire water system
DELIVERY LOCATION : 0026 - H4 STORES, AWEER
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PAINTED RAL 3000; MAKE : FLUID FIREEQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYSTEM						
9	2300050598		FLANGE; SPLIT; SIZE : DN150 X ANSI CLASS 125; FLUID STYLE: 375; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE: 35 BAR; EPDM RUBBER GASKET; UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIREEQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYSTEM	1	EA				
10	2300050597		GASKET; MATERIAL: EPDM RUBBER COMPOUND; ASTM D2000; AWWA C606; COLOURCODE : GREEN MARK; SHORE HARDNESS : 65; MINIMUM ELONGATION: 300%;REQUIRED FOR FLANGE; SPLIT; SIZE : DN100 X ANSI CLASS 125; FLUID STYLE:375; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE : 35 BAR; EPDMRUBBER GASKET; UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIREEQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYSTEM	4	EA				
11	2300050596		FLANGE; SPLIT; SIZE : DN100 X ANSI CLASS 125; FLUID STYLE: 375; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE: 35 BAR; EPDM RUBBER GASKET; UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIREEQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYSTEM	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012601131
DATE : 10.03.2026
REQ No : 1012601105
REQ TITLE : Purchase of fire water system
DELIVERY LOCATION : 0026 - H4 STORES, AWEER
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BBER GASKET; UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIREEQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYSTEM						
12	2300050595		GASKET; MATERIAL: EPDM RUBBER COMPOUND; ASTM D2000; AWWA C606; COLOURCODE : GREEN MARK; SHORE HARDNESS : 65; MINIMUM ELONGATION: 30 0%;REQUIRED FOR FLANGE; SPLIT; SIZE : DN80 X ANSI CLASS 125; FLUID STYLE:375; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE : 35 BAR; EPDMRUBBER GASKET; UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIREEQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WA TE R SYSTEM	4	EA				
13	2300050594		FLANGE; SPLIT; SIZE : DN80 X ANSI CLASS 125; FLUID STYLE: 375; MATERIAL:DUCTILE IRON; ASTM A 536; WORKING PRESSURE: 35 BAR; EPDM RU BBER GASKET;UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIRE EQUIPMENT; UK/INDIA;APPLICATION : PHASE IV FIRE WATER SYSTEM	1	EA				
14	2300050593		GASKET; MATERIAL: EPDM RUBBER COMPOUND; ASTM D2000; AWWA C606; COLOURCODE : GREEN	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012601131
DATE : 10.03.2026
REQ No : 1012601105
REQ TITLE : Purchase of fire water system
DELIVERY LOCATION : 0026 - H4 STORES, AWEER
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MARK; SHORE HARDNESS : 65; MINIMUM ELONGATION: 30 0%;REQUIRED FOR FLANGE; SPLIT; SIZE : DN50 X ANSI CLASS 125; FLUID STYLE:375; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE : 35 BAR; EPDMRUBBER GASKET; UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIREEQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYSTEM						
15	2300050592		FLANGE; SPLIT; SIZE : DN50 X ANSI CLASS 125; FLUID STYLE: 375; MATERIAL:DUCTILE IRON; ASTM A 536; WORKING PRESSURE: 35 BAR; EPDM RUBBER GASKET;UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIRE EQUIPMENT; UK/INDIA;APPLICATION : PHASE IV FIRE WATER SYSTEM	1	EA				
16	2300050591		GASKET; MATERIAL: EPDM RUBBER COMPOUND; ASTM D2000; AWWA C606; COLOURCODE : GREEN MARK; SHORE HARDNESS : 65; MINIMUM ELONGATION: 30 0%;REQUIRED FOR COUPLING; FLEXIBLE GROOVED; SIZE : DN300 X SCHEDULE 40;STYLE: 315; MATERIAL: DUCTILE IRON; ASTM A 536;	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012601131
DATE : 10.03.2026
REQ No : 1012601105
REQ TITLE : Purchase of fire water system
DELIVERY LOCATION : 0026 - H4 STORES, AWEER
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WORKING PRE S SURE: 35BAR; MAKE : FLUID FIRE EQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIREWATER SYSTEM						
17	2300050590		COUPLING; FLEXIBLE GROOVED; SIZE : DN300 X SCHEDULE 40; STYLE: 315; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE: 35 BAR; EP DMRUBBER GASKET; UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIREEQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYSTEM	1	EA				
18	2300050589		GASKET; MATERIAL: EPDM RUBBER COMPOUND; ASTM D2000; AWWA C606; COLOURCODE : GREEN MARK; SHORE HARDNESS : 65; MINIMUM ELONGATION: 30 0%; REQUIRED FOR COUPLING; FLEXIBLE GROOVED; SIZE : DN250 X SCHEDULE 40; STYLE: 315; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRE S SURE: 35BAR; MAKE : FLUID FIRE EQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIREWATER SYSTEM	4	EA				
19	2300050588		COUPLING; FLEXIBLE GROOVED; SIZE : DN250 X	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012601131
DATE : 10.03.2026
REQ No : 1012601105
REQ TITLE : Purchase of fire water system
DELIVERY LOCATION : 0026 - H4 STORES, AWEER
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SCHEDULE 40; STYLE: 315; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE: 35 BAR; EP DMRUBBER GASKET; UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIREEQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYSTEM						
20	2300050587		GASKET; MATERIAL: EPDM RUBBER COMPOUND; ASTM D2000; AWWA C606; COLOURCODE : GREEN MARK; SHORE HARDNESS : 65; MINIMUM ELONGATION: 30 0%;REQUIRED FOR COUPLING; FLEXIBLE GROOVED; SIZE : DN200 X SCHEDULE 40;STYLE: 315; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRE S SURE: 35BAR; MAKE : FLUID FIRE EQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIREWATER SYSTEM	4	EA				
21	2300050576		COUPLING; FLEXIBLE GROOVED; SIZE : DN200 X SCHEDULE 40; FLUID STYLE:315; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE: 35 B AR; EPDMRUBBER GASKET; UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIREEQUIPMENT;	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012601131
DATE : 10.03.2026
REQ No : 1012601105
REQ TITLE : Purchase of fire water system
DELIVERY LOCATION : 0026 - H4 STORES, AWEER
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYSTEM						
22	2300050575		GASKET; MATERIAL: EPDM RUBBER COMPOUND; ASTM D2000; AWWA C606; COLOURCODE : GREEN MARK; SHORE HARDNESS : 65; MINIMUM ELONGATION: 300%;REQUIRED FOR COUPLING; FLEXIBLE GROOVED; SIZE : DN150 X SCHEDULE 40;FLUID STYLE: 313; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE:35 BAR; MAKE : FLUID FIRE EQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYSTEM	4	EA				
23	2300050574		COUPLING; FLEXIBLE GROOVED; SIZE : DN150 X SCHEDULE 40; FLUID STYLE:313; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE: 35 BAR; EPDM RUBBER GASKET; UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIRE EQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYSTEM	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012601131
DATE : 10.03.2026
REQ No : 1012601105
REQ TITLE : Purchase of fire water system
DELIVERY LOCATION : 0026 - H4 STORES, AWEER
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
24	2300050573		GASKET; MATERIAL: EPDM RUBBER COMPOUND; ASTM D2000; AWWA C606; COLOURCODE : GREEN MARK; SHORE HARDNESS : 65; MINIMUM ELONGATION: 30 0%;REQUIRED FOR COUPLING; FLEXIBLE GROOVED; SIZE : DN100 X SCHEDULE 40;FLUID STYLE: 313; MATERIAL: DUCTILE IRON; ASTM A 536; WORKI N G PRESSURE:35 BAR; MAKE : FLUID FIRE EQUIPMENT; UK/INDIA; APPLICATION : PHASE IVFIRE WATER SYSTEM	4	EA				
25	2300050572		COUPLING; FLEXIBLE GROOVED; SIZE : DN100 X SCHEDULE 40; FLUID STYLE:313; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE: 35 B AR; EPDMRUBBER GASKET; UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIREEQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WATER SY S TEM	1	EA				
26	2300050571		GASKET; MATERIAL: EPDM RUBBER COMPOUND; ASTM D2000; AWWA C606; COLOURCODE : GREEN MARK; SHORE HARDNESS : 65; MINIMUM	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012601131
DATE : 10.03.2026
REQ No : 1012601105
REQ TITLE : Purchase of fire water system
DELIVERY LOCATION : 0026 - H4 STORES, AWEER
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ELONGATION: 30 0%;REQUIRED FOR COUPLING; FLEXIBLE GROOVED; SIZE : DN80 X SCHEDULE 40;FLUID STYLE: 313; MATERIAL: DUCTILE IRON; ASTM A 536; WORKIN G PRESSURE:35 BAR; MAKE : FLUID FIRE EQUIPMENT; UK/INDIA; APPLICATION : PHASE IVFIRE WATER SYSTEM						
27	2300050570		COUPLING; FLEXIBLE GROOVED; SIZE : DN80 X SCHEDULE 40; FLUID STYLE: 313;MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE: 35 BA R; EPDMRUBBER GASKET; UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIREEQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYS T EM	1	EA				
28	2300050569		GASKET; MATERIAL: EPDM RUBBER COMPOUND; ASTM D2000; AWWA C606; COLOURCODE : GREEN MARK; SHORE HARDNESS : 65; MINIMUM ELONGATION: 30 0%;REQUIRED FOR COUPLING; FLEXIBLE GROOVED; SIZE : DN50 X SCHEDULE 40;FLUID	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012601131
DATE : 10.03.2026
REQ No : 1012601105
REQ TITLE : Purchase of fire water system
DELIVERY LOCATION : 0026 - H4 STORES, AWEER
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			STYLE: 313; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE:35 BAR; MAKE : FLUID FIRE EQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYSTEM						
29	2300050568		COUPLING; FLEXIBLE GROOVED; SIZE : DN50 X SCHEDULE 40; FLUID STYLE: 313; MATERIAL: DUCTILE IRON; ASTM A 536; WORKING PRESSURE: 35 BAR; EPDM RUBBER GASKET; UL LISTED; RED PAINTED RAL 3000; MAKE : FLUID FIRE EQUIPMENT; UK/INDIA; APPLICATION : PHASE IV FIRE WATER SYSTEM	1	EA				

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Purchase of fire water system pipeline fittings and gaskets for H-Station, Phase-IV, Al-Aweer.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2012601131
DATE	: 10.03.2026
REQ No	: 1012601105
REQ TITLE	: Purchase of fire water system
DELIVERY LOCATION	: 0026 - H4 STORES, AWEER
CLOSING DATE	: 16.03.2026
CLOSING TIME	: 10:00:00

For any inquiries related this item, Kindly contact:

Mohamed Safik: 04-81-40306 / mohamed.sait@dewa.gov.ae;

Zamir Usman Bhai Alware: 04-81-40304/Zamir.Alware@dewa.gov.ae

STANDARD TERMS & CONDITIONS

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page13 of 16

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2012601131
DATE	: 10.03.2026
REQ No	: 1012601105
REQ TITLE	: Purchase of fire water system
DELIVERY LOCATION	: 0026 - H4 STORES, AWEER
CLOSING DATE	: 16.03.2026
CLOSING TIME	: 10:00:00

shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8) Data Privacy, Security and Sharing:

- Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
- DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
- DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
- DEWA reserves the right to withhold data from third parties if deemed sensitive.
- Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
- Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012601131
DATE : 10.03.2026
REQ No : 1012601105
REQ TITLE : Purchase of fire water system
DELIVERY LOCATION : 0026 - H4 STORES, AWEER
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012601131
DATE : 10.03.2026
REQ No : 1012601105
REQ TITLE : Purchase of fire water system
DELIVERY LOCATION : 0026 - H4 STORES, AWEER
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP