

# REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

هيئة كـهـرباء وميـاه دبـي Dubai Electricity&Water Authority



RFQ NUMBER	: 2332302164				
DATE	: 26.09.2023				
REQ No	: 1032303418				
REQ TITLE	: SPECIALIST SERVICE				
DELIVERY LOCATION					
CLOSING DATE	: 02.10.2023				
CLOSING TIME	: 10:00:00				

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SPECIALIST SERVICE FOR FIRMWARE'S UPGRADATION OF EXISTING EMERSON AMS6500 ATG "TURBINE SUPERVISORY SYSTEM" IN DEWA JABAL ALI E-STATI ON, MAKE: EMERSON, MODEL: AMS 6500 ATG. THERE ARE 19 MODULES INSTALLED IN EXISTING ATG SYSTEM, AS FOLLOWING: - UNIVERSAL MODULE A65 00-UM: 14 NO.S - RELAY MODULE A6500-RC: 3 NO.S - COMMUNICATION A6500-CC: 2 NO.S - RACK A6500-SR: 3 NO,S THE NUMBER OF SPARES ARE AS FOLLOWING: - A6500-UM: 4 NO.S - A6500-RC: 2 NO.S - A6500-CC: 2 NO.S - A6500-RC: 2 NO.S - A6500-CC: 2 NO.S - A6500-SR: 2 NO.S NOTES TO VENDORS: -ALL OF THE EXISTING I NSTALLED MODULES/RACKS AND THE SPARE MODULES SHALL BE FIRMWARE UPGRADED. ALSO THE LATEST MACHINE STUDIO SOFTWARE NEED TO BE INSTALLE D ON OUR EXISTING CONFIGURATION LAPTOP BEFORE UPGRADING THE FIRMWARE'S, FULL BACKUPS OF EXISTING MODULES & PROJECT SOFTWAREETC	1	JOB				

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.



### REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

هيئة كـهـربـاء وميـاه دبـي Dubai Electricity&Water Authority



RFQ NUMBER	: 2332302164				
DATE	: 26.09.2023				
REQ No	: 1032303418				
REQ TITLE	: SPECIALIST SERVICE				
DELIVERY LOCATION					
CLOSING DATE	: 02.10.2023				
CLOSING TIME	: 10:00:00				

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MUST BE TAKEN SO IN CASE THE FIRMWARE						
			UPGRADE ACTIVITY WAS NOT SUCCESSFUL THEN						
			ATG SYSTEM CAN BE BROUGHT BACK TO						
			PREVIOUS WORKING N						
			ORMAL CONDITION ! - ALL THE EXISTING						
			SETTINGS/CONFIGURATIONS/USER PROGRAM OF						
			THE MODULES SHALL BE RETAINED AND SHOULD						
			NOT BE DISTUR						
			BED WHEN FIRMWARE UPGRADED AFTER						
			FIRMWARE UPGRADE, DURING TURBINE STARTUP,						
			VENDOR SHALL BE AVAILABLE TO MONITOR THE						
			SYSTEM PERFO						
			RMANCE AND BEHAVIOR SCOPE OF WORK FOR						
			DEWA WILL BE: ARRANGING GATEPASS AND						
			TURBINE SHUTDOWN ONLY. FOR MORE						
			TECHNICAL INFORMATIO						
			N PLEASE CONTACT: - MR. ESMAEEL ON 055-144						
			2323 (SAYED.HOSEYNI@DEWA.GOV.AE) - MR.						
			KARIM ON 052-4844344						
			(KARIM.ELGAMASY@DEWA.GOV.AE)						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### SPECIAL NOTES / INSTRUCTIONS:

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.



# REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

هيئة كـهـربـاء وميـاه دبــي Dubai Electricity&Water Authority



<b>RFQ NUMBER</b>	: 2332302164
DATE	: 26.09.2023
REQ No	: 1032303418
REQ TITLE	: SPECIALIST SERVICE
DELIVERY LOCATION	
CLOSING DATE	: 02.10.2023
CLOSING TIME	: 10:00:00

SPECIALIST SERVICE

#### **STANDARD TERMS & CONDITIONS**

1) Prices should be 'DDP' delivery duty paid at DEWA stores.

2) Quotation to be submitted only in local currency U.A.E Dirhams

3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material

4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP