

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332302305
DATE : 13.10.2023
REQ No : 1032303866
REQ TITLE : PH 1 CONDENSATE TANK
DELIVERY LOCATION
CLOSING DATE : 23.10.2023
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK AT K STATION, JEBEL ALI POWER STATION TITLE: REPLACEMENT OF DEFECTIVE CARBON STEEL PIPE AND FITTINGS AT K PH1 CONDENSATE LINE. SIZE AND QUANTITY: SIZE#NO OF JOINTS # 1"#14# 2"#38# 3"#21# 4"#36# NOTE : INVOICE LUMP SUM BASIS MATERIAL :SA 106 WORK SCHEDULE: DURATION - 4 DAYS PRE-BID SITE INSPECTION: THE CONTRACTOR SHALL VISIT THE SITE AND BE FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, ETC., BEFORE SUBMITTING THE BID. DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES / PRICES DURING AND AFTER THE EXECUTION OF WORK. SCOPE OF WORK: MOBILIZE MEN/EQUIPMENT WITHIN 01 DAYS OF ADVANCE NOTICE. SUBMIT FOLLOWING DOCUMENTS TO OBTAIN PTW, METHOD STATEMENT RISK ASSESSMENT OF THE</p>	1	LS				

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332302305
DATE : 13.10.2023
REQ No : 1032303866
REQ TITLE : PH 1 CONDENSATE TANK
DELIVERY LOCATION
CLOSING DATE : 23.10.2023
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WORK TOOLBOX TALK REPORT. OBTAIN PTW (PERMIT TO WORK) AND LC (LINE CLEARANCE) FROM DEWA. CONDUCT SITE SURVEY AND SAFETY INSPECTION, TO ASSESS THE WORKING ENVIRONMENT. ENSURE SITE AREA IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALL RESPECTS. ENSURE PROPER ISOLATION OF THE LINE & DEWA CHEMIST CLEARANCE & HWP ARE OBTAINED DAILY BEFORE START OF WORK. ENSURE NO FLAMMABLE MATERIALS NEAR THE HOT WORK AREA. IF THE WORKING ENVIRONMENT IS SAFE, PROCEED WITH THE FOLLOWING STEPS. FOR HOT WORK, WELDING BOOTH TO BE PROVIDED TO PREVENT WELDING SPARK OR CUTTING MATERIALS COMING OUT FROM HOT WORK AREA. ENSURE TO PROVIDE ENOUGH FIRE EXTINGUISHER, FIRE BLANKETS AT SITE. PROTECT THE NEARBY LINES / CABLES USING FIRE BLANKET. BARRICADE THE AREA BELOW WITH SIGNAGE</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332302305
DATE : 13.10.2023
REQ No : 1032303866
REQ TITLE : PH 1 CONDENSATE TANK
DELIVERY LOCATION
CLOSING DATE : 23.10.2023
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PROCEED WITH CUTTING/REMOVAL OF PIPE & PREPARE THE JOINTS. WELD THE PIPE FITTINGS. QUALIFIED JOB SUPERVISOR SHALL BE ASSIGNED FOR THE JOB. SKILLED FABRICATORS / WELDERS SHALL CARRY OUT ALL THE JOBS. WELD JOINTS TO BE MADE BY QUALIFIED WELDER ACCORDING TO APPLICABLE WPS & ASME REQUIREMENTS. (WPS & WELDER CERTIFICATE TO BE PROVIDED) HOUSEKEEPING AND DISPOSAL OF WASTE TO BE DONE BEFORE SITE CLEARANCE. DE-MOBILIZE MEN AND EQUIPMENT AFTER COMPLETION OF THE JOB. WORK COMPLETION REPORT TO BE SUBMITTED. REPORT SHALL CONTAIN RELEVANT PHOTOS. ALL TOOLS & TACKLES ARE IN CONTRACTOR'S SCOPE. PROPER AND TESTED TOOLS TO BE USED. ALL LIFTING & POWER TOOLS SHALL HAVE VALID 3RD PARTY TEST CERTIFICATE. WELDING MACHINES ALL HAVE 3RD PARTY CALIBRATION CERTIFICATE.</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332302305
DATE : 13.10.2023
REQ No : 1032303866
REQ TITLE : PH 1 CONDENSATE TANK
DELIVERY LOCATION
CLOSING DATE : 23.10.2023
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DEWA SCOPE: SCAFFOLDING PIPES AND FITTINGS SUPPLY. NDE WARRANTY THE WARRANTY PERIOD FOR THE WORK SHALL BE ONE YEAR FROM THE DATE OF COMPLETION OF WORK CERTIFIED BY DEWA GENERAL TERMS & CONDITIONS THE CONTRACTOR SHALL VISIT THE SITE AND BE FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE SUBMIT HIS BID. THE CONTRACTOR SHALL ENSURE HOUSEKEEPING ON A DAILY BASIS AND THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSALS TO DESIGNATED PLACES. ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATION SHALL BE FOLLOWED AT WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR'S ENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILE WORKING IN A HAZARDOUS AREA. SC</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332302305
DATE : 13.10.2023
REQ No : 1032303866
REQ TITLE : PH 1 CONDENSATE TANK
DELIVERY LOCATION
CLOSING DATE : 23.10.2023
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AFFOLDING IF REQUIRED SHALL BE ARRANGED BY DEWA. QUALIFIED RIGGER SHALL BE ARRANGED BY CONTRACTOR FOR RIGGING ACTIVITIES. 9.6. THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PER QUALITY/SCHEDULE REQUIREMENT. 9.7. CONTRACTOR'S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THE PERIOD OF WORK. 9.8. SERVICE AIR, ELECTRICITY AND WATER FOR WORK AT DEWA SITE. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO HAVE HIS OWN ARRANGEMENT IN EXTENDING THE ELECTRICITY AND WATER UTILITY TO HIS PLACES OF WORK INCLUDING LIGHTING. SAFETY, HEALTH AND ENVIRONMENT THE CONTRACTOR SHALL COMPLY WITH ALL THE REQUIREMENTS STIPULATED IN THE FOLLOWING OHS DOCUMENT FROM DEWA FOR HEALTH, SAFETY AND ENVIRONMENTAL REQUIREMENTS DURING THE EXECUTION OF THE PROJECT. IMSP01 # SP 06 #</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332302305
DATE : 13.10.2023
REQ No : 1032303866
REQ TITLE : PH 1 CONDENSATE TANK
DELIVERY LOCATION
CLOSING DATE : 23.10.2023
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>H&S PROCEDURE FOR CONT RACTOR AND CONSULTANT IMSP01 # SP 15 # CONTROL OF SUBSTANCES HAZARDOUS TO HEALTH (COSHS) 10.1.3. JAPS/H-18 # ENVIRONMENTAL MANAGEMEN T SYSTEM PROCEDURE THE CONTRACTOR#S WORK WILL FALL WITHIN THE PURVIEW OF SAFETY SURVEYS CONDUCTED REGULARLY BY THE DEWA SAFETY SECTI ON. ALL THEIR SAFETY REQUIREMENTS SHALL BE PROMPTLY MET. THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THE WORK CON DUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT. NO WASTAGES SHALL BE LEFT ON THE GROUND OR AT ANY AREA BEI NG PART OF THE CONTRACTOR#S WORK AREA. SUGGESTED TO USE TARPULIN AND/OR MESH COVER SURROUND SYSTEM. SECURITY PERMISSIONS THE CONTR ACTOR SHOULD SUBMIT THE FOLLOWING PARTICULARS WELL IN ADVANCE FOR DEWA TO</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332302305
DATE : 13.10.2023
REQ No : 1032303866
REQ TITLE : PH 1 CONDENSATE TANK
DELIVERY LOCATION
CLOSING DATE : 23.10.2023
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ISSUE ENTRY PASSES FOR THEM VALID UP TO THE PERIOD OF CONTRACT WORK LIST OF HIS STAFF PROPOSED TO BE ENGAGED ON THE JOB WITH DESIGNATION, COPY OF THEIR VALID PASSPORT, LABOR CARD AND TWO PP SIZE PHOTOGRAPHS. FOR VEHICLE DRIVERS, COPIES OF THEIR VALID DRIVING LICENSE ALSO ARE TO BE ATTACHED. # LIST OF VEHICLES WITH A COPY OF VALID REGISTRATION CERTIFICATE/ VEHICLE LICENSE OF EACH VEHICLE. LIST OF TOOLS, EQUIPMENT, CONSUMABLES, ETC., WITH DELIVERY NOTE FOR EACH. TRAVEL DECLARATION FORM UNDERTAKING LETTER THE CONTRACTOR SHALL BRING THEIR MATERIALS, EQUIPMENT, OFFICE FACILITIES, SUBSTANCES, COMPUTERS, CAMERAS ETC. WITH THEIR DELIVERY NOTE AFTER DEWA APPROVAL ONLY FOR THE INTENDED CONTRACT PURPOSE. # ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332302305
DATE : 13.10.2023
REQ No : 1032303866
REQ TITLE : PH 1 CONDENSATE TANK
DELIVERY LOCATION
CLOSING DATE : 23.10.2023
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>POWER STATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BY DEWA SECURITY.</p> <p>THIS DOCUMENTS INCLUDING DELIVERY NOTE WILL BE THE BASIS FOR THE CLEARANCE (GATE PASS) TO TAKE THE MATERIAL & TOOLS OUT ON COMPLETI</p> <p>ON OF THE JOB. AT ALL TIMES CONTRACTORS# PERSONNEL MUST STRICTLY ADHERE TO THE SECURITY PROCEDURES OF DEWA DURING THEIR PRESENCE AND</p> <p>WHILE WORKING INSIDE DEWA PREMISES. THE PRESENCE OF CONTRACTOR#S MANPOWER SHALL BE RESTRICTED TO THE WORKING AREAS ONLY. ANY CONTRA</p> <p>CTOR#S STAFF VIOLATING THIS WOULD BE BARRED FROM ENTERING DEWA PREMISES. EXTENSION OF CONTRACTOR#S WORKING TIME BEYOND DEWA#S NORMAL</p> <p>DUTY TIME SHALL BE GRANTED FURTHER TO THE APPROVAL OF DEWA CONCERNED SITE ENGINEER.</p> <p># NO STAFF OR VEHICLES OF THE CONTRACTOR WILL B</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332302305
DATE : 13.10.2023
REQ No : 1032303866
REQ TITLE : PH 1 CONDENSATE TANK
DELIVERY LOCATION
CLOSING DATE : 23.10.2023
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			E PERMITTED TO STAY INSIDE DEWA PREMISES AFTER CLOSE OF BUSINESS HOURS. CONTRACTOR WHILE WORKING AT SITE SHALL HAVE ALL THE DATASHEET, DAILY TOOL BOX TALK RECORDS, PERMIT TO WORK DOCUMENTS, HOT WORK PERMIT DISPLAYED AT SITE AND THE WARNING SIGN BOARD SHALL BE AVAILABLE AT SITE AT ALL TIMES.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

PH 1 CONDENSATE TANK LINE REPLACEMENT WORK; Contact Person:
Kaliyamoorthi Venkatachalapathi / KaliyamoorthiV@dewa.gov.ae / 043226919

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material

**REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION**

RFQ NUMBER : 2332302305
DATE : 13.10.2023
REQ No : 1032303866
REQ TITLE : PH 1 CONDENSATE TANK
DELIVERY LOCATION
CLOSING DATE : 23.10.2023
CLOSING TIME : 10:00:00

4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP