



**RFQ NUMBER** : 2332302767

**DATE** : 15.12.2023 **REQ No** : 1032304659

**REQ TITLE** : AMC for Fire Protection Syste

**DELIVERY LOCATION** 

**CLOSING DATE** : 29.12.2023

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	FIRE PROTECTION SYSTEM (FPS) AMC FOR 33 KV SUBSTATION FAQA#FIRE PROTECTION SYSTEM ANNUAL MAINTENANCE CONTRACT (AMC) WHICH SHALLINCLU DE- QUARTERLY BASIS (4 TIMES) PLANNED PREVENTIVE MAINTENANCE/SERVICING ANDINSPECTION UNLIMITED 24/7 EMERGENCY CALL RESPONSE FOR FA ULT ATTENDING/BREAKDOWNMAINTENANCE FIRE SYSTEMS SHALL COVER FIRE ALARM SYSTEM, FIRE FIGHTING SYSTEM, FIREPUMPS, SPRINKLER SYSTEMS, FIRE HOSE REELS, LANDING VALVES, BREECHINGINLETS AND FIRE EXTINGUISHERS (INSPECTION ANDVALIDATION OF FIRE EXTINGUISHERS ON QUARTERL Y BASIS), FM200 SYSTEM- EMERGENCY EXIT/LIGHT SYSTEM AND ASSOCIATED ACCESSORIES.CONTACT PERSON:- RAM KUMAR RAVI (0559566720) (RAM.RA VI@DEWA.GOV.AE)	1	EA				
2		ITEM-00001	FIRE PROTECTION SYSTEM (FPS) AMC FOR 33 KV SUBSTATION QRLS#FIRE PROTECTION SYSTEM	1	EA				





**RFQ NUMBER** : 2332302767

**DATE** : 15.12.2023 **REQ No** : 1032304659

**REQ TITLE** : AMC for Fire Protection Syste

**DELIVERY LOCATION** 

**CLOSING DATE** : 29.12.2023

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ANNUAL MAINTENANCE CONTRACT (AMC) WHICH SHALLINCLU DE- QUARTERLY BASIS (4 TIMES) PLANNED PREVENTIVE MAINTENANCE/SERVICING ANDINSPECTION UNLIMITED 24/7 EMERGENCY CALL RESPONSE FOR FA ULT ATTENDING/BREAKDOWNMAINTENANCE FIRE SYSTEMS SHALL COVER FIRE ALARM SYSTEM, FIRE FIGHTING SYSTEM, FIREPUMPS, SPRINKLER SYSTEMS, FIRE HOSE REELS, LANDING VALVES, BREECHINGINLETS AND FIRE EXTINGUISHERS (INSPECTION ANDVALIDATION OF FIRE EXTINGUISHERS ON QUARTERL Y BASIS), FM200 SYSTEM- EMERGENCY EXIT/LIGHT SYSTEM AND ASSOCIATED ACCESSORIES.CONTACT PERSON:- RAM KUMAR RAVI (0559566720) (RAM.RA VI@DEWA.GOV.AE)						
3		ITEM-00001	FIRE PROTECTION SYSTEM (FPS) AMC FOR 33 KV SUBSTATION SOLRPLNT#FIRE PROTECTION SYSTEM ANNUAL MAINTENANCE CONTRACT (AMC) WHICH SHALLI	1	EA				





**RFQ NUMBER** : 2332302767

**DATE** : 15.12.2023 **REQ No** : 1032304659

**REQ TITLE** : AMC for Fire Protection Syste

**DELIVERY LOCATION** 

**CLOSING DATE** : 29.12.2023

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NCLUDE- QUARTERLY BASIS (4 TIMES) PLANNED PREVENTIVE MAINTENANCE/SERVICING ANDINSPECTION UNLIMITED 24/7 EMERGENCY CALL RESPONSE FO R FAULT ATTENDING/BREAKDOWNMAINTENANCEFIRE SYSTEMS SHALL COVER FIRE ALARM SYSTEM, FIRE FIGHTING SYSTEM, FIREPUMPS, SPRINKLER SYST EMS, FIRE HOSE REELS, LANDING VALVES, BREECHINGINLETS AND FIRE EXTINGUISHERS (INSPECTION ANDVALIDATION OF FIRE EXTINGUISHERS ON QUAR TERLY BASIS), FM200 SYSTEM- EMERGENCY EXIT/LIGHT SYSTEM AND ASSOCIATED ACCESSORIES.CONTACT PERSON: RAM KUMAR RAVI (0559566720) (RAM.RAVI@DEWA.GOV.AE)						
4		ITEM-00001	FIRE PROTECTION SYSTEM (FPS) AMC FOR 33 KV SUBSTATION SHYSLAM#FIRE PROTECTION SYSTEM ANNUAL MAINTENANCE CONTRACT (AMC) WHICH SHALLIN CLUDE- QUARTERLY BASIS (4 TIMES) PLANNED PREVENTIVE MAINTENANCE/SERVICING	1	EA				





**RFQ NUMBER** : 2332302767

**DATE** : 15.12.2023 **REQ No** : 1032304659

**REQ TITLE** : AMC for Fire Protection Syste

**DELIVERY LOCATION** 

**CLOSING DATE** : 29.12.2023

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ANDINSPECTION UNLIMITED 24/7 EMERGENCY CALL RESPONSE FOR FAULT ATTENDING/BREAKDOWNMAINTENANCE FIRE SYSTEMS SHALL COVER FIRE ALARM SYSTEM, FIRE FIGHTING SYSTEM, FIREPUMPS, SPRINKLER SYSTE MS, FIRE HOSE REELS, LANDING VALVES, BREECHINGINLETS AND FIRE EXTINGUISHERS (INSPECTION ANDVALIDATION OF FIRE EXTINGUISHERS ON QUART ERLY BASIS), FM200 SYSTEM- EMERGENCY EXIT/LIGHT SYSTEM AND ASSOCIATED ACCESSORIES.CONTACT PERSON:- RAM KUMAR RAVI (0559566720) (RAM .RAVI @ DEWA.GOV.AE)						
5		ITEM-00001	FIRE PROTECTION SYSTEM (FPS) AMC FOR 33 KV SUBSTATION TAWILHBB#FIRE PROTECTION SYSTEM ANNUAL MAINTENANCE CONTRACT (AMC) WHICH SHALLI NCLUDE- QUARTERLY BASIS (4 TIMES) PLANNED PREVENTIVE MAINTENANCE/SERVICING ANDINSPECTION UNLIMITED 24/7 EMERGENCY CALL RESPONSE FO	1	EA				





**RFQ NUMBER** : 2332302767

**DATE** : 15.12.2023 **REQ No** : 1032304659

**REQ TITLE** : AMC for Fire Protection Syste

**DELIVERY LOCATION** 

**CLOSING DATE** : 29.12.2023

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			R FAULT ATTENDING/BREAKDOWNMAINTENANCE FIRE SYSTEMS SHALL COVER FIRE ALARM SYSTEM, FIRE FIGHTING SYSTEM, FIREPUMPS, SPRINKLER SYST EMS, FIRE HOSE REELS, LANDING VALVES, BREECHINGINLETS AND FIRE EXTINGUISHERS (INSPECTION ANDVALIDATION OF FIRE EXTINGUISHERS ON QUAR TERLY BASIS), FM200 SYSTEM- EMERGENCY EXIT/LIGHT SYSTEM AND ASSOCIATED ACCESSORIES.CONTACT PERSON: - RAM KUMAR RAVI (0559566720) (RA M.RAVI@DEWA.GOV.AE)						
6		ITEM-00001	FIRE PROTECTION SYSTEM (FPS) AMC FOR 33 KV SUBSTATION MARMOOM#FIRE PROTECTION SYSTEM ANNUAL MAINTENANCE CONTRACT (AMC) WHICH SHALLIN CLUDE- QUARTERLY BASIS (4 TIMES) PLANNED PREVENTIVE MAINTENANCE/SERVICING ANDINSPECTION UNLIMITED 24/7 EMERGENCY CALL RESPONSE FOR FAULT ATTENDING/BREAKDOWNMAINTENANCEFIRE SYSTEMS SHALL COVER FIRE ALARM	1	EA				





**RFQ NUMBER** : 2332302767

**DATE** : 15.12.2023 **REQ No** : 1032304659

**REQ TITLE** : AMC for Fire Protection Syste

**DELIVERY LOCATION** 

**CLOSING DATE** : 29.12.2023

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SYSTEM, FIRE FIGHTING SYSTEM, FIREPUMPS, SPRINKLER SYSTE MS, FIRE HOSE REELS, LANDING VALVES, BREECHINGINLETS AND FIRE EXTINGUISHERS (INSPECTION ANDVALIDATION OF FIRE EXTINGUISHERS ON QUART ERLY BASIS), FM200 SYSTEM- EMERGENCY EXIT/LIGHT SYSTEM AND ASSOCIATED ACCESSORIES.CONTACT PERSON: RAM KUMAR RAVI (0559566720) (RAM .RAVI@DEWA.GOV.AE)						
7		ITEM-00001	FIRE PROTECTION SYSTEM (FPS) AMC FOR 33 KV SUBSTATION LHBRD#FIRE PROTECTION SYSTEM ANNUAL MAINTENANCE CONTRACT (AMC) WHICH SHALLINCL UDE- QUARTERLY BASIS (4 TIMES) PLANNED PREVENTIVE MAINTENANCE/SERVICING ANDINSPECTION UNLIMITED 24/7 EMERGENCY CALL RESPONSE FOR F AULT ATTENDING/BREAKDOWNMAINTENANCEFIRE SYSTEMS SHALL COVER FIRE ALARM SYSTEM, FIRE FIGHTING SYSTEM, FIREPUMPS, SPRINKLER SYSTEMS	1	EA				





**RFQ NUMBER** : 2332302767

**DATE** : 15.12.2023 **REQ No** : 1032304659

**REQ TITLE** : AMC for Fire Protection Syste

**DELIVERY LOCATION** 

**CLOSING DATE** : 29.12.2023

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			, FIRE HOSE REELS, LANDING VALVES, BREECHINGINLETS AND FIRE EXTINGUISHERS (INSPECTION ANDVALIDATION OF FIRE EXTINGUISHERS ON QUARTER LY BASIS), FM200 SYSTEM- EMERGENCY EXIT/LIGHT SYSTEM AND ASSOCIATED ACCESSORIES.CONTACT PERSON: - RAM KUMAR RAVI (0559566720) (RAM.R AVI@DEWA.GOV.AE)						

TOTAL AMOUNT IN WORDS: TOTAL AMOUNT:

#### **SPECIAL NOTES / INSTRUCTIONS:**

AMC for Fire Protection Systems. For 33 KV Substations (2023-24)

Contact Person :- Ram Kumar Ravi (+971 55 956 6720)

#### **STANDARD TERMS & CONDITIONS**

1) Prices should be 'DDP' delivery duty paid at DEWA stores.





**RFQ NUMBER** : 2332302767

**DATE** : 15.12.2023 **REQ No** : 1032304659

**REQ TITLE** : AMC for Fire Protection Syste

**DELIVERY LOCATION** 

**CLOSING DATE** : 29.12.2023

CLOSING TIME : 10:00:00

- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS:

SUPPLIER'S SIGNATURE AND STAMP