

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400594
DATE : 29.02.2024
REQ No : 1032400725
REQ TITLE : 1032400725 SITC DELUGE
DELIVERY LOCATION
CLOSING DATE : 06.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	#SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF DELUGE VALVEASSEMBLY INCLUDING REMOVAL OF EXISTING AND ASSOCIATED WORKS AT JFZS4 00KV DEWA SUBSTATION1.#SCOPE OF WORK##### THE SCOPE OF WORKS COVERS BUT NOT LIMITED TO THE FOLLOWING:CURRENT MODEL DETAILS.SL#DES CRIPTION#EXISTING DELUGE VALVE MAKE#MODEL#DELUGE SIZE#1.##ICT-1#FLUID #FX#6 INCH#2.##ICT-2#FLUID #FX#6 INCH#3.##ICT-3#FLUID #FX#6 INCH#4.##ICT-4#FLUID #FX#6 INCH#5.##400 KV BASEMENT-1#FLUID #FX#6 INCH#6.##132 KV BASEMENT-1#FLUID #FX#6 INCH#7.##400 KV BASEMENT-2#FLUID #FX#6 INCH#8.##132 KV BASEMENT-2#FLUID #FX#6 INCH#.#NEW DELUGE VALVE WITH TRIM ASSEMBLY SHALL BE DEWA-TP APPROVED MODEL,RELIABLE DDX MAKE ONLY. REFER TABLE ABOVE FOR AREA AND SIZE.#EXISTING WET PILOT LINE TO BE RETAINED.#NECESSARY MODIFICATIONS IN	8	EA				

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400594
DATE : 29.02.2024
REQ No : 1032400725
REQ TITLE : 1032400725 SITC DELUGE
DELIVERY LOCATION
CLOSING DATE : 06.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MANIFOLD A S REQUIRED BY SITE CONDITION.#INTERFACING AND TESTING OF NEW DELUGE PRESSURE SWITCHES WITH EXISTINGFIRE ALARM CONTROL PANEL / SCADA .#ALL ASSOCIATED CIVIL AND ELECTRICAL WORKS REQUIRED FOR THE JOB.#ALL MANIFOLDS TO BE PAINTED INCLUDING RISER PIPE.#DELUGE RESETT ING PROCEDURE (ANODIZED ALUMINIUM PLATE) SHALL BE FIXEDNEAR ALL MANIFOLDS.#ANY DELUGE VALVE IDENTIFICATION PLATE MISSING TO BE PROV IDED.#EXISTING DELUGE ISOLATION VALVE WITH TRIM TO BE REPLACED WITH NEWDEWA-TP APPROVED MODELS.#NEW SUPERVISORY SWITCH TO BE PROVID ED FOR EXISTING ONES AT SITE., IFAVAILABLE AT SITE.#PROVISION OF NEW SUPERVISORY SWITCH, ADDITIONAL FIRE ALARM MODULE ANDASSOCIATE F IRE ALARM PROGRAMMING ARE NOT PART OF THE SCOPE.#NEW PRV AND ARV SHALL BE PROVIDED</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400594
DATE : 29.02.2024
REQ No : 1032400725
REQ TITLE : 1032400725 SITC DELUGE
DELIVERY LOCATION
CLOSING DATE : 06.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>IN ALL MANIFOLDS WITH DEDICATED ISOLATION VALVES. #ALL SCRAP MATERIALS TO BE SHIFTED TO DEWA RUWAIYYAH SCRAPYARD, AS PER DEWA INSTRUCTION.#ISOLATION OF FIRE PROTECTION SHALL BE MINIMAL. PRE-FABRICATED PIPING ASSEMBLIES SHALL BE USED WHEREVER POSSIBLE.#HYDROSTATIC PRESSURE TEST TO BE PERFORMED FOR REPLACED ITEMS, WHEREVER APPLICABLE.#SUCCESSFUL DISCHARGE TEST TO BE PERFORMED FOR FINAL ACCEPTANCE.#AS BUILT DRAWINGS, O&M MANUALS AND TEST REPORTS SHALL BE PROVIDED AS PER DEWA REQUIREMENTS.#ALL TOOLS, LIFTING EQUIPMENT#S, SCAFFOLDING, LADDERS AND TESTING EQUIPMENTS REQUIRED FOR THE JOB IS CONTRACTOR SCOPE.#ADDITIONAL CABLING WORKS WHEREVER REQUIRED.#CONTRACTOR MUST FOLLOW DEWA OUTAGE SCHEDULES WHEREVER APPLICABLE, DURING THE EXECUTION OF</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400594
DATE : 29.02.2024
REQ No : 1032400725
REQ TITLE : 1032400725 SITC DELUGE
DELIVERY LOCATION
CLOSING DATE : 06.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>JOB.#CONTRACTOR MUST FOLLOW ALL DEWA SAFETY RULES AND FORMALITIES DURINGTHE EXECUTION OF THE JOB. #CONTRACTOR SHALL ACCEPT FULL RESPONSIBILITY FOR ANY DAMAGE THAT MAYBE CAUSED TO ANY PLANTS DUE TO NEGLIGENCE.#POWER SUPPLY AND WATER REQUIRED FOR THE WORK WILL BE PROVIDED BYDEWA.#WARRANTY OF TWO YEAR FOR THE ENTIRE JOB, FROM THE DATE OF FINALACCEPTANCE.2.#SPECIFICATION2.1 DELUGE VALVE SETS SHALL INCLUDE:-#STOP VALVE OF APPROVED CONSTRUCTION WITH AN INDICATOR SHOWING "OPEN"AND "CLOSED" POSITIONS, COMPLETE WITH PADLOCKED SECURING STRAPS. THEVALVE SHALL BE MOUNTED ON THE INCOMING SIDE OF THE ALARM OR DELUGEVALVE. ALL VALVES SHALL BE FLANGED OS & Y AND RESILIENT SEATED TYPE. ALLVALVES SHALL BE EASILY ACCESSIBLE OR PROVIDE PERMANENT PLATFORM FOROPERA</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400594
DATE : 29.02.2024
REQ No : 1032400725
REQ TITLE : 1032400725 SITC DELUGE
DELIVERY LOCATION
CLOSING DATE : 06.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TION AND MAINTENANCE PURPOSE.#ALL SUCH VALVES AND VALVE SEATS SHALL BE LEAK TIGHT UNDER ALLPRESSURE UP TO THE TEST PRESSURE OF THE SYSTEM. EACH CONTROL VALVESTATION SHALL BE PROVIDED WITH INDIVIDUAL MECHANICAL ALARM. ADEQUATETESTING ARRANGEMENT SHALL BE PROVIDED WITHOUT SPRAY THE FIREWATER TOHAZARD.#EACH PRESSURE (ALARM) SWITCH SHALL HAVE TWO SEPARATE OPERATINGSWITCHES. RANGE OF ALARM PRESSURE SWITCHES SHALL BE 0 ~ 20 PSI (FACTORYSET).#DIAL PRESSURE GAUGES (WITH ANTI-VIBRATION FLUID), WEATHER PROOF, 4INCH DIAL, SS BODY, ARRANGED TO MONITOR THE WATER PRESSURES ABOVE ANDBELOW THE DELUGE VALVE SET THAT MEANS EACH DELUGE VALVE SHOULD HAVE TWODIAL PRESSURE GAUGES. EACH GAUGE SHALL BE PROVIDED WITH A THREE-WAYISOLATING VALVE SO THAT IT CAN BE EASILY ISOLATED AND REMOVED</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400594
DATE : 29.02.2024
REQ No : 1032400725
REQ TITLE : 1032400725 SITC DELUGE
DELIVERY LOCATION
CLOSING DATE : 06.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FOR TESTING AND CHECKING WITHOUT SHUTTING DOWN THE WATER SUPPLY. #ARRANGEMENT SHOULD BE PROVIDED FOR TESTING THE OPERATION OF WATER-MOTOR-ALARM WHILE KEEPING DELUGE ISOLATION VALVE CLOSED. #MANUAL RELEASE DEVICES (BOX TYPE) SHALL BE PROVIDED FOR ALL DELUGE VALVES. SUCH DEVICES SHALL BE CONTROLLED FROM READILY ACCESSIBLE LOCATIONS IN THE EVENT OF FIRE. CONTROL SHALL BE MECHANICAL. MANUAL RELEASE DEVICES ARE TO BE FITTED WITH A WIRE SEAL. #PROVIDE LABELS/MARKING TO EACH DRAIN VALVE, TRIM COMPONENTS WITH RESPECTIVE TRANSFORMERS. #DELUGE VALVE TO BE RED IN COLOR. #NEW ALARM GONG AND MANUAL RELEASE BOX TO BE PROVIDED. PIPES AND FITTINGS: STANDARD WEIGHT STEEL PIPE ASTM A53, SEAMLESS, SCHEDULE-40, FACTORY GALVANIZED. #ALL THE PIPING OF SIZE 2" DIA & BELOW SHALL BE</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400594
DATE : 29.02.2024
REQ No : 1032400725
REQ TITLE : 1032400725 SITC DELUGE
DELIVERY LOCATION
CLOSING DATE : 06.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THREADED TYPE & MILLGALVANIZED, AND 2.5" DIA& AB OVE SHALL BE HOP DIP GALVANIZED AFTERFABRICATION & WELDING.ALL FITTINGS AND FIXTURES FOR PIPE WORK SHALL BE OF SEAMLESS CARBONSTEEL SCHEDULE 40, HOT DIPPED GALVANIZED AND PAINTED TO COLOR RED.USE OF WELDED JOINTS WITH GALVANIZED STEEL PIPES NOT ACCEPTABLE.DEWA TP APPROVED PIPES AND FITTINGS. PAINTINGALL SURFACES OF PIPES AND FITTINGS SHOULD BE CLEAN, DRY AND FREE FROMCONTAMINATIONPAINTING SHALL BE DONE AS PER PAINT MANUFACTURER#S SPECIFICATION. TWOCOAT OF RED OXIDE AND TWO COAT OF GLOSS RED PAINT BY MIXING WITH PROPERRATIO OF BASE AND CURING AGENT WITH THINNER. EXPOSED PIPE WORK SHALLADDITIONALLY BE PAINTED ONE COAT GLOSS RED.SPECIFICATION AND METHOD S TATEMENT FROM PAINT MANUFACTURER SHALL</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400594
DATE : 29.02.2024
REQ No : 1032400725
REQ TITLE : 1032400725 SITC DELUGE
DELIVERY LOCATION
CLOSING DATE : 06.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BESUBMITTED FOR DEWA APPROVAL FLUSHINGALL PIPE WORKS INSTALLED UNDER THIS CONTRACT SHALL BE THOROUGHLY FLUSHEDWITH WATER IN ORDER TO REMOVE FOREIGN MATER.GENERALTHE CONTRACTOR SHALL SUBMIT TECHNICAL OFFER WITH FULL DETAILED WORKINGPROGRAM TO EXECUTE THIS JOB. THE CONTRACTOR MUST COMPLETE THE EXECUTIONOF THE PROJECT WITH 6 MONTHS PERIOD. THIS WORK PLAN P ROGRAM SHALLINCLUDE BUT NOT LIMITED TO THE FOLLOWINGS:O#MATERIAL SUBMITTALSO#INSTALLATIONO#COMMISSIONING DATEO#SYSTEM HAND OVER DATE FOR SITE VISIT AND ENTRY PERMIT, CONTACT THE FOLLOWING ENGINEERS1. SHERIEF C HAMZA [MOB:0529219010]2. USMAN ARSHAD [MOB:0561721269]</p>						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

SITC DELUGE VALVE ASSEMBLY

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400594
DATE : 29.02.2024
REQ No : 1032400725
REQ TITLE : 1032400725 SITC DELUGE
DELIVERY LOCATION
CLOSING DATE : 06.03.2024
CLOSING TIME : 10:00:00

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP