

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400640
DATE : 06.03.2024
REQ No : 1032400898
REQ TITLE : External Cleaning & Coating o
DELIVERY LOCATION
CLOSING DATE : 18.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	EXTERNAL CLEANING & COATING OF DN2400, DN2100, DN1200 VALVES & DN900 CONNECTIONS TO CONDENSER AT PRESSURE CULVERT D STN PH2 TOTAL QUANTITY : ##DN 2400 VALVES : 2 NOS ##DN 2100 VALVES : 4 NOS ##DN 1200 VALVES : 1 NO ##DN 900 RISERS : 6 NOS ##DN 600 MANHOLES : 8 NO SCOPE OF WORK : 1. #PREPARE EXTERNAL SURFACE OF VALVES FOR COATING BY ANY SUITABLE METHOD (HIGH PRESSURE HYDROJET / SAND BLASTING / SPONGE BLASTING) ETC. 2. #AFTER PREPARATION OF SURFACE APPLY UNDERCOAT. 3. #APPLY SUITABLE ANTI CORROSION COATING WHICH CAN HANDLE HARSH ENVIRONMENT CONDITIONS, CORROSIVE ENVIRONMENTS. 4. #COATING TO BE ABOVE 500 MICRONS. 5. #REMOVE AVAILABLE WRAPPING ON DN 900 CONNECTIONS TO RISERS. 6. #PREPARE SURFACE & APPLY UNDERCOAT & COATING UPTO 500 MICRONS. 7. #RISERS TO BE WRAPPED AGAIN AS PER ORIGINAL WRAPPING	2	EA				

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400640
DATE : 06.03.2024
REQ No : 1032400898
REQ TITLE : External Cleaning & Coating o
DELIVERY LOCATION
CLOSING DATE : 18.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			(COROPLAST 91 2ALUMINIUM BANDS WIDTH.150 MM LONG.50 M / POLYKEN 943.30 ANTICORROSIONBANDS WIDTH.100 MM LONG.31 M /POLYKEN 954.15 MECHANICAL PROTEC TION BANDSWIDTH.100 MM LONG.31 M)8.#ALL PRESSURE CULVERT MANHOLES TO BE INTERNALLY CLEANED & RECOATEDWITH CERAMIC COATING & IF ORIGI NAL FOUND DAMAGED BOONNA FEASIBLE COATINGALSO TO BE APPLIED.9.#IT IS CONTRACTOR#S RESPONSIBILITY FOR MAKING SITE READY FOR BLASTINGW ITH PROPER COVERING WITHOUT DISTURBING OTHER EQUIPMENT.10.#WARRANTY OF 5 YEARS TO BE PROVIDED AGAINST COATING.11.#HOUSEKEEPING OF SI TE TO BE DONE ON DAILY BASIS.12.#IF SAND BLASTING OR SPONGE BLASTING IS DONE DISPOSABLE ISCONTRACTOR#S RESPONSIBILITY.13.#SCALES TO BE DISPOSED TO DEWA YARD BY CONTRACTOR.14.#WORK TO BE CARRIED OUT						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400640
DATE : 06.03.2024
REQ No : 1032400898
REQ TITLE : External Cleaning & Coating o
DELIVERY LOCATION
CLOSING DATE : 18.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DURING PH2 TOTAL OUTAGE BETWEEN 3RD APRIL2024 TILL 30TH APRIL 2024 .NOTE: BIDDERS ARE REQUESTED TO VISIT THE SITE TO EVALUATE AND ACCESSCLEAR SCOPE AND QUANTUM OF WORK ,NO ADDITIONAL COST WILL BE ACC EPTABLEAFTER PO ISSUANCE##CONTACT PERSON: RAFIQUE / RAFIQUE@DEWA.GOV.AE / 056-7013425 /04-32-26172						
2		ITEM-00001	EXTERNAL CLEANING & COATING OF DN2400, DN2100,DN1200 VALVES & DN900CONNECTIONS TO CONDENSER AT PRESSURE CULVERT D STN PH2TOTAL QUAN TITY :##DN 2400 VALVES : 2 NOS##DN 2100 VALVES : 4 NOS##DN 1200 VALVES : 1 NO##DN 900 RISERS : 6 NOS##DN 600 MANHOLES : 8 NOSSCOPE OF WORK :1.#PREPARE EXTERNAL SURFACE OF VALVES FOR COATING BY ANY SUITABLEMETHOD (HIGH PRESSURE HYDROJET / SAND BLASTING/ SPONGE BLA STING) ETC.2.#AFTER PREPARATION OF SURFACE APPLY UNDERCOAT.3.#APPLY SUITABLE ANTI	4	EA				

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400640
DATE : 06.03.2024
REQ No : 1032400898
REQ TITLE : External Cleaning & Coating o
DELIVERY LOCATION
CLOSING DATE : 18.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CORROSION COATING WHICH CAN HANDLE HARSH ENVIRONMENT CONDITIONS, CORROSIVE ENVIRONMENTS.4.#COATING TO BE ABOVE 500MICRONS.5.#REMOVE AVAILABLE WRAPPING ON DN 900 CONNECTIONS TO RISERS .6.#PREPARE SURFACE & APPLY UNDERCOAT & COATING UPTO 500MICRONS.7.#RISERS TO BE WRAPPED AGAIN AS PER ORIGINAL WRAPPING (COROPLAST 91</p> <p>2ALUMINIUM BANDS WIDTH.150 MM LONG.50 M / POLYKEN 943.30 ANTICORROSIONBANDS WIDTH.100 MM LONG.31 M /POLYKEN 954.15 MECHANICAL PROTECTION BANDSWIDTH.100 MM LONG.31 M)8.#ALL PRESSURE CULVERT MANHOLES TO BE INTERNALLY CLEANED & RECOATEDWITH CERAMIC COATING & IF ORIGINAL FOUND DAMAGED BOONNA FEASIBLE COATINGALSO TO BE APPLIED.9.#IT IS CONTRACTOR#S RESPONSIBILITY FOR MAKING SITE READY FOR BLASTING WITH PROPER COVERING WITHOUT DISTURBING</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400640
DATE : 06.03.2024
REQ No : 1032400898
REQ TITLE : External Cleaning & Coating o
DELIVERY LOCATION
CLOSING DATE : 18.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OTHER EQUIPMENT.10.#WARRANTY OF 5 YEARS TO BE PROVIDED AGAINST COATING.11.#HOUSEKEEPING OF SITE TO BE DONE ON DAILY BASIS.12.#IF SAND BLASTING OR SPONGE BLASTING IS DONE DISPOSABLE ISCONTRACTOR#S RESPONSIBILITY.13.#SCALES TO BE DISPOSED TO DEWA YARD BY CONTRACTOR.14.#WORK TO BE CARRIED OUT DURING PH2 TOTAL OUTAGE BETWEEN 3RD APRIL2024 TILL 30TH APRIL 2024 .NOTE: BIDDERS ARE REQUESTED TO VISIT THE SITE TO EVALUATE AND ACCESSCLEAR SCOPE AND QUANTUM OF WORK ,NO ADDITIONAL COST WILL BE ACC EPTABLEAFTER PO ISSUANCE##CONTACT PERSON: RAFIQUE / RAFIQUE@DEWA.GOV.AE / 056-7013425 /04-32-26172						
3		ITEM-00001	EXTERNAL CLEANING & COATING OF DN2400, DN2100,DN1200 VALVES & DN900CONNECTIONS TO CONDENSER AT PRESSURE CULVERT D STN PH2TOTAL QUANTITY :##DN 2400 VALVES : 2 NOS##DN 2100	1	EA				

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400640
DATE : 06.03.2024
REQ No : 1032400898
REQ TITLE : External Cleaning & Coating o
DELIVERY LOCATION
CLOSING DATE : 18.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>VALVES : 4 NOS##DN 1200 VALVES : 1 NO##DN 900 RISERS : 6 NOS##DN 600 MANHOLES : 8 NOSSCOPE</p> <p>OF WORK :1.#PREPARE EXTERNAL SURFACE OF VALVES FOR COATING BY ANY SUITABLEMETHOD (HIGH PRESSURE HYDROJET / SAND BLASTING/ SPONGE BLASTING) ETC.2.#AFTER PREPARATION OF SURFACE APPLY UNDERCOAT.3.#APPLY SUITABLE ANTI CORROSION COATING WHICH CAN HANDLE HARSHENVIRONMENTS CONDITIONS, CORROSIVE ENVIRONMENTS.4.#COATING TO BE ABOVE 500MICRONS.5.#REMOVE AVAILABLE WRAPPING ON DN 900 CONNECTIONS TO RISERS .6.#PREPARE SURFACE & APPLY UNDERCOAT & COATING UPTO 500MICRONS.7.#RISERS TO BE WRAPPED AGAIN AS PER ORIGINAL WRAPPING (COROPLAST 91</p> <p>2ALUMINIUM BANDS WIDTH.150 MM LONG.50 M / POLYKEN 943.30 ANTICORROSIONBANDS WIDTH.100 MM LONG.31 M /POLYKEN 954.15 MECHANICAL PROTEC</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400640
DATE : 06.03.2024
REQ No : 1032400898
REQ TITLE : External Cleaning & Coating o
DELIVERY LOCATION
CLOSING DATE : 18.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TION BANDSWIDTH.100 MM LONG.31 M)8.#ALL PRESSURE CULVERT MANHOLES TO BE INTERNALLY CLEANED & RECOATEDWITH CERAMIC COATING & IF ORIGI NAL FOUND DAMAGED BOONNA FEASIBLE COATINGALSO TO BE APPLIED.9.#IT IS CONTRACTOR#S RESPONSIBILITY FOR MAKING SITE READY FOR BLASTINGW ITH PROPER COVERING WITHOUT DISTURBING OTHER EQUIPMENT.10.#WARRANTY OF 5 YEARS TO BE PROVIDED AGAINST COATING.11.#HOUSEKEEPING OF SI TE TO BE DONE ON DAILY BASIS.12.#IF SAND BLASTING OR SPONGE BLASTING IS DONE DISPOSABLE ISCONTRACTOR#S RESPONSIBILITY.13.#SCALES TO BE DISPOSED TO DEWA YARD BY CONTRACTOR.14.#WORK TO BE CARRIED OUT DURING PH2 TOTAL OUTAGE BETWEEN 3RD APRIL2024 TILL 30TH APRIL 2024 .NOTE: BIDDERS ARE REQUESTED TO VISIT THE SITE TO EVALUATE AND ACCESSCLEAR SCOPE AND QUANTUM OF WORK ,NO ADDITIONAL COST</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400640
DATE : 06.03.2024
REQ No : 1032400898
REQ TITLE : External Cleaning & Coating o
DELIVERY LOCATION
CLOSING DATE : 18.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WILL BE ACC EPTABLEAFTER PO ISSUANCE##CONTACT PERSON: RAFIQUE / RAFIQUE@DEWA.GOV.AE / 056-7013425 /04-32-26172						
4		ITEM-00001	EXTERNAL CLEANING & COATING OF DN2400, DN2100,DN1200 VALVES & DN900CONNECTIONS TO CONDENSER AT PRESSURE CULVERT D STN PH2TOTAL QUAN TITY :##DN 2400 VALVES : 2 NOS##DN 2100 VALVES : 4 NOS##DN 1200 VALVES : 1 NO##DN 900 RISERS : 6 NOS##DN 600 MANHOLES : 8 NOSSCOPE OF WORK :1.#PREPARE EXTERNAL SURFACE OF VALVES FOR COATING BY ANY SUITABLEMETHOD (HIGH PRESSURE HYDROJET / SAND BLASTING/ SPONGE BLA STING) ETC.2.#AFTER PREPARATION OF SURFACE APPLY UNDERCOAT.3.#APPLY SUITABLE ANTI CORROSION COATING WHICH CAN HANDLE HARSHENVIRONMEN T CONDITIONS, CORROSIVE ENVIRONMENTS.4.#COATING TO BE ABOVE 500MICRONS.5.#REMOVE AVAILABLE WRAPPING	6	EA				

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400640
DATE : 06.03.2024
REQ No : 1032400898
REQ TITLE : External Cleaning & Coating o
DELIVERY LOCATION
CLOSING DATE : 18.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ON DN 900 CONNECTIONS TO RISERS .6.#PREPARE SURFACE & APPLY UNDERCOAT & COATING UPTO 500MICRONS.7.#RISERS TO BE WRAPPED AGAIN AS PER ORIGINAL WRAPPING (COROPLAST 91 2ALUMINIUM BANDS WIDTH.150 MM LONG.50 M / POLYKEN 943.30 ANTICORROSIONBANDS WIDTH.100 MM LONG.31 M /POLYKEN 954.15 MECHANICAL PROTECTION BANDSWIDTH.100 MM LONG.31 M)8.#ALL PRESSURE CULVERT MANHOLES TO BE INTERNALLY CLEANED & RECOATEDWITH CERAMIC COATING & IF ORIGINAL FOUND DAMAGED BOONNA FEASIBLE COATINGALSO TO BE APPLIED.9.#IT IS CONTRACTOR#S RESPONSIBILITY FOR MAKING SITE READY FOR BLASTING WITH PROPER COVERING WITHOUT DISTURBING OTHER EQUIPMENT.10.#WARRANTY OF 5 YEARS TO BE PROVIDED AGAINST COATING.11.#HOUSEKEEPING OF SITE TO BE DONE ON DAILY BASIS.12.#IF SAND BLASTING OR SPONGE BLASTING IS DONE</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400640
DATE : 06.03.2024
REQ No : 1032400898
REQ TITLE : External Cleaning & Coating o
DELIVERY LOCATION
CLOSING DATE : 18.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DISPOSABLE ISCONTRACTOR#S RESPONSIBILITY.13.#SCALES TO BE DISPOSED TO DEWA YARD BY CONTRACTOR.14.#WORK TO BE CARRIED OUT DURING PH2 TOTAL OUTAGE BETWEEN 3RD APRIL2024 TILL 30TH APRIL 2024 .NOTE: BIDDERS ARE REQUESTED TO VISIT THE SITE TO EVALUATE AND ACCESSCLEAR SCOPE AND QUANTUM OF WORK ,NO ADDITIONAL COST WILL BE ACC EPTABLEAFTER PO ISSUANCE##CONTACT PERSON: RAFIQUE / RAFIQUE@DEWA.GOV.AE / 056-7013425 /04-32-26172						
5		ITEM-00001	EXTERNAL CLEANING & COATING OF DN2400, DN2100,DN1200 VALVES & DN900CONNECTIONS TO CONDENSER AT PRESSURE CULVERT D STN PH2TOTAL QUAN TITY :##DN 2400 VALVES : 2 NOS##DN 2100 VALVES : 4 NOS##DN 1200 VALVES : 1 NO##DN 900 RISERS : 6 NOS##DN 600 MANHOLES : 8 NOSSCOPE OF WORK :1.#PREPARE EXTERNAL SURFACE OF VALVES FOR COATING BY ANY SUITABLEMETHOD	8	EA				

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400640
DATE : 06.03.2024
REQ No : 1032400898
REQ TITLE : External Cleaning & Coating o
DELIVERY LOCATION
CLOSING DATE : 18.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			(HIGH PRESSURE HYDROJET / SAND BLASTING/ SPONGE BLASTING) ETC.2.#AFTER PREPARATION OF SURFACE APPLY UNDERCOAT.3.#APPLY SUITABLE ANTI CORROSION COATING WHICH CAN HANDLE HARSH ENVIRONMENT CONDITIONS, CORROSIVE ENVIRONMENTS.4.#COATING TO BE ABOVE 500MICRONS.5.#REMOVE AVAILABLE WRAPPING ON DN 900 CONNECTIONS TO RISERS .6.#PREPARE SURFACE & APPLY UNDERCOAT & COATING UPTO 500MICRONS.7.#RISERS TO BE WRAPPED AGAIN AS PER ORIGINAL WRAPPING (COROPLAST 91 2ALUMINIUM BANDS WIDTH.150 MM LONG.50 M / POLYKEN 943.30 ANTICORROSIONBANDS WIDTH.100 MM LONG.31 M /POLYKEN 954.15 MECHANICAL PROTECTION BANDSWIDTH.100 MM LONG.31 M)8.#ALL PRESSURE CULVERT MANHOLES TO BE INTERNALLY CLEANED & RECOATED WITH CERAMIC COATING & IF ORIGINAL FOUND DAMAGED BOONNA FEASIBLE						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400640
DATE : 06.03.2024
REQ No : 1032400898
REQ TITLE : External Cleaning & Coating o
DELIVERY LOCATION
CLOSING DATE : 18.03.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>COATINGALSO TO BE APPLIED.9.#IT IS CONTRACTOR#S RESPONSIBILITY FOR MAKING SITE READY FOR BLASTING WITH PROPER COVERING WITHOUT DISTURBING OTHER EQUIPMENT.10.#WARRANTY OF 5 YEARS TO BE PROVIDED AGAINST COATING.11.#HOUSEKEEPING OF SITE TO BE DONE ON DAILY BASIS.12.#IF SAND BLASTING OR SPONGE BLASTING IS DONE DISPOSABLE ISCONTRACTOR#S RESPONSIBILITY.13.#SCALES TO BE DISPOSED TO DEWA YARD BY CONTRACTOR.14.#WORK TO BE CARRIED OUT DURING PH2 TOTAL OUTAGE BETWEEN 3RD APRIL2024 TILL 30TH APRIL 2024 .NOTE: BIDDERS ARE REQUESTED TO VISIT THE SITE TO EVALUATE AND ACCESSCLEAR SCOPE AND QUANTUM OF WORK ,NO ADDITIONAL COST WILL BE ACCEPTABLEAFTER PO ISSUANCE##CONTACT PERSON: RAFIQUE / RAFIQUE@DEWA.GOV.AE / 056-7013425 /04-32-26172</p>						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400640
DATE : 06.03.2024
REQ No : 1032400898
REQ TITLE : External Cleaning & Coating o
DELIVERY LOCATION
CLOSING DATE : 18.03.2024
CLOSING TIME : 10:00:00

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

External Cleaning <(>&<)> Coating of DN2400, DN2100, DN1200 valves
<(>&<)> DN900 connections to condenser at Pressure Culvert D Stn Ph2

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP