

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400987
DATE : 23.04.2024
REQ No : 1032401639
REQ TITLE : Service (Ph2 Condenser SW inl
DELIVERY LOCATION
CLOSING DATE : 29.04.2024
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|--|-----|-----|--------------|----------|------------|-------------|
| 1 | | ITEM-00001 | D, PH1 MAIN CONDENSER SEA WATER INLET VALVE SIZE-DN900 REPAIR AND CERAMIC COATING/RUBBER LINING WORK.1. VENDOR SHOULD VISIT SITE BEFORE SUBMITTING OFFER TO ESTIMATE THE WORK AND CONFIRM SCOPE OF WORK.2. COLLECTION OF VALVES FROM SITE.3. DISASSEMBLE VALVE COMPLETELY, CLEAN AND INSPECT EACH ITEM THROUGH VISUAL MEASUREMENT, TESTS ETC. WHATEVER REQUIRED CONFIRMING ITS WORTHINESS TO REUSE.4. INSPECT SEAT AND SEALING AREA OF THE VALVE, DO NECESSARY MACHINING, LAPPING ETC. TO REACH FULL SEALING CONTACT.5. REPLACE ALL CONSUMABLES LIKE O-RING, GLAND SEAL RINGS PACKING'S ETC.6. CHECK THE BEARINGS AND REPLACE WITH NEW.7. CHECK SHAFT (SPINDLE) FOR CORROSION DAMAGE OR PITCHES AND REPAIR. REPLACE THE SPINDLE IN CASE THE DAMAGE IS HEAVY.8. REPLACE PINS AND LOCKING NUTS AS REQUIRED.9. APPLYING | 2 | AU | | | | |

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400987
DATE : 23.04.2024
REQ No : 1032401639
REQ TITLE : Service (Ph2 Condenser SW inl
DELIVERY LOCATION
CLOSING DATE : 29.04.2024
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|---|-----|-----|--------------|----------|------------|-------------|
| | | | <p>CERAMIC COAT ING ON INTERNAL BODY SURFACE AFTER OBTAININGREQUIRED SURFACE FINISH.10. RE-ASSEMBLE THE VALVE.11. ALL METALS TO BE FREE FROM SURFACE OIL AND GREASE, REMOVAL BYHYDROCARBON SOLVENT.12. ALL SURFACES TO BE LINED SHALL BE BLAST CLEANED, IN A WORKPLACESEPARATE FROM PREP ARATION /LINING AREA.13. STANDARD OF BLASTING TO BE SA 2.1/2, AS DEFINED IN THE SWEDISHSTANDARD S.I.S 05 5900.14. REMOVE ALL SURFACE DUST AND RESIDUE BY VACUUMING15. APPLY HOLDING PRIMER WITHIN FOUR HOURS.16. ALL SURFACES TO BE LINED SHALL BE MAINTAINED AT A TEMPE RATURE OF ATLEAST 3 DEGREES C ABOVE DEW POINT.17. THE TESTING OF LINING SHALL BE CARRIED OUT SYSTEMATICALLY, BEFOREAND AFTER CURING. 18. INSPECTION SHALL BE CARRIED OUT ACCORDINGLY TO THE</p> | | | | | | |

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400987
DATE : 23.04.2024
REQ No : 1032401639
REQ TITLE : Service (Ph2 Condenser SW inl
DELIVERY LOCATION
CLOSING DATE : 29.04.2024
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|---|-----|-----|--------------|----------|------------|-------------|
| | | | CUSTOMER#SSATISFACTION, AND TEST CERTIFICATES ISSUED ON COMPLETION OF THE FIN ALSPARK TEST AFTER CURING.19. CARRY OUT FULL INSPECTION OF THE RUBBER LININGS AND REPAIR BY SAMEPROCEDURE IF ANY DEFECT.20. DELIVER TO SITE BY SAFE & STANDARD PACKING.CONTACT:HAJI ABDULLAH-0526970925 (HAJI.SHAIK@DEWA.GOV.AE) | | | | | | |

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Service (Ph2 Condenser SW inlet valve (DN900) Repair,ceramic coating /rubber lining work.) Contact:Haji Abdullah-0526970925 (haji.sh aik@dewa.gov.ae)

STANDARD TERMS & CONDITIONS

1) Prices should be 'DDP' delivery duty paid at DEWA stores.

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400987
DATE : 23.04.2024
REQ No : 1032401639
REQ TITLE : Service (Ph2 Condenser SW inl
DELIVERY LOCATION
CLOSING DATE : 29.04.2024
CLOSING TIME : 10:00:00

- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP