

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400999
DATE : 24.04.2024
REQ No : 1032401400
REQ TITLE : 1032401400 VALVE BODY
DELIVERY LOCATION
CLOSING DATE : 07.05.2024
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|---|-----|-----|--------------|----------|------------|-------------|
| 1 | | ITEM-00001 | <p>TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK M STATION, JEBELALI POWER STATION TITLE: M STATION ST LP EXTRACTION CONTROL VALVE BODY SEAT WELD REPAIR AND MACHINING, SIZE: 42 INCH. #QUANTITY & SPECIFICATION: #QUANTITY: 02 NOS. #SIZE: 42 IN. #CLASS: 150. #BODY SEAT MATERIAL: ASTM A216 WCB + THERMANITE 19-15 (SEAT WELD OVERLAY). #TYPE: TRIPLE ECCENTRIC BUTTERFLY VALVE. #REFER ATTACHED VALVE DR</p> <p>AWING. B. #WORK DURATION: #TO BE COMPLETED IN 07 DAYS. #PRE-BID SITE INSPECTION: #THE CONTRACTOR SHALL VISIT THE WORKSHOP AND INSPECT THE VALVE AND BE FULLY FAMILIAR WITH THE WORK SCOPE, BEFORE SUBMITTING THE BID. DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES / PRICES DURING AND AFTER THE EXECUTION OF WORK. #SITE LOCATION: VALVE IS CURRENTLY AVAILABLE AT DEWA #S</p> | 1 | LS | | | | |

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400999
DATE : 24.04.2024
REQ No : 1032401400
REQ TITLE : 1032401400 VALVE BODY
DELIVERY LOCATION
CLOSING DATE : 07.05.2024
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|--|-----|-----|--------------|----------|------------|-------------|
| | | | CONTRACTORWORKSHO P LOCATED IN AL QUSAIS, DUBAI.CONTACT DETAILS FOR SITE VISIT1.#ANTON JACOB0554607122ANTON.JACOB@DEWA.GOV.AE2. #ASHIL PRABHAKAR0585839 585ASHIL.PRABHAKAR@DEWA.GOV.AED.#QUALIFIC ATION OF BIDDER:#THE BIDDER SHALL HAVE PROVEN EXPERIENCE FOR SIMILAR JOBS AND SHALLSUBMIT EVIDENCE.E.#SCOPE OF WORK:#COLLECT THE VALVE & SPARE SEAT RING WITHIN 01 DAY AFTER RECEIVING POFROM DEWA#S CONTRACTOR WORKSHOP LOCA TED IN AL QUSAIS, DUBAI.#CONDUCT INSPECTION OF THE VALVE BODY SEAT AREA USING APPLICABLE NDEMETHODS TO IDENTIFY ALL THE DEFECTS AND SUBMIT REPAIR PROCEDURE TO DEWA.#CARRY OUT WELD REPAIR OF THE BODY SEAT (SEAT MATERIAL IS ASTM A216WCB + THERMANITE 19- 15 (SEAT W ELD OVERLAY).#WELDING IS TO BE DONE BY QUALIFIED WELDER ACCORDING TO APPLICABLE | | | | | | |

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400999
DATE : 24.04.2024
REQ No : 1032401400
REQ TITLE : 1032401400 VALVE BODY
DELIVERY LOCATION
CLOSING DATE : 07.05.2024
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|---|-----|-----|--------------|----------|------------|-------------|
| | | | WPS& ASME REQUIREMENTS.#CONDUCT APPLICABLE NDE (MPI , DPT ETC.) AFTER THE REPAIR WORK.#MACHINE THE BODY SEAT AND MATCH WITH SEAT RING.#CONDUCT APPLICABLE NDE (MPI, DPT ETC.) AFTER MA CHINING WORK.#PROVIDE THE COMPLETE REPORT WITH PHOTOS INCLUDING ALL NDE REPORTS.#AFTER SUCCESSFUL COMPLETION, DELIVER THE VALVE BACK TO DEWA#SCONTRACTOR WORKSHOP LOCATED IN AL QUSAIS, DUBAI FOR FURTHER ASSEMBLINGAND TESTING.NOTE: SCOPE OF WORK MENTIONED HERE ONLY PROVIDES BROAD OUTLINE OF THE TASK. THE BIDDER IS EXPECTED TO REVIEW THE ADEQUACY OF THE PROPOSEDSCOPE OF WORKS TO CARRY OUT REQUIRED TASK AND ADD ANY ADDITIONAL WORKS THAT ARE NEEDED FOR SATISFACTORY COMPLETION OF THIS PROJECT.F.#WARRANTY.#THE WARRANTY PERIOD FOR THE WORK SHALL BE 01 YEAR FROM THE DATE | | | | | | |

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400999
DATE : 24.04.2024
REQ No : 1032401400
REQ TITLE : 1032401400 VALVE BODY
DELIVERY LOCATION
CLOSING DATE : 07.05.2024
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|---|-----|-----|--------------|----------|------------|-------------|
| | | | OF COMPLETION OF WORK CERTIFIED BY DEWA. #IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THIS CONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL CARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN SHORTEST PERIOD. | | | | | | |

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK M STATION, JEBEL ALI POWER STATION FOR ST LP EXTRACTION CONTROL VALVE BODY SEAT WELD REPAIR AND MACHINING, SIZE: 42 INCH, SCOPE OF WORK <(>&<)> VALVE DRAWING ATTACHED

STANDARD TERMS & CONDITIONS

- Prices should be 'DDP' delivery duty paid at DEWA stores.
- Quotation to be submitted only in local currency U.A.E Dirhams

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332400999
DATE : 24.04.2024
REQ No : 1032401400
REQ TITLE : 1032401400 VALVE BODY
DELIVERY LOCATION
CLOSING DATE : 07.05.2024
CLOSING TIME : 10:00:00

- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP