

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332403055
DATE : 27.11.2024
REQ No : 1032405308
REQ TITLE : Overhauling 1032405308
DELIVERY LOCATION
CLOSING DATE : 03.12.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	OVERHAULING OF INDUCTION MOTOR OF DIP PUMPING STATION PHASE-2 AS PER ATTACHED SPECIFICATION TO BE MADE SUITABLE FOR OPERATION WITH VARIABLE FREQUENCY DRIVE. QUANTITY: 8 MOTOR DETAILS: RATED POWER: 290 KW VOLTAGE: 400V, 3-PHASE, 50 HZ RATED CURRENT: 510 A RATED RPM: 993 MOUNTING: HORIZONTAL MODEL: ILA8 355-6AB90-Z MAKE: SIEMENS MOTOR ASSET NO: 50344532 SCOPE OF WORK INCLUDES: 1. PICK UP / DELIVERY OF MOTOR FROM / TO DIP PUMPING STATION PHASE-2. 2. DISMANTLING AND PREPARATION OF INITIAL INSPECTION REPORT. 3. CLEANING. 4. ROTOR TEST AND DY NAMIC BALANCING. 5. STATOR TEST (IR, HI-POT, PARTIAL DISCHARGE). 6. TESTING AND CORRECTION (IF REQUIRED) OF WINDING RTDS, PTCS AND SPA CE HEATER. 6. REPLACEMENT OF DE AND NDE BEARING. NDE BEARING SHALL BE INSULATED AND SUITABLE FOR VFD APPLICATION. 7.	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332403055
DATE : 27.11.2024
REQ No : 1032405308
REQ TITLE : Overhauling 1032405308
DELIVERY LOCATION
CLOSING DATE : 03.12.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INSTALLATION OF SHA FT GROUNDING BUSH IN DE SIDE OF MOTOR FOR VFDAPPLICATION.8. INSTALLATION AND WIRING OF RTD FOR DE SIDE AND NDE SIDE BEARINGS.9. ASSE MBLY OF MOTOR.10. PAINTING OF MOTOR WITH SAME COLOR AS EXISTING.11. FINAL TESTING, INCLUDING VIBRATION LEVEL, TEMPERATURE RISE AND S OUNDLEVEL.12. PREPARATION OF FINAL REPORT.INITIAL INSPECTION AND FINAL INSPECTION SHALL BE WITNESSED BY DEWAENGINEERS.WARRANTY OF SE RVICE SHALL BE 24 MONTHS FROM DATE OF DELIVERY OF THEMOTOR.FOR SITE VISITS OR TECHNICAL CLARIFICATIONS, PLEASE CONTACT VENUGOPAL(VEN UGOPAL.RAMAN@DEWA.GOV.AE, 04-3229452) OR ANNAMALAI(ANNAMALAI@DEWA.GOV.AE, 04-3229430)</p>						
2		ITEM-00001	OVERHAULING OF INDUCTION MOTOR OF DIP PUMPING STATION PHASE-2 AS PERATTACHED SPECIFICATION TO BE MADE SUITABLE FOR	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332403055
DATE : 27.11.2024
REQ No : 1032405308
REQ TITLE : Overhauling 1032405308
DELIVERY LOCATION
CLOSING DATE : 03.12.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OPERATION WITH VA RIABLEFREQUENCY DRIVE.QUANTITY: 8 NOSMOTOR DETAILS:RATED POWER: 290 KWVOLTAGE: 400V, 3-PHASE, 50HZRATED CURRENT: 510 ARATED RPM: 993 MOUNTING: HORIZONTALMODEL: ILA8 355-6AB90-ZMAKE: SIEMENSMOTOR ASSET NO: 50344535SCOPE OF WORK INCLUDES:1. PICK UP / DELIVERY OF MOTO R FROM / TO DIP PUMPING STATION PHASE-2.2. DISMANTLING AND PREPARATION OF INITIAL INSPECTION REPORT.3. CLEANING.4. ROTOR TEST AND DY NAMIC BALANCING.5. STATOR TEST (IR, HI-POT, PARTIAL DISCHARGE).6. TESTING AND CORRECTION (IF REQUIRED) OF WINDING RTDS, PTCS AND SPA CEHEATER.6. REPLACEMENT OF DE AND NDE BEARING. NDE BEARING SHALL BE INSULATED ANDSUITABLE FOR VFD APPLICATION.7. INSTALLATION OF SHA FT GROUNDING BUSH IN DE SIDE OF MOTOR FOR VFDAPPLICATION.8. INSTALLATION AND WIRING OF</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332403055
DATE : 27.11.2024
REQ No : 1032405308
REQ TITLE : Overhauling 1032405308
DELIVERY LOCATION
CLOSING DATE : 03.12.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RTD FOR DE SIDE AND NDE SIDE BEARINGS.9. ASSE MBLY OF MOTOR.10. PAINTING OF MOTOR WITH SAME COLOR AS EXISTING.11. FINAL TESTING, INCLUDING VIBRATION LEVEL, TEMPERATURE RISE AND S OUNDLEVEL.12. PREPARATION OF FINAL REPORT.INITIAL INSPECTION AND FINAL INSPECTION SHALL BE WITNESSED BY DEWAENGINEERS.WARRANTY OF SE RVICE SHALL BE 24 MONTHS FROM DATE OF DELIVERY OF THEMOTOR.FOR SITE VISITS OR TECHNICAL CLARIFICATIONS, PLEASE CONTACT VENUGOPAL(VEN UGOPAL.RAMAN@DEWA.GOV.AE, 04-3229452) OR ANNAMALAI(ANNAMALAI@DEWA.GOV.AE, 04-3229430)						
3		ITEM-00001	OVERHAULING OF INDUCTION MOTOR OF DIP PUMPING STATION PHASE-2 AS PERATTACHED SPECIFICATION TO BE MADE SUITABLE FOR OPERATION WITH VA RIABLEFREQUENCY DRIVE.QUANTITY: 8 NOMOTOR DETAILS:RATED POWER: 290	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332403055
DATE : 27.11.2024
REQ No : 1032405308
REQ TITLE : Overhauling 1032405308
DELIVERY LOCATION
CLOSING DATE : 03.12.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			KWVOLTAGE: 400V, 3-PHASE, 50HZRATED CURRENT: 510 ARATED RPM: 993 MOUNTING: HORIZONTALMODEL: ILA8 355-6AB90-ZMAKE: SIEMENSMOTOR ASSET NO: 50344537SCOPE OF WORK INCLUDES:1. PICK UP / DELIVERY OF MOTO R FROM / TO DIP PUMPING STATION PHASE-2.2. DISMANTLING AND PREPARATION OF INITIAL INSPECTION REPORT.3. CLEANING.4. ROTOR TEST AND DY NAMIC BALANCING.5. STATOR TEST (IR, HI-POT, PARTIAL DISCHARGE).6. TESTING AND CORRECTION (IF REQUIRED) OF WINDING RTDS, PTCS AND SPA CEHEATER.6. REPLACEMENT OF DE AND NDE BEARING. NDE BEARING SHALL BE INSULATED ANDSUITABLE FOR VFD APPLICATION.7. INSTALLATION OF SHA FT GROUNDING BUSH IN DE SIDE OF MOTOR FOR VFDAPPLICATION.8. INSTALLATION AND WIRING OF RTD FOR DE SIDE AND NDE SIDE BEARINGS.9. ASSE MBLY OF MOTOR.10. PAINTING OF MOTOR WITH						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332403055
DATE : 27.11.2024
REQ No : 1032405308
REQ TITLE : Overhauling 1032405308
DELIVERY LOCATION
CLOSING DATE : 03.12.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SAME COLOR AS EXISTING.11. FINAL TESTING, INCLUDING VIBRATION LEVEL, TEMPERATURE RISE AND SOUND LEVEL.12. PREPARATION OF FINAL REPORT.INITIAL INSPECTION AND FINAL INSPECTION SHALL BE WITNESSED BY DEWA ENGINEERS.WARRANTY OF SERVICE SHALL BE 24 MONTHS FROM DATE OF DELIVERY OF THE MOTOR.FOR SITE VISITS OR TECHNICAL CLARIFICATIONS, PLEASE CONTACT VENUGOPAL(VENUGOPAL.RAMAN@DEWA.GOV.AE, 04-3229452) OR ANNAMALAI(ANNAMALAI@DEWA.GOV.AE, 04-3229430)						
4		ITEM-00001	OVERHAULING OF INDUCTION MOTOR OF DIP PUMPING STATION PHASE-2 AS PER ATTACHED SPECIFICATION TO BE MADE SUITABLE FOR OPERATION WITH VARIABLE FREQUENCY DRIVE.QUANTITY: 8 NOS.MOTOR DETAILS:RATED POWER: 290 KW.VOLTAGE: 400V, 3-PHASE, 50 HZ.RATED CURRENT: 510 A.RATED RPM: 993 MOUNTING: HORIZONTAL.MODEL: ILA8	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332403055
DATE : 27.11.2024
REQ No : 1032405308
REQ TITLE : Overhauling 1032405308
DELIVERY LOCATION
CLOSING DATE : 03.12.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			355-6AB90-ZMAKE: SIEMENSMOTOR ASSET NO: 50344539SCOPE OF WORK INCLUDES:1. PICK UP / DELIVERY OF MOTO R FROM / TO DIP PUMPING STATION PHASE-2.2. DISMANTLING AND PREPARATION OF INITIAL INSPECTION REPORT.3. CLEANING.4. ROTOR TEST AND DY NAMIC BALANCING.5. STATOR TEST (IR, HI-POT, PARTIAL DISCHARGE).6. TESTING AND CORRECTION (IF REQUIRED) OF WINDING RTDS, PTCS AND SPA CEHEATER.6. REPLACEMENT OF DE AND NDE BEARING. NDE BEARING SHALL BE INSULATED ANDSUITABLE FOR VFD APPLICATION.7. INSTALLATION OF SHA FT GROUNDING BUSH IN DE SIDE OF MOTOR FOR VFDAPPLICATION.8. INSTALLATION AND WIRING OF RTD FOR DE SIDE AND NDE SIDE BEARINGS.9. ASSE MBLY OF MOTOR.10. PAINTING OF MOTOR WITH SAME COLOR AS EXISTING.11. FINAL TESTING, INCLUDING VIBRATION LEVEL, TEMPERATURE RISE AND S						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332403055
DATE : 27.11.2024
REQ No : 1032405308
REQ TITLE : Overhauling 1032405308
DELIVERY LOCATION
CLOSING DATE : 03.12.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OUNDLEVEL.12. PREPARATION OF FINAL REPORT.INITIAL INSPECTION AND FINAL INSPECTION SHALL BE WITNESSED BY DEWAENGINEERS.WARRANTY OF SERVICE SHALL BE 24 MONTHS FROM DATE OF DELIVERY OF THEMOTOR.FOR SITE VISITS OR TECHNICAL CLARIFICATIONS, PLEASE CONTACT VENUGOPAL(VENUGOPAL.RAMAN@DEWA.GOV.AE, 04-3229452) OR ANNAMALAI(ANNAMALAI@DEWA.GOV.AE, 04-3229430)						
5		ITEM-00001	OVERHAULING OF INDUCTION MOTOR OF DIP PUMPING STATION PHASE-2 AS PERATTACHED SPECIFICATION TO BE MADE SUITABLE FOR OPERATION WITH VARIABLEFREQUENCY DRIVE.QUANTITY: 8 NOSMOTOR DETAILS:RATED POWER: 290 KWWVOLTAGE: 400V, 3-PHASE, 50HZRATED CURRENT: 510 ARATED RPM: 993 MOUNTING: HORIZONTALMODEL: ILA8 355-6AB90-ZMAKE: SIEMENSMOTOR ASSET NO: 50344570SCOPE OF WORK INCLUDES:1. PICK UP / DELIVERY OF MOTO	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332403055
DATE : 27.11.2024
REQ No : 1032405308
REQ TITLE : Overhauling 1032405308
DELIVERY LOCATION
CLOSING DATE : 03.12.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			R FROM / TO DIP PUMPING STATION PHASE-2.2. DISMANTLING AND PREPARATION OF INITIAL INSPECTION REPORT.3. CLEANING.4. ROTOR TEST AND DY NAMIC BALANCING.5. STATOR TEST (IR, HI-POT, PARTIAL DISCHARGE).6. TESTING AND CORRECTION (IF REQUIRED) OF WINDING RTDS, PTCS AND SPA CEHEATER.6. REPLACEMENT OF DE AND NDE BEARING. NDE BEARING SHALL BE INSULATED ANDSUITABLE FOR VFD APPLICATION.7. INSTALLATION OF SHA FT GROUNDING BUSH IN DE SIDE OF MOTOR FOR VFDAPPLICATION.8. INSTALLATION AND WIRING OF RTD FOR DE SIDE AND NDE SIDE BEARINGS.9. ASSE MBLY OF MOTOR.10. PAINTING OF MOTOR WITH SAME COLOR AS EXISTING.11. FINAL TESTING, INCLUDING VIBRATION LEVEL, TEMPERATURE RISE AND S OUNDLEVEL.12. PREPARATION OF FINAL REPORT.INITIAL INSPECTION AND FINAL INSPECTION SHALL BE WITNESSED BY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332403055
DATE : 27.11.2024
REQ No : 1032405308
REQ TITLE : Overhauling 1032405308
DELIVERY LOCATION
CLOSING DATE : 03.12.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DEWAENGINEERS.WARRANTY OF SERVICE SHALL BE 24 MONTHS FROM DATE OF DELIVERY OF THEMOTOR.FOR SITE VISITS OR TECHNICAL CLARIFICATIONS, PLEASE CONTACT VENUGOPAL(VENUGOPAL.RAMAN@DEWA.GOV.AE, 04-3229452) OR ANNAMALAI(ANNAMALAI@DEWA.GOV.AE, 04-3229430)						
6		ITEM-00001	OVERHAULING OF INDUCTION MOTOR OF DIP PUMPING STATION PHASE-2 AS PERATTACHED SPECIFICATION TO BE MADE SUITABLE FOR OPERATION WITH VARIABLEFREQUENCY DRIVE.QUANTITY: 8 NOSMOTOR DETAILS:RATED POWER: 290 KWWVOLTAGE: 400V, 3-PHASE, 50HZRATED CURRENT: 510 ARATED RPM: 993 MOUNTING: HORIZONTALMODEL: ILA8 355-6AB90-ZMAKE: SIEMENSMOTOR ASSET NO: 50344573SCOPE OF WORK INCLUDES:1. PICK UP / DELIVERY OF MOTOR FROM / TO DIP PUMPING STATION PHASE-2.2. DISMANTLING AND PREPARATION OF INITIAL INSPECTION REPORT.3. CLEANING.4. ROTOR TEST	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332403055
DATE : 27.11.2024
REQ No : 1032405308
REQ TITLE : Overhauling 1032405308
DELIVERY LOCATION
CLOSING DATE : 03.12.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AND DY NAMIC BALANCING.5. STATOR TEST (IR, HI-POT, PARTIAL DISCHARGE).6. TESTING AND CORRECTION (IF REQUIRED) OF WINDING RTDS, PTCS AND SPA CEHEATER.6. REPLACEMENT OF DE AND NDE BEARING. NDE BEARING SHALL BE INSULATED ANDSUITABLE FOR VFD APPLICATION.7. INSTALLATION OF SHA FT GROUNDING BUSH IN DE SIDE OF MOTOR FOR VFDAPPLICATION.8. INSTALLATION AND WIRING OF RTD FOR DE SIDE AND NDE SIDE BEARINGS.9. ASSE MBLY OF MOTOR.10. PAINTING OF MOTOR WITH SAME COLOR AS EXISTING.11. FINAL TESTING, INCLUDING VIBRATION LEVEL, TEMPERATURE RISE AND S OUNDLEVEL.12. PREPARATION OF FINAL REPORT.INITIAL INSPECTION AND FINAL INSPECTION SHALL BE WITNESSED BY DEWAENGINEERS.WARRANTY OF SE RVICE SHALL BE 24 MONTHS FROM DATE OF DELIVERY OF THEMOTOR.FOR SITE VISITS OR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332403055
DATE : 27.11.2024
REQ No : 1032405308
REQ TITLE : Overhauling 1032405308
DELIVERY LOCATION
CLOSING DATE : 03.12.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TECHNICAL CLARIFICATIONS, PLEASE CONTACT VENUGOPAL(VENUGOPAL.RAMAN@DEWA.GOV.AE, 04-3229452) OR ANNAMALAI(ANNAMALAI@DEWA.GOV.AE, 04-3229430)						
7		ITEM-00001	OVERHAULING OF INDUCTION MOTOR OF DIP PUMPING STATION PHASE-2 AS PER ATTACHED SPECIFICATION TO BE MADE SUITABLE FOR OPERATION WITH VARIABLE FREQUENCY DRIVE. QUANTITY: 8 MOTOR DETAILS: RATED POWER: 290 KW VOLTAGE: 400V, 3-PHASE, 50 HZ RATED CURRENT: 510 A RATED RPM: 993 MOUNTING: HORIZONTAL MODEL: ILA8 355-6AB90-Z MAKE: SIEMENS MOTOR ASSET NO: 50344577 SCOPE OF WORK INCLUDES: 1. PICK UP / DELIVERY OF MOTOR FROM / TO DIP PUMPING STATION PHASE-2. 2. DISMANTLING AND PREPARATION OF INITIAL INSPECTION REPORT. 3. CLEANING. 4. ROTOR TEST AND DYNAMIC BALANCING. 5. STATOR TEST (IR, HI-POT, PARTIAL DISCHARGE). 6. TESTING AND	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332403055
DATE : 27.11.2024
REQ No : 1032405308
REQ TITLE : Overhauling 1032405308
DELIVERY LOCATION
CLOSING DATE : 03.12.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CORRECTION (IF REQUIRED) OF WINDING RTDS, PTCS AND SPA CEHEATER.6. REPLACEMENT OF DE AND NDE BEARING. NDE BEARING SHALL BE INSULATED ANDSUITABLE FOR VFD APPLICATION.7. INSTALLATION OF SHA FT GROUNDING BUSH IN DE SIDE OF MOTOR FOR VFDAPPLICATION.8. INSTALLATION AND WIRING OF RTD FOR DE SIDE AND NDE SIDE BEARINGS.9. ASSE MBLY OF MOTOR.10. PAINTING OF MOTOR WITH SAME COLOR AS EXISTING.11. FINAL TESTING, INCLUDING VIBRATION LEVEL, TEMPERATURE RISE AND S OUNDLEVEL.12. PREPARATION OF FINAL REPORT.INITIAL INSPECTION AND FINAL INSPECTION SHALL BE WITNESSED BY DEWAENGINEERS.WARRANTY OF SE RVICE SHALL BE 24 MONTHS FROM DATE OF DELIVERY OF THEMOTOR.FOR SITE VISITS OR TECHNICAL CLARIFICATIONS, PLEASE CONTACT VENUGOPAL(VEN UGOPAL.RAMAN@DEWA.GOV.AE, 04-3229452) OR						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332403055
DATE : 27.11.2024
REQ No : 1032405308
REQ TITLE : Overhauling 1032405308
DELIVERY LOCATION
CLOSING DATE : 03.12.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ANNAMALAI(ANNAMALAI@DEWA.GOV.AE, 04-3229430)						
8		ITEM-00001	OVERHAULING OF INDUCTION MOTOR OF DIP PUMPING STATION PHASE-2 AS PERATTACHED SPECIFICATION TO BE MADE SUITABLE FOR OPERATION WITH VARIABLE FREQUENCY DRIVE. QUANTITY: 8 MOTOR DETAILS: RATED POWER: 290 KW VOLTAGE: 400V, 3-PHASE, 50 HZ RATED CURRENT: 510 A RATED RPM: 993 MOUNTING: HORIZONTAL MODEL: ILA8 355-6AB90-Z MAKE: SIEMENS MOTOR ASSET NO: 50344581 SCOPE OF WORK INCLUDES: 1. PICK UP / DELIVERY OF MOTOR FROM / TO DIP PUMPING STATION PHASE-2. 2. DISMANTLING AND PREPARATION OF INITIAL INSPECTION REPORT. 3. CLEANING. 4. ROTOR TEST AND DYE NAMIC BALANCING. 5. STATOR TEST (IR, HI-POT, PARTIAL DISCHARGE). 6. TESTING AND CORRECTION (IF REQUIRED) OF WINDING RTDS, PTCS AND SPA CE HEATER. 6. REPLACEMENT OF DE AND NDE	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332403055
DATE : 27.11.2024
REQ No : 1032405308
REQ TITLE : Overhauling 1032405308
DELIVERY LOCATION
CLOSING DATE : 03.12.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BEARING. NDE BEARING SHALL BE INSULATED AND SUITABLE FOR VFD APPLICATION.7. INSTALLATION OF SHAFT GROUNDING BUSH IN DE SIDE OF MOTOR FOR VFD APPLICATION.8. INSTALLATION AND WIRING OF RTD FOR DE SIDE AND NDE SIDE BEARINGS.9. ASSEMBLY OF MOTOR.10. PAINTING OF MOTOR WITH SAME COLOR AS EXISTING.11. FINAL TESTING, INCLUDING VIBRATION LEVEL, TEMPERATURE RISE AND SOUND LEVEL.12. PREPARATION OF FINAL REPORT. INITIAL INSPECTION AND FINAL INSPECTION SHALL BE WITNESSED BY DEWA ENGINEERS. WARRANTY OF SERVICE SHALL BE 24 MONTHS FROM DATE OF DELIVERY OF THE MOTOR. FOR SITE VISITS OR TECHNICAL CLARIFICATIONS, PLEASE CONTACT VENUGOPAL (VENUGOPAL.RAMAN@DEWA.GOV.AE, 04-3229452) OR ANNAMALAI (ANNAMALAI@DEWA.GOV.AE, 04-3229430)</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332403055
DATE : 27.11.2024
REQ No : 1032405308
REQ TITLE : Overhauling 1032405308
DELIVERY LOCATION
CLOSING DATE : 03.12.2024
CLOSING TIME : 10:00:00

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Overhauling

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP