

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500127  
**DATE** : 14.01.2025  
**REQ No** : 1032500163  
**REQ TITLE** : JAPS L1-STATION SERVICING  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.01.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SERVICING AND TESTING OF HYDRAULIC ACCUMULATOR:SCOPE OVERVIEW:THE OBJECTIVE OF THIS PROJECT IS TO PROCURE THE NECESSARY SERVICES,MAT ERIALS, AND COMPONENTS REQUIRED FOR THE SERVICING AND TESTING OF THEHYDRAULIC ACCUMULATOR. THIS INCLUDES THE LOCAL PURCHASE OF ALL M ATERIALSAND LABOR TO ENSURE THAT THE HYDRAULIC ACCUMULATOR IS FULLY FUNCTIONALAND MEETS SAFETY AND OPERATIONAL STANDARDS.SCOPE OF WO RK:1.#COLLECTION: HYDRAULIC ACCUMULATOR FROM DEWA.2.#INSPECTION AND DISASSEMBLY:PERFORM AN INITIAL INSPECTION OF THE HYDRAULIC ACCUM ULATOR TO ASSESS ITSCURRENT CONDITION.DISASSEMBLE THE ACCUMULATOR FOR INTERNAL INSPECTION, IDENTIFYING WEARAND TEAR OR OTHER SIGNS O F DAMAGE.3.#CLEANING:CLEAN ALL INTERNAL AND EXTERNAL PARTS OF THE HYDRAULIC ACCUMULATOR,INCLUDING THE DIAPHRAGM,	1	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500127  
**DATE** : 14.01.2025  
**REQ No** : 1032500163  
**REQ TITLE** : JAPS L1-STATION SERVICING  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.01.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BLADDER, PISTON, SEALS, AND VALVE COMPONENTS.ENSURE ALL PARTS ARE FREE FROM CONTAMINANTS (DIRT, RUST, DEBRIS) THATCOULD AFFECT FUNCTIONALITY.4.#REPLACEMENT OF WORN OR DAMAGED COMPONENTS:IDENTIFY COMPONENTS THAT REQUIRE REPLACEMENT (SEALS, O-RINGS,DIAPHRAGMS, VALVES, ETC.).PROVIDE AND INSTALL NEW COMPONENTS AS NECESSARY TO RESTORE THEACCUMULATOR TO OPTIMAL CONDITION.5.#REASSEMBLY:REASSEMBLE THE ACCUMULATOR AFTER ALL NECESSARY MAINTENANCE AND PARTREPLACEMENTS HAVE BEEN CARRIED OUT.TESTING OF HYDRAULIC ACCUMULATOR:A.#PRESSURE TESTING:PERFORM A PRESSURE TEST (55 BAR) ON THE HYDRAULIC ACCUMULATOR TO ENSUREIT CAN SAFELY HOLD THE OPERATING PRESSURE WITHOUT ANY LEAKAGE.TEST THE ACCUMULATOR UNDER DIFFERENT LOAD</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500127  
**DATE** : 14.01.2025  
**REQ No** : 1032500163  
**REQ TITLE** : JAPS L1-STATION SERVICING  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.01.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONDITIONS TO CHECK FOR PERFORMANCE AND FUNCTIONALITY. B.#FUNCTIONALITY TEST: TEST THE ACCUMULATOR'S OPERATIONAL RESPONSE TO ENSURE IT IS PERFORMING CORRECTLY UNDER NORMAL SYSTEM CONDITIONS. ENSURE THAT THE ACCUMULATOR EFFECTIVELY ABSORBS, AND RELEASES PRESSURE AS REQUIRED FOR THE SPECIFIC HYDRAULIC SYSTEM. C.#LEAKAGE TEST: CONDUCT A THOROUGH LEAKAGE TEST FOR BOTH INTERNAL AND EXTERNAL AREAS OF THE ACCUMULATOR, ENSURING NO LEAKAGE AT SEALS OR ANY OTHER CRITICAL COMPONENTS. D.#DOCUMENTATION: INSPECTION AND SERVICE REPORT: A COMPREHENSIVE REPORT DOCUMENTING THE FINDINGS DURING THE INSPECTION, ANY REPLACEMENTS MADE, AND THE RESULTS OF THE TESTING. PROVIDE TEST DATA, SUCH AS PRESSURE READINGS AND LEAKAGE RESULTS, TO ENSURE ALL TESTS ARE PERFORMED</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500127  
**DATE** : 14.01.2025  
**REQ No** : 1032500163  
**REQ TITLE** : JAPS L1-STATION SERVICING  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.01.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ACCORDING TO INDUSTRY STANDARDS.SERVICE AND TEST CERTIFICATES:PROVIDE A CERTIFICATE OF SERVICE COMPLETION AND A TEST CERTIFICATE THATCONFIRMS THE HYDRAULI C ACCUMULATOR IS FIT FOR USE AND MEETS ALL SAFETYAND OPERATIONAL STANDARDS.SERVICE PROVIDER REQUIREMENTS:THE SERVICE PROVIDER MUST B E QUALIFIED AND EXPERIENCED IN SERVICING ANDTESTING HYDRAULIC ACCUMULATORS.THE SERVICE PROVIDER SHOULD ENSURE THAT ALL WORK IS PERFO RMED INCOMPLIANCE WITH APPLICABLE SAFETY STANDARDS AND REGULATIONS.THE PROVIDER SHOULD BE CAPABLE OF PROVIDING THE NECESSARY TEST RE SULTSAND CERTIFICATION AS REQUIRED.ACCEPTANCE CRITERIA:THE HYDRAULIC ACCUMULATOR MUST PASS ALL PRESSURE AND LEAKAGE TESTS WITHNO ISS UES.ALL REPLACEMENT PARTS AND CONSUMABLES MUST BE OF GOOD</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500127  
**DATE** : 14.01.2025  
**REQ No** : 1032500163  
**REQ TITLE** : JAPS L1-STATION SERVICING  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.01.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			QUALITY,COMPATIBLE WITH THE ACCUMULATOR#S SPECIFICATIONS.THE SERVICE AND T ESTING PROCESS MUST MEET THE TECHNICAL AND SAFETYSTANDARDS OUTLINED IN THE REPORT"NOTE:THIS SCOPE OF WORK IS INTENDED TO OUTLINE THE GENERAL TASKS ANDREQUIREMENTS FOR INSPECTION, SERVICING, REPAIRING, AND TESTING. SPECIFICDETAILS MAY VARY BASED ON THE EQUIPMENT AN D MANUFACTURER SPECIFICATIONS.CONTACT PERSON FROM DEWA1. SYED SHOWKAT ALI - SYEDS.ALI@DEWA.GOV.AE / 048140513 OR2. MUHAMMAD SHAMIM K HAN- MUHAMMAD.KHAN@DEWA.GOV.AE / 043226023 /050-2806027						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### SPECIAL NOTES / INSTRUCTIONS:

JAPS L1-STATION SERVICING AND TESTING OF HYDRAULIC ACCUMULATOR

### STANDARD TERMS & CONDITIONS

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500127  
**DATE** : 14.01.2025  
**REQ No** : 1032500163  
**REQ TITLE** : JAPS L1-STATION SERVICING  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.01.2025  
**CLOSING TIME** : 10:00:00

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**