

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	REPLACEMENT OF JUNCTION BOXA)#REMOVAL OF THE EXISTING DAMAGED JUNCTION BOX WITH INSTRUMENTSUPPORT, & U BEAM AND ACCESSORIES (NUT, BO LT, SWING PIN ETC.)B)#SUPPLY INSTALLATION OF SUNSHADE & ITS NECESSARY SUPPORTS WITH EPOXYCOATING.#SUNSHADE MATERIALS SHALL BE HOT DI P GALVANIZED WITH EPOXY COATING.#ALL FASTENERS & ACCESSORIES SHALL BE SS316.C)#SUPPLY AND INSTALLATION OF WEATHER PROOF IP66 RATED J UNCTION BOX ANDTHE TECHNICAL DETAILS AS FOLLOW AS.#MAKE: RITTAL / SCHNEIDER ELECTRIC.#IP66 RATED.#WALL MOUNTED TYPE WITH INDUSTRIAL MULTIPURPOSE ENCLOSURE.#ENCLOSURE WITH BACKPLATE AND ALL NECESSARY ACCESSORIES SHOULD BEINCLUDED AS PER THE BELOW REQUIREMENTS.#MAT ERIAL SHALL BE SS316 ENCLOSURE.#4-POINT LOCK WITH HANDLE AND 10MM DOUBLE BAR INSERT.#EQUIPPED WITH BASE MOUNTING PLATE	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>IN VERTICAL & HORIZONTAL.#STANDARDS: IEC 60529,62262,62208 & 62210, NEMA 4X CLASSIFICATION 13,15 & 4X WITH EXPLOSION PROOF, EN 1634-3 & EN.#PRODU CT CERTIFICATIONS: UL & FM APPROVAL.#FIRE RESISTANCE: 960 C WITH 10 HOURS.#AMBIENT TEMPERATURE -35 C TO 120 C.#TEMPERATURE AND UV R ESISTANCE FOR OUTDOOR USE.#SHALL BE CAPABLE OF THE APPLICATION AS FIRE RESISTANCE, FIRE LOADINSULATION AND SMOKE PROTECTIOND)#THE AC CESSORIES SHALL BE REPLACED AND SHALL BE CORROSION RESISTANTAND FIRE RETARDANT.E)#THE MICC CABLE SHROUD,GLAND,POT & SEAL MATERIALS S HOULD BE FROM THEPRYSMIAN (MAKE).F)#THE EXISTING JUNCTION BOX REMOVAL AND REPLACEMENT WORK SHOULD BECARRIED OUT WITHOUT DISTURBING A NY INSTRUMENTS IN THE JUNCTION BOX & ANYOTHER SYSTEMS IN THE PLANT AND TO BE REPLACED BY VENDOR IF ANYINSTRUMENTS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DAMAGED.G)#ALL THE NECESSARY ACCESSORIES SHOULD BE SUPPLIED BY CONTRACTORH)#IT IS THE CONTRACTOR RESPONSIBILITY TO CARRY OUT A SITE SURVEY TOVERIFY TH E EXACT QUANTITIES AND DIMENSIONS MENTIONED IN THE SCOPE AND TOGET THE DISCREPANCIES CORRECTED IN ADVANCE BEFORE ORDERING. THECONTRA CTOR SHALL SUBMIT THE SPECIFICATIONS AND DRAWINGS OF THEEQUIPMENT'S FOR DEWA APPROVAL BEFORE FINALIZATION OF THE ORDER.I)#THE COMPLE TE HANDLING OF THE MATERIALS INCLUDING TRANSPORT FROM SHOPTO SITE, LOADING AND UNLOADING, STORING AT SITE TILL THE INSTALLATIONSHALL BE DONE BY THE CONTRACTOR AT HIS COST AND RESPONSIBILITY.J)#ANY REPLACED PARTS/SCRAP, WHICH IS NOT REQUIRED BY DEWA SHALL BEREMOVED FROM SITE. THE DISPOSAL IS THE CONTRACTOR RESPONSIBILITY. THEOTHER MATERIALS, SCRAPS						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OF THE REPLACED EQUIPMENT, WHICH DEWA REQUIRES ARE TO BE TRANSFERRED TO THE ASSIGNED STATION LOCATION BY THE CONTRACTOR. ANY PLACE, WHERE OLD EQUIPMENT HAD BEEN REMOVED, MUST BE CLEANED FOR GOOD HOUSEKEEPING.K)#IT IS THE CONTRACTOR'S RESPONSIBILITY TO ENSURE THAT THE REPLACEMENT SHOULD PROVIDE CONVENIENCE OF OPERATION AND MAINTENANCE, NEAT AND ORDERLY ARRANGEMENT WHICH CONSIDERS THE FUNCTIONAL REQUIREMENTS AND GOOD AESTHETIC LOOK.L)#THE TAG NO. OR THE SERVICE DESCRIPTION OR THE KKS CODE ENCRYPTED PLATES (SS316) SHALL BE FIXED ON THE NEW JBS.M)#THE CABLE TAG SHOULD BE PROVIDED AND SHOULD BE INDUSTRIAL TYPE N)#THE SCAFFOLDING WHEREVER REQUIRED, SHALL BE DONE BY THE CONTRACTOR. THE CONTRACTOR MUST CAREFULLY UNINSTALL AND INSTALL THE EQUIPMENT FOR THIS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PROJECT. IT IS THE CONTRACTOR#S SOLE RESPONSIBILITY TO ENSURE THATNO DISTURBANCE, INTERFERENCE, OR INTERRUPTION TO BE CAUSED ON NORMALPLANT OPERATION. ANY DAMAGE TO THE EQUIPMENT DURING THE EXECUTION WORKSHALL BE RESTORED IMMEDIATELY BY THE CONTRACTOR WITH THE SAME MATERIAL.O)#ANY UNFORESEEN OR ADDITIONAL EXPENSES INCURRED FOR THE FULL FUNCTION/ COMPLETION OF THE INTENDED JOB ALLOTTED TO THE CONTRACTOR SHALL BEUNDER HIS SCOPE AND USE NEW AREA AS PROPOSED BY DEWA IF NOT ABLE TO USE EXISTING PLACE.P)#ON RECEIVING CONFIRMED PURCHASE ORDER FROM DEWA, CONTRACTOR SHALLPROVIDE DETAILED SCHEDULE IN MS PROJECT FORMAT HI GHLIGHTING SUPPLY ANDIMPLEMENTATION OF TOTAL WORK. NECESSARY DOCUMENTS / CERTIFICATES /DATASHEETS FOR THE SUPPLIED MATERIAL SHALL B						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>E PROVIDED FOR APPROVAL.Q)#ALL THE ACTIVITIES MENTIONED IN THE SCOPE ARE TO BE CARRIED OUTBASED ON THE PLANT UNDER OPERATING CONDITI ONS. THEREFORE, THE SERVICEWORK ACTIVITIES SHALL BE DONE WITH UTMOST CARE AND IN A SAFE MANNER TOAVOID ANY DISTURBANCE IN THE PLANT. R)#THE PROJECT SHALL BE COMPLETED AND HANDED OVER TO DEWA AT THESHORTEST POSSIBLE TIME.S)#THE CONTRACTOR SHALL ABIDE BY THE PREVAILI NG SAFETY AND SECURITYRULES AND REGULATIONS IN FORCE AT DEWA JEBEL ALI POWER STATION.T)#THE DEDICATED SAFETY OFFICER AND ENGINEER SH OULD BE AVAILABLE DURINGTHE WORK.U)#THE CONTRACTOR SHALL BE LIABLE FOR ALL POSSIBLE DAMAGES TO THEEQUIPMENT AND PERSONS WORKING DUR ING THE EXECUTION OF THE CONTRACT.V)#DEWA WILL NOT PROVIDE ANY SUPPORT / MATERIALS / CONSUMABLE TOCOMPLETE THIS JOB AND ALL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440

DATE : 12.02.2025

REQ No : 1032500626

REQ TITLE : Junction box 1032500626

DELIVERY LOCATION

CLOSING DATE : 20.02.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE WORKS FULLY RESPONSIBLE BY CONTRACTOR.W)#THE MATERIAL TEST CONFORMITY CERTIFICATE & ORIGIN CERTIFICATE SHOULD BE PROVIDED BEFORE OBTAINING THE APPROVAL.X)#THE CONTRACTOR SHALL PROVIDE A MATERIAL SUPPLY WARRANTY OF 5 YEARS AND SERVICE WARRANTY OF 1 YEARS FOR THE WORK PERFORMED.CONTACT:RAMESH KUMAR RRAMESH.R@DEWA.GOV.AE						
2		ITEM-00001	REPLACEMENT OF JUNCTION BOX A)#REMOVAL OF THE EXISTING DAMAGED JUNCTION BOX WITH INSTRUMENT SUPPORT, & U BEAM AND ACCESSORIES (NUT, BOLT, SWING PIN ETC.)B)#SUPPLY INSTALLATION OF SUNSHADE & ITS NECESSARY SUPPORTS WITH EPOXY COATING.#SUNSHADE MATERIALS SHALL BE HOT DIP GALVANIZED WITH EPOXY COATING.#ALL FASTENERS & ACCESSORIES SHALL BE SS316.C)#SUPPLY AND INSTALLATION OF WEATHERPROOF IP66 RATED JU	6	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>JUNCTION BOX AND THE TECHNICAL DETAILS AS FOLLOW AS: MAKE: RITTAL / SCHNEIDER ELECTRIC IP66 RATED WALL MOUNTED TYPE WITH INDUSTRIAL MULTIPURPOSE ENCLOSURE ENCLOSURE WITH BACKPLATE AND ALL NECESSARY ACCESSORIES SHOULD BE INCLUDED AS PER THE BELOW REQUIREMENTS. MATERIAL SHALL BE SS316 ENCLOSURE 4-POINT LOCK WITH HANDLE AND 10MM DOUBLE BAR INSERT EQUIPPED WITH BASE MOUNTING PLATE IN VERTICAL & HORIZONTAL. STANDARDS: IEC 60529, 62262, 62208 & 62210, NEMA 4X CLASSIFICATION 13, 15 & 4X WITH EXPLOSION PROOF, EN 1634-3 & EN PRODUCT CERTIFICATIONS: UL & FM APPROVAL FIRE RESISTANCE: 960 C WITH 10 HOURS. AMBIENT TEMPERATURE -35 C TO 120 C. TEMPERATURE AND UV RESISTANCE FOR OUTDOOR USE. SHALL BE CAPABLE OF THE APPLICATION AS FIRE RESISTANCE, FIRE LOAD INSULATION AND SMOKE PROTECTION. THE ACC</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ESSORIES SHALL BE REPLACED AND SHALL BE CORROSION RESISTANT AND FIRE RETARDANT.E)#THE MICC CABLE SHROUD, GLAND, POT & SEAL MATERIALS SHOULD BE FROM THE PRYSMIAN (MAKE).F)#THE EXISTING JUNCTION BOX REMOVAL AND REPLACEMENT WORK SHOULD BE CARRIED OUT WITHOUT DISTURBING ANY INSTRUMENTS IN THE JUNCTION BOX & ANY OTHER SYSTEMS IN THE PLANT AND TO BE REPLACED BY VENDOR IF ANY INSTRUMENTS DAMAGED.G)#ALL THE NECESSARY ACCESSORIES SHOULD BE SUPPLIED BY CONTRACTOR.H)#IT IS THE CONTRACTOR RESPONSIBILITY TO CARRY OUT A SITE SURVEY TO VERIFY THE EXACT QUANTITIES AND DIMENSIONS MENTIONED IN THE SCOPE AND TO GET THE DISCREPANCIES CORRECTED IN ADVANCE BEFORE ORDERING. THE CONTRACTOR SHALL SUBMIT THE SPECIFICATIONS AND DRAWINGS OF THE EQUIPMENT'S FOR DEWA APPROVAL BEFORE FINALIZATION OF THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ORDER.I)#THE COMPLET E HANDLING OF THE MATERIALS INCLUDING TRANSPORT FROM SHOPTO SITE, LOADING AND UNLOADING, STORING AT SITE TILL THE INSTALLATIONSHALL BE DONE BY THE CONTRACTOR AT HIS COST AND RESPONSIBILITY.J)#ANY REPLACED PARTS/SCRAP, WHICH IS NOT REQUIRED BY DEWA SHALL BEREMOVED FROM SITE. THE DISPOSAL IS THE CONTRACTOR RESPONSIBILITY. THEOTHER MATERIALS, SCRAPS OF THE REPLACED EQUIPMENT, WHICH DEWA REQUIRESA RE TO BE TRANSFERRED TO THE ASSIGNED STATION LOCATION BY THECONTRACTOR. ANY PLACE, WHERE OLD EQUIPMENT HAD BEEN REMOVED, MUST BECLEA NED FOR GOOD HOUSEKEEPING.K)#IT IS THE CONTRACTOR#S RESPONSIBILITY TO ENSURE THAT THE REPLACEMENTSHOULD PROVIDE CONVENIENCE OF OPERA TION AND MAINTENANCE, NEAT ANDORDERLY ARRANGEMENT WHICH CONSIDERS THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FUNCTIONAL REQUIREMENTS AND GOODAESTHETIC LOOK.L)#THE TAG NO. OR THE SERVICE DESCRIPTION OR THE KKS CODE ENCRYPTEDPLATES (SS316) SHALL BE FIXED ON THE NEW JBS.M)#THE CABLE TAG SHOULD BE PROVIDED AND SHOULD BE INDUSTRIAL TYPEN)#THE SCAFFOLDING WHEREVER REQUIRED, SHALL BE DONE BY THE CONTRACTOR.THE CONTRACTOR MUST CAREFULLY UNINSTALL AND INSTALL THE EQUIPMENT FORTHIS PROJECT. IT IS THE CONTRACTOR#S SOLE RESPONSIBILITY TO ENSURE THATNO DISTURBANCE, INTERFER ENCE, OR INTERRUPTION TO BE CAUSED ON NORMALPLANT OPERATION. ANY DAMAGE TO THE EQUIPMENT DURING THE EXECUTION WORKSHALL BE RESTORED IMMEDIATELY BY THE CONTRACTOR WITH THE SAME MATERIAL.O)#ANY UNFORESEEN OR ADDITIONAL EXPENSES INCURRED FOR THE FULL FUNCTION/ COMPLETION OF THE INTENDED JOB ALLOTTED TO THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONTRACTOR SHALL BE UNDER HIS SCOPE AND USE NEW AREA AS PROPOSED BY DEWA IF NOT ABLE TO USE EXISTING PLACE.P)#ON RECEIVING CONFIRMED PURCHASE ORDER FROM DEWA, CONTRACTOR SHALL PROVIDE DETAILED SCHEDULE IN MS PROJECT FORMAT HIGHLIGHTING SUPPLY AND IMPLEMENTATION OF TOTAL WORK. NECESSARY DOCUMENTS / CERTIFICATES / DATA SHEETS FOR THE SUPPLIED MATERIAL SHALL BE PROVIDED FOR APPROVAL.Q)#ALL THE ACTIVITIES MENTIONED IN THE SCOPE ARE TO BE CARRIED OUT BASED ON THE PLANT UNDER OPERATING CONDITIONS. THEREFORE, THE SERVICE WORK ACTIVITIES SHALL BE DONE WITH UTMOST CARE AND IN A SAFE MANNER TO AVOID ANY DISTURBANCE IN THE PLANT.R)#THE PROJECT SHALL BE COMPLETED AND HANDED OVER TO DEWA AT THE SHORTEST POSSIBLE TIME.S)#THE CONTRACTOR SHALL ABIDE BY THE PREVAILING</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>G SAFETY AND SECURITY RULES AND REGULATIONS IN FORCE AT DEWA JEBEL ALI POWER STATION.T)#THE DEDICATED SAFETY OFFICER AND ENGINEER SHOULD BE AVAILABLE DURING THE WORK.U)#THE CONTRACTOR SHALL BE LIABLE FOR ALL POSSIBLE DAMAGES TO THE EQUIPMENT AND PERSONS WORKING DURING THE EXECUTION OF THE CONTRACT.V)#DEWA WILL NOT PROVIDE ANY SUPPORT / MATERIALS / CONSUMABLE TO COMPLETE THIS JOB AND ALL THE WORKS FULLY RESPONSIBLE BY CONTRACTOR.W)#THE MATERIAL TEST CONFORMITY CERTIFICATE & ORIGIN CERTIFICATE SHOULD BE PROVIDED BEFORE OBTAINING THE APPROVAL.X)#THE CONTRACTOR SHALL PROVIDE A MATERIAL SUPPLY WARRANTY OF 5 YEARS AND SERVICE WARRANTY OF 1 YEARS FOR THE WORK PERFORMED.CONTACT: RAMESH KUMAR RRAMESH.R@DEWA.GOV.AE</p>						
3		ITEM-00001	REPLACEMENT OF JUNCTION BOX A)#REMOVAL OF	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE EXISTING DAMAGED JUNCTION BOX WITH INSTRUMENTSUPPORT, & U BEAM AND ACCESSORIES (NUT, BO LT, SWING PIN ETC.)B)#SUPPLY INSTALLATION OF SUNSHADE & ITS NECESSARY SUPPORTS WITH EPOXYCOATING.#SUNSHADE MATERIALS SHALL BE HOT DI</p> <p>P GALVANIZED WITH EPOXY COATING.#ALL FASTENERS & ACCESSORIES SHALL BE SS316.C)#SUPPLY AND INSTALLATION OF WEATHERPROOF IP66 RATED JU</p> <p>NCTION BOX ANDTHE TECHNICAL DETAILS AS FOLLOW AS.#MAKE: RITTAL / SCHNEIDER ELECTRIC.#IP66 RATED.#WALL MOUNTED TYPE WITH INDUSTRIAL M</p> <p>ULTIPURPOSE ENCLOSURE.#ENCLOSURE WITH BACKPLATE AND ALL NECESSARY ACCESSORIES SHOULD BEINCLUDED AS PER THE BELOW REQUIREMENTS.#MATE</p> <p>RIAL SHALL BE SS316 ENCLOSURE.#4-POINT LOCK WITH HANDLE AND 10MM DOUBLE BAR INSERT.#EQUIPPED WITH BASE MOUNTING PLATE IN VERTICAL &</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>HORIZONTAL.#STANDARDS: IEC 60529,62262,62208 & 62210, NEMA 4X CLASSIFICATION 13,15 & 4X WITH EXPLOSION PROOF, EN 1634-3 & EN.#PRODUC T CERTIFICATIONS: UL & FM APPROVAL.#FIRE RESISTANCE: 960 C WITH 10 HOURS.#AMBIENT TEMPERATURE -35 C TO 120 C.#TEMPERATURE AND UV RE SISTANCE FOR OUTDOOR USE.#SHALL BE CAPABLE OF THE APPLICATION AS FIRE RESISTANCE, FIRE LOADINSULATION AND SMOKE PROTECTIOND)#THE ACC ESSORIES SHALL BE REPLACED AND SHALL BE CORROSION RESISTANTAND FIRE RETARDANT.E)#THE MICC CABLE SHROUD,GLAND,POT & SEAL MATERIALS SH OULD BE FROM THEPRYSMIAN (MAKE).F)#THE EXISTING JUNCTION BOX REMOVAL AND REPLACEMENT WORK SHOULD BECARRIED OUT WITHOUT DISTURBING AN Y INSTRUMENTS IN THE JUNCTION BOX & ANYOTHER SYSTEMS IN THE PLANT AND TO BE REPLACED BY VENDOR IF ANYINSTRUMENTS DAMAGED.G)#ALL THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NECESSARY ACCESSORIES SHOULD BE SUPPLIED BY CONTRACTOR)#IT IS THE CONTRACTOR RESPONSIBILITY TO CARRY OUT A SITE SURVEY TO VERIFY THE EXACT QUANTITIES AND DIMENSIONS MENTIONED IN THE SCOPE AND TO GET THE DISCREPANCIES CORRECTED IN ADVANCE BEFORE ORDERING. THE CONTRACTOR SHALL SUBMIT THE SPECIFICATIONS AND DRAWINGS OF THE EQUIPMENT'S FOR DEWA APPROVAL BEFORE FINALIZATION OF THE ORDER.I)#THE COMPLETE HANDLING OF THE MATERIALS INCLUDING TRANSPORT FROM SHOP TO SITE, LOADING AND UNLOADING, STORING AT SITE TILL THE INSTALLATION SHALL BE DONE BY THE CONTRACTOR AT HIS COST AND RESPONSIBILITY.J)#ANY REPLACED PARTS/SCRAP, WHICH IS NOT REQUIRED BY DEWA SHALL BE REMOVED FROM SITE. THE DISPOSAL IS THE CONTRACTOR RESPONSIBILITY. THE OTHER MATERIALS, SCRAPS OF THE REPLACED EQUIPMENT, WHICH DEWA</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REQUIRES A RE TO BE TRANSFERRED TO THE ASSIGNED STATION LOCATION BY THE CONTRACTOR. ANY PLACE, WHERE OLD EQUIPMENT HAD BEEN REMOVED, MUST BE CLEANED FOR GOOD HOUSEKEEPING. K) IT IS THE CONTRACTOR'S RESPONSIBILITY TO ENSURE THAT THE REPLACEMENT SHOULD PROVIDE CONVENIENCE OF OPERATION AND MAINTENANCE, NEAT AND ORDERLY ARRANGEMENT WHICH CONSIDERS THE FUNCTIONAL REQUIREMENTS AND GOOD AESTHETIC LOOK. L) THE TAG NO. OR THE SERVICE DESCRIPTION OR THE KKS CODE ENCRYPTED PLATES (SS316) SHALL BE FIXED ON THE NEW JBS. M) THE CABLE TAG SHOULD BE PROVIDED AND SHOULD BE INDUSTRIAL TYPE. N) THE SCAFFOLDING WHEREVER REQUIRED, SHALL BE DONE BY THE CONTRACTOR. THE CONTRACTOR MUST CAREFULLY UN INSTALL AND INSTALL THE EQUIPMENT FOR THIS PROJECT. IT IS THE CONTRACTOR'S SOLE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440

DATE : 12.02.2025

REQ No : 1032500626

REQ TITLE : Junction box 1032500626

DELIVERY LOCATION

CLOSING DATE : 20.02.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RESPONSIBILITY TO ENSURE THAT NO DISTURBANCE, INTERFERENCE, OR INTERRUPTION TO BE CAUSED ON NORMAL PLANT OPERATION. ANY DAMAGE TO THE EQUIPMENT DURING THE EXECUTION WORK SHALL BE RESTORED IMMEDIATELY BY THE CONTRACTOR WITH THE SAME MATERIAL. O) # ANY UNFORESEEN OR ADDITIONAL EXPENSES INCURRED FOR THE FULL FUNCTION/ COMPLETION OF THE INTENDED JOB ALLOTTED TO THE CONTRACTOR SHALL BE UNDER HIS SCOPE AND USE NEW AREA AS PROPOSED BY DEWA IF NOT ABLE TO USE EXISTING PLACE. P) # ON RECEIVING CONFIRMED PURCHASE ORDER FROM DEWA, CONTRACTOR SHALL PROVIDE DETAILED SCHEDULE IN MS PROJECT FORMAT HIGHLIGHTING SUPPLY AND IMPLEMENTATION OF TOTAL WORK. NECESSARY DOCUMENTS / CERTIFICATES / DATA SHEETS FOR THE SUPPLIED MATERIAL SHALL BE PROVIDED FOR APPROVAL. Q) # ALL THE ACTIVITIES						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MENTIONED IN THE SCOPE ARE TO BE CARRIED OUTBASED ON THE PLANT UNDER OPERATING CONDITIO NS. THEREFORE, THE SERVICEWORK ACTIVITIES SHALL BE DONE WITH UTMOST CARE AND IN A SAFE MANNER TOAVOID ANY DISTURBANCE IN THE PLANT.R</p> <p>)#THE PROJECT SHALL BE COMPLETED AND HANDED OVER TO DEWA AT THESHORTEST POSSIBLE TIME.S)#THE CONTRACTOR SHALL ABIDE BY THE PREVAILIN G SAFETY AND SECURITYRULES AND REGULATIONS IN FORCE AT DEWA JEBEL ALI POWER STATION.T)#THE DEDICATED SAFETY OFFICER AND ENGINEER SHO UL D BE AVAILABLE DURINGTHE WORK.U)#THE CONTRACTOR SHALL BE LIABLE FOR ALL POSSIBLE DAMAGES TO THEEQUIPMENT AND PERSONS WORKING DURIN G THE EXECUTION OF THE CONTRACT.V)#DEWA WILL NOT PROVIDE ANY SUPPORT / MATERIALS / CONSUMABLE TOCOMPLETE THIS JOB AND ALL THE WORKS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FULLY RESPONSIBLE BY CONTRACTOR.W)#THE MATERIAL TEST CONFORMITY CERTIFICATE & ORIGIN CERTIFICATE SHOULD BE PROVIDED BEFORE OBTAINING THE APPROVAL.X)#THE CONTRACTOR SHALL PROVIDE A MATERIAL SUPPLY WARRANTY OF 5 YEARS AND SERVICE WARRANTY OF 1 YEARS FOR THE WORK PERFORMED.CONTACT:RAMESH KUMAR RRAMESH.R@DEWA.GOV.AE						
4		ITEM-00001	REPLACEMENT OF JUNCTION BOX A)#REMOVAL OF THE EXISTING DAMAGED JUNCTION BOX WITH INSTRUMENT SUPPORT, & U BEAM AND ACCESSORIES (NUT, BOLT, SWING PIN ETC.) B)#SUPPLY INSTALLATION OF SUNSHADE & ITS NECESSARY SUPPORTS WITH EPOXY COATING.#SUNSHADE MATERIALS SHALL BE HOT DIP GALVANIZED WITH EPOXY COATING.#ALL FASTENERS & ACCESSORIES SHALL BE SS316.C)#SUPPLY AND INSTALLATION OF WEATHERPROOF IP66 RATED JUNCTION BOX AND THE TECHNICAL DETAILS AS	10	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FOLLOW AS:#MAKE: RITTAL / SCHNEIDER ELECTRIC.#IP66 RATED.#WALL MOUNTED TYPE WITH INDUSTRIAL M</p> <p>ULTIPURPOSE ENCLOSURE.#ENCLOSURE WITH BACKPLATE AND ALL NECESSARY ACCESSORIES SHOULD BEINCLUDED AS PER THE BELOW REQUIREMENTS.#MATE</p> <p>RIAL SHALL BE SS316 ENCLOSURE.#4-POINT LOCK WITH HANDLE AND 10MM DOUBLE BAR INSERT.#EQUIPPED WITH BASE MOUNTING PLATE IN VERTICAL &</p> <p>HORIZONTAL.#STANDARDS: IEC 60529,62262,62208 & 62210, NEMA 4X CLASSIFICATION 13,15 & 4X WITH EXPLOSION PROOF, EN 1634-3 & EN.#PRODUC</p> <p>T CERTIFICATIONS: UL & FM APPROVAL.#FIRE RESISTANCE: 960 C WITH 10 HOURS.#AMBIENT TEMPERATURE -35 C TO 120 C.#TEMPERATURE AND UV RE</p> <p>SISTANCE FOR OUTDOOR USE.#SHALL BE CAPABLE OF THE APPLICATION AS FIRE RESISTANCE, FIRE LOADINSULATION AND SMOKE PROTECTIOND)#THE ACC</p> <p>ESSORIES SHALL BE REPLACED AND SHALL BE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CORROSION RESISTANT AND FIRE RETARDANT. E) # THE MICC CABLE SHROUD, GLAND, POT & SEAL MATERIALS SHOULD BE FROM THE PRYSMIAN (MAKE). THE CO2 STATUS INDICATOR CARD & LIGHT CONNECTIONS TO BE REMOVED AND REINSTALLED BACK TO THE NEW BOX</p> <p>AND THE NECESSARY ACCESSORIES TO BE INCLUDED IN THE OFFER. THE DAMAGED LED ITEMS TO BE REPLACED DURING THE REMOVAL PROCESS. F) # THE EXISTING JUNCTION BOX REMOVAL AND REPLACEMENT WORK SHOULD BE CARRIED OUT WITHOUT DISTURBING ANY INSTRUMENTS IN THE JUNCTION BOX & ANY OTHER SYSTEMS IN THE PLANT AND TO BE REPLACED BY VENDOR IF ANY INSTRUMENTS DAMAGED. G) # ALL THE NECESSARY ACCESSORIES SHOULD BE SUPPLIED BY CONTRACTOR. H) # IT IS THE CONTRACTOR RESPONSIBILITY TO CARRY OUT A SITE SURVEY TO VERIFY THE EXACT QUANTITIES AND DIMENSIONS MENTIONED I</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>N THE SCOPE AND TOGET THE DISCREPANCIES CORRECTED IN ADVANCE BEFORE ORDERING. THECONTRACTOR SHALL SUBMIT THE SPECIFICATIONS AND DRAW INGS OF THEEQUIPMENT'S FOR DEWA APPROVAL BEFORE FINALIZATION OF THE ORDER.I)#THE COMPLETE HANDLING OF THE MATERIALS INCLUDING TRANSP ORT FROM SHOPTO SITE, LOADING AND UNLOADING, STORING AT SITE TILL THE INSTALLATIONSHALL BE DONE BY THE CONTRACTOR AT HIS COST AND RE SPONSIBILITY.J)#ANY REPLACED PARTS/SCRAP, WHICH IS NOT REQUIRED BY DEWA SHALL BEREMOVED FROM SITE. THE DISPOSAL IS THE CONTRACTOR RE SPONSIBILITY. THEOTHER MATERIALS, SCRAPS OF THE REPLACED EQUIPMENT, WHICH DEWA REQUIRESARE TO BE TRANSFERRED TO THE ASSIGNED STATION LOCATION BY THECONTRACTOR. ANY PLACE, WHERE OLD EQUIPMENT HAD BEEN REMOVED, MUST BECLEANED FOR GOOD</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			HOUSEKEEPING.K)#IT IS THE CONTR ACTOR#S RESPONSIBILITY TO ENSURE THAT THE REPLACEMENTSHOULD PROVIDE CONVENIENCE OF OPERATION AND MAINTENANCE, NEAT ANDORDERLY ARRANG EMENT WHICH CONSIDERS THE FUNCTIONAL REQUIREMENTS AND GOODAESTHETIC LOOK.L)#THE TAG NO. OR THE SERVICE DESCRIPTION OR THE KKS CODE E NCRYPTEDPLATES (SS316) SHALL BE FIXED ON THE NEW JBS.M)#THE CABLE TAG SHOULD BE PROVIDED AND SHOULD BE INDUSTRIAL TYPEN)#THE SCAFFOL DING WHEREVER REQUIRED, SHALL BE DONE BY THE CONTRACTOR.THE CONTRACTOR MUST CAREFULLY UNINSTALL AND INSTALL THE EQUIPMENT FORTHIS PR OJECT. IT IS THE CONTRACTOR#S SOLE RESPONSIBILITY TO ENSURE THATNO DISTURBANCE, INTERFERENCE, OR INTERRUPTION TO BE CAUSED ON NORMAL PLANT OPERATION. ANY DAMAGE TO THE EQUIPMENT DURING THE EXECUTION WORKSHALL						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440

DATE : 12.02.2025

REQ No : 1032500626

REQ TITLE : Junction box 1032500626

DELIVERY LOCATION

CLOSING DATE : 20.02.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BE RESTORED IMMEDIATELY BY THE CONTRACTOR WITH THE SAME MATERIAL.O)#ANY UNFORESEEN OR ADDITIONAL EXPENSES INCURRED FOR THE FULL FUNCTION/ COMPLETION OF THE INTENDED JOB ALLOTTED TO THE CON</p> <p>TRACTOR SHALL BE UNDER HIS SCOPE AND USE NEW AREA AS PROPOSED BY DEWA IF NOT ABLE TO USE EXISTING PLACE.P)#ON RECEIVING CONFIRMED PURC</p> <p>HASE ORDER FROM DEWA, CONTRACTOR SHALL PROVIDE DETAILED SCHEDULE IN MS PROJECT FORMAT HIGHLIGHTING SUPPLY AND IMPLEMENTATION OF TOTAL WORK. NECESSARY DOCUMENTS / CERTIFICATES / DATA SHEETS FOR THE SUPPLIED MATERIAL SHALL BE PROVIDED FOR APPROVAL.Q)#ALL THE ACTIVITIES</p> <p>MENTIONED IN THE SCOPE ARE TO BE CARRIED OUT BASED ON THE PLANT UNDER OPERATING CONDITIONS. THEREFORE, THE SERVICE WORK ACTIVITIES SH</p> <p>ALL BE DONE WITH UTMOST CARE AND IN A SAFE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MANNER TO AVOID ANY DISTURBANCE IN THE PLANT.R)#THE PROJECT SHALL BE COMPLETED AND HANDED OVER TO DEWA AT THE SHORTEST POSSIBLE TIME.S)#THE CONTRACTOR SHALL ABIDE BY THE PREVAILING SAFETY AND SECURITY RULES AND REGULATIONS I N FORCE AT DEWA JEBEL ALI POWER STATION.T)#THE DEDICATED SAFETY OFFICER AND ENGINEER SHOULD BE AVAILABLE DURING THE WORK.U)#THE CONTRACTOR SHALL BE LIABLE FOR ALL POSSIBLE DAMAGES TO THE EQUIPMENT AND PERSONS WORKING DURING THE EXECUTION OF THE CONTRACT.V)#DEWA WILL NOT PROVIDE ANY SUPPORT / MATERIALS / CONSUMABLE TO COMPLETE THIS JOB AND ALL THE WORKS FULLY RESPONSIBLE BY CONTRACTOR.W)#THE MATERIAL TEST CONFORMITY CERTIFICATE & ORIGIN CERTIFICATE SHOULD BE PROVIDED BEFORE OBTAINING THE APPROVAL.X)#THE CONTRACTOR SHALL PROVIDE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			A MATERIAL SUPPLY WARRANTY OF 5 YEARSAND SERVICE WARRANTY OF 1 YEARS FOR THE WORK PERFORMED.CONTACT:RAMESH KUMAR RRAMESH.R@DEWA.GOV .AE						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Junction box

STANDARD TERMS & CONDITIONS

- Prices should be 'DDP' delivery duty paid at DEWA stores.
- Quotation to be submitted only in local currency U.A.E Dirhams
- DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500440
DATE : 12.02.2025
REQ No : 1032500626
REQ TITLE : Junction box 1032500626
DELIVERY LOCATION
CLOSING DATE : 20.02.2025
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP