

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500590  
**DATE** : 26.02.2025  
**REQ No** : 1032500985  
**REQ TITLE** : Hiring of OEM service for JFZ  
**DELIVERY LOCATION**  
**CLOSING DATE** : 11.03.2025  
**CLOSING TIME** : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION   | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|---|-----|-----|--------------|----------|------------|-------------|
| 1     |           | ITEM-00001 | REPLACEMENT OF JFZW EL UPS SYSTEM AND ASSOCIATED BATTERY<br>BANKINTRODUCTION:TOTAL REPLACEMENT (INCLUDING DESIGN/REDESIGN, SUPPLY, INST ALLATION,TESTING & COMMISSIONING) OF UNINTERRUPTIBLE POWER SUPPLY (UPS) SYSTEMALONG WITH FULL BATTERY BANK LOCATED AT JFZW SS. EXIST<br>ING UPS AND BATTERY DETAILS:UPS MAKE: STATRONMODEL: S2100-010 1V2 INVERTERSYSTEM RATING: 125BDTE150CAPACITY: 8KVABATTERY MAKE: SAFTB<br>ATTERY MODEL/TYPE: SBLE435BATTERY QTY: 86 CELLSSCOPE DETAILS:VENDORS SHALL REPLACE THE EXISTING FAULTY UPS SYSTEM WITH THE SAME OREQ<br>UIVALENT TYPE INCLUDING BATTERIES AND RELATED ACCESSORIES NECESSARYFOR THE SATISFACTORY PERFORMANCE OF THE SYSTEM. UPS AND BATTERY M<br>ODULESSHALL BE REPLACED WITH THE EQUIVALENT RATING FROM THE EXISTING DESIGNCAPACITY AND EXPECTED BACKUP | 1   | AU  |              |          |            |             |

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500590  
**DATE** : 26.02.2025  
**REQ No** : 1032500985  
**REQ TITLE** : Hiring of OEM service for JFZ  
**DELIVERY LOCATION**  
**CLOSING DATE** : 11.03.2025  
**CLOSING TIME** : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION   | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|---|-----|-----|--------------|----------|------------|-------------|
|       |           |            | <p>TIME.THE REPLACEMENT OFFERED MUST SUPPORT ALL THE NECESSARY OBJECTIVES ANDREQUIREMENTS INTENDED FOR DC SYSTEM AS MENTIONED IN THE LATEST DEWASTANDARD TECHNICAL SPECIFICATIONS FOR DC SYSTEM.THE FOLLOWING MUST BE SUPPLIED:1.#1 X AC UPS + 1 X BYPASS + 1 X ACDB # 8KVA UPS CAPACITY2.#2. 1 X BATTE RY BANK (1 X 86 X SBLE 435)3.#1X FUSEBOX (FOR BATTERY BANK)UPS SHALL BE CAPABLE OF AUTO MODE AND TO SUCCESSFULLY REINSTATE THE MAINE LECTRICAL POWER SUPPLY THROUGH UPS TO THE SUBJECT LOADS.ALL SUPPLIED MATERIALS AND THE SERVICE UNDER THIS CONTRACT MUST BEGUARANTEED FOR TWO (2) YEARS FROM THE DATE OF FINAL ENERGIZATION.VENDOR TO ARRANGE FAT FOR UPS/BATTERIES AS PER DEWA INSPECTION POLICY.THE VEN DOR SHALL BE RESPONSIBLE FOR ALL SUPPLY &amp; LOGISTICS INCLUDINGLOADING, UNLOADING AND SHIFTING OF MATERIALS NECESSARY FOR THE</p> |     |     |              |          |            |             |

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500590  
**DATE** : 26.02.2025  
**REQ No** : 1032500985  
**REQ TITLE** : Hiring of OEM service for JFZ  
**DELIVERY LOCATION**  
**CLOSING DATE** : 11.03.2025  
**CLOSING TIME** : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION  | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|--|-----|-----|--------------|----------|------------|-------------|
|       |           |            | <p>MENTIONE<br/> DWORK. ALL TOOLS AND INSTRUMENTS<br/> NECESSARY FOR EXECUTING THE JOB SHALL<br/> BEARRANGED ACCORDINGLY.LIKEWISE, VENDOR<br/> MUST ENSURE THE UNINT<br/> ERRUPTED POWER SUPPLY TO THEEXISTING LOAD<br/> DURING THE REPLACEMENT. DC STANDBY POWER<br/> SUPPLY SYSTEMSHALL BE USED TO MAINTAIN<br/> POWER SUPP<br/> LY TO THE EXISTING LOAD AND TOPREVENT ANY<br/> DISTURBANCE TO DC POWER SUPPLY.ALL<br/> RELATED CIVIL WORK, CABLE LAYING AND<br/> TERMINATION WORK,<br/> WHETHERSPECIFICALLY MENTIONED OR NOT,<br/> SHALL BE CONSIDERED PART OF<br/> SCOPE.SCHEMATIC DRAWING, GENERAL<br/> ARRANGEMENT &amp; EQUIPMENT DETAILS,<br/> MUST BESUBMITTED TO DEWA FOR APPROVAL<br/> DURING THE ENGINEERING STAGE.EXTENSION &amp;<br/> VERIFICATION OF ALL SIGNALS TO LOCAL HMI &amp;<br/> CONTROL CE<br/> NTER ASPER DC SIGNAL LIST IS PART OF THE<br/> SCOPE.FURTHERMORE, THE OFFERED UPS</p> |     |     |              |          |            |             |

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500590  
**DATE** : 26.02.2025  
**REQ No** : 1032500985  
**REQ TITLE** : Hiring of OEM service for JFZ  
**DELIVERY LOCATION**  
**CLOSING DATE** : 11.03.2025  
**CLOSING TIME** : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION   | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|---|-----|-----|--------------|----------|------------|-------------|
|       |           |            | <p>SYSTEM DESIGN MUST ENSURE AN EFFECTIVE INTERNAL COOLING SYSTEM WITHOUT REDUCING THE RATED CAPACITY &amp; OUTPUT VOLTAGE. SINCE WORK WILL BE CARRIED OUT ON LIVE SUBSTATIONS, IN THIS REGARD, ALL THE CONSTRAINTS RELATED TO CIVIL, SPACE ALLOCATION, SIZING AND OTHER ENGINEERING ASPECTS SHALL BE FINALIZED DURING THE TENDERING STAGE. MOREOVER, VENDORS MUST SUBMIT A SAMPLE OF THE METHOD OF STATEMENT, RISK ASSESSMENT AND OUTAGE REQUIREMENT ALONG WITH THE OFFER. THE METHOD STATEMENT, RISK ASSESSMENT AND OUTAGE REQUIREMENT FOR SPECIFIC WORK SHALL BE SUBMITTED AT AN APPROPRIATE STAGE DURING EXECUTION. THE VENDOR SHALL FOLLOW ALL HEALTH &amp; SAFETY REQUIREMENTS WHILE CARRYING OUT THE JOB. ONLY FULLY TRAINED AND QUALIFIED STAFF WITH PROPER PPE AND TEST EQUIPMENT SHOULD PERFORM</p> |     |     |              |          |            |             |

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500590  
**DATE** : 26.02.2025  
**REQ No** : 1032500985  
**REQ TITLE** : Hiring of OEM service for JFZ  
**DELIVERY LOCATION**  
**CLOSING DATE** : 11.03.2025  
**CLOSING TIME** : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION  | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|--|-----|-----|--------------|----------|------------|-------------|
|       |           |            | <p>THE ACTIVITY.VENDOR SHALL OBTAIN THE ENTRY PERMIT (PERMIT TO WORK- PTW) APPROVAL FROMDEWA IN THE PRESCRIBED FORMAT PRIOR TO START OF THE WORK. UPON APPROVALOF PTW, THE WORK SHALL BE CARRIED OUT IN THE PRESENCE OF DEWA STAFF.A FTER THE REPLACEMENT OF UPS SYSTEM, COMPREHENSIVE TESTING TO BEPERFORMED AS PER SYSTEM RATED CAPACITY &amp; OUTPUT VOLTAGE AND AUTO MODE OPERATION SHALL BE RESTORED UP TO THE FULL SATISFACTION OFALL THE REMOVED COMPONENTS/EQUIPMENT SHALL BE HANDED OVER TO DEWA STOREFOR STORAGE/SCRAPPING BASED ON DEWA#S DISCRETION.NOTE: BATTERIES MUST BE EMPTIED BEFORE DISPATCHING TO DEWA SCRAP YARD.THE VENDOR WILL BE RESPONSIBLE FOR THE DISPOSAL OF ELECTROLYTE AS PERDEWA IMS POLICY, DUBAI MUNICIPALITY &amp; UAE ENVIRONMENTAL LAWS WITHOUTFINANCIAL I</p> |     |     |              |          |            |             |

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500590  
**DATE** : 26.02.2025  
**REQ No** : 1032500985  
**REQ TITLE** : Hiring of OEM service for JFZ  
**DELIVERY LOCATION**  
**CLOSING DATE** : 11.03.2025  
**CLOSING TIME** : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION   | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|---|-----|-----|--------------|----------|------------|-------------|
|       |           |            | <p>IMPLICATION TO DEWA.THE INTERESTED PARTY SHALL VISIT THE SITE TO COLLECT ALL REQUIREDDETAILS, ASSESS THE ENTIRE SCOPE OF WORK PRIOR T<br/>O QUOTE AND NO CLAIM ORCHANGE IN PRICE ACCEPTED AFTER ISSUE OF PO.ALL WORK NOT EXPRESSLY CALLED FOR IN THIS DOCUMENT, BUT NECESSARY<br/>FORTHE COMPLETE AND PROPER INSTALLATION AND SATISFACTORY OPERATION OF THEEQUIPMENT/ACCESSORIES EVEN IF NOTICED AT THE TIME OFINSTALL<br/>ATION/COMMISSIONING, SHALL BE PERFORMED AND FURNISHED BY THEVENDOR AT NO ADDITIONAL FINANCIAL IMPLICATIONS TO DEWA.SUPPLY OF O&amp;M MAN<br/>UAL AND AS-BUILT DRAWINGS IN PDF AND AUTOCAD FORMATSUPON COMPLETION OF WORK TO BE SUBMITTED IN OFFICE AND SEPARATE HARD COPYTO BE KE<br/>PT AT SITE FOR MAINTENANCE REFERENCE.THE DELIVERY NOTE, FINAL TESTING REPORT, JOB COMPLETION REPORT ANDWARRANTY</p> |     |     |              |          |            |             |

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500590  
**DATE** : 26.02.2025  
**REQ No** : 1032500985  
**REQ TITLE** : Hiring of OEM service for JFZ  
**DELIVERY LOCATION**  
**CLOSING DATE** : 11.03.2025  
**CLOSING TIME** : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION   | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|---|-----|-----|--------------|----------|------------|-------------|
|       |           |            | <p>CERTIFICATE ALONG WITH PO COPY SHALL BE SUBMITTED TO DEWA-TAM AFTER SUCCESSFUL COMPLETION OF THE JOB. OPERATIONAL &amp; MAINTENANCE TRAINING FOR DEWA SITE STAFF SHALL BE ARRANGED AND PART OF THE SCOPE. ALL REQUIRED SOFTWARE NECESSARY TO CONFIGURE THE UPS SYSTEM SHALL BE PROVIDED, INCLUDING TRAINING AND FAMILIARIZATION FOR PREVENTIVE MAINTENANCE. FOR ANY FURTHER CLARIFICATION PLEASE CONTACT: NOEL ORCALES AMPERSR ENGR- ASSET MANAGEMENT PROTECTION TRANSMISSION POWER - ASSET MANAGEMENT - PROTECTION &amp; OT DUBAI ELECTRICITY &amp; WATER AUTHORITY (PJSC)<br/>P.O. BOX: 564 DUBAI - UAE<br/>PHONE: 04-32-21701 # FAX: # MOBILE: +971523601282<br/>ORSYED MUHAMMAD NOMAN TAHIR<br/>ACTG DY MGR - ASSET PLNG - PROT &amp; OT # ASSET PLANNING &amp; LIFE CYCLE TRANSMISSION POWER - TRANSMISSION ASSET MANAGEMENT<br/>PHONE:</p> |     |     |              |          |            |             |

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500590  
**DATE** : 26.02.2025  
**REQ No** : 1032500985  
**REQ TITLE** : Hiring of OEM service for JFZ  
**DELIVERY LOCATION**  
**CLOSING DATE** : 11.03.2025  
**CLOSING TIME** : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION                               | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|---|-----|-----|--------------|----------|------------|-------------|
|       |           |            | 04-32-21748 # FAX: # MOBILE: +97150695306 |     |     |              |          |            |             |

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### **SPECIAL NOTES / INSTRUCTIONS:**

Hiring of OEM service for JFZW EL UPS - Rectification Replacement.

### **STANDARD TERMS & CONDITIONS**

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.



## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500590  
**DATE** : 26.02.2025  
**REQ No** : 1032500985  
**REQ TITLE** : Hiring of OEM service for JFZ  
**DELIVERY LOCATION**  
**CLOSING DATE** : 11.03.2025  
**CLOSING TIME** : 10:00:00

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**