

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500701  
**DATE** : 13.03.2025  
**REQ No** : 1032501207  
**REQ TITLE** : M-Station Desal requests Over  
**DELIVERY LOCATION**  
**CLOSING DATE** : 19.03.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>CONTRACTOR DETAILED SCOPE OF SUPPLY IS SHOWN BELOW, HOWEVER IN BRIEF, THE FOLLOWING WORKS SHALL BE CARRIED-OUT: # REMOVE PUMP AND TRANSPORT BACK TO CONTRACTOR WORKSHOP. ## CONTRACTOR WILL COLLECT PUMP AND BE RESPONSIBLE FOR TRANSPORT TO WORKSHOP # DIS-ASSEMBLY, CLEAN, INSPECT (DCI) AND REPORT. # SUBMITTAL OF DETAILED ENGINEERING REPORT WHICH INCLUDES ALL FINDINGS, RECOMMENDATIONS, COSTS AND TIMESCALE S. # REBUILD AND TRANSPORT BACK TO DEWA JEBEL ALI STATION SITE. # CONTRACTOR TO RE-INSTALL THE PUMP. # UPON INSTALLATION OF PUMP, CONTRACTOR WILL ATTEND SITE AND INSPECT WORK AND THEN SUPERVISE THE COMMISSIONING. # UPON SATISFACTORY RUN AND TEST THE PUMP TO DEWA # SATISFACTORY THE PUMP WILL BE HANDED OVER TO DEWA OPERATIONS. # FINAL REPORT WILL BE SUBMITTED. RESPONSIBILITIES: CONTRACTOR</p>	3	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500701  
**DATE** : 13.03.2025  
**REQ No** : 1032501207  
**REQ TITLE** : M-Station Desal requests Over  
**DELIVERY LOCATION**  
**CLOSING DATE** : 19.03.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHALL PROVIDE THE FOLLOWING:(I) FULLY EXPERIENCED SPECIALIST PUMP ENGINEERS FOR THE STRIP DOWN,INSPECTION, REPAIR,REBUILD, INSTALLATION AND COMMISSIONING OF ALL TYPES OF CENTRIFUGALPUMPS.(II) EXPERT PUMP SUPERVISORS.(III) ADEQUATE TOOLS SUCH AS TORQUE WRENCH, PRECISION LEVELS, STRAIGHTEDGES, DIAL GAUGES, MICROMETRES (INSIDE AND OUTSIDE) AND ANY OTHERREQUIRED TOOLS.(IV) A FINAL DETAILED INSPECTION REPORT PROVIDING ALL FINDINGS, ACTIONSTAKEN AND RECOMMENDATIONS FOR REPAIR OR REPLACEMENT OF PARTS.(V) SHAFT STRAIGHTENING, CAN BE CARRIED OUT AT EXTRA COST, IF REQUIRED.(VI) REPAIR OF PARTS, IF ANY, WILL BE CARRIED OUT AT EXTRA COST AFTERAGREED WITH DEWA.DEWA TO PROVIDE THE FOLLOWING:(I) GATE PASSES, PERMIT TO WORKS &amp; ANY OTHER DOCUMENT TO ENTER &amp;COMMENCE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500701  
**DATE** : 13.03.2025  
**REQ No** : 1032501207  
**REQ TITLE** : M-Station Desal requests Over  
**DELIVERY LOCATION**  
**CLOSING DATE** : 19.03.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE WORK AT SITE.(II) MOBILE OVERHEAD, SITE CRANE            AGE &amp; FORKLIFT ETC. FOR            REMOVAL,RE-INSTALLATION AND COMMISSIONING            OF PUMP AT SITE.(III) DISCONNECTION AND            RECONNECTION OF I&amp;C INSTR            UMENTS.(IV) SCAFFOLDING AND LIFTING GEAR. (V)            FREE ISSUE OF SPARE PARTS REQUIRED            REPLACING THE WORN/DAMAGED PARTS(VI) FREE            ISSUE OF            LUBRICANT(VII) CONSUMABLES SUCH AS O-RINGS,            GASKETS, FASTNERS, BOLTS, NUTS, ETC SHALL BE            PROVIDED BY CONTRACTOR.(VIII) MEASURING OF            P            ERFORMANCE DATA (PRESSURE, FLOW,            CURRENT CONSUMPTION ETC) ASSUMES THAT ALL            NECESSARY INSTRUMENTATION IS            ALREADY INSTALLED AND IN WORKI            NG ORDER.CONTRACTOR SCOPE OF WORK:1            UNCOUPLE THE MOTOR FROM THE PUMP BY            REMOVING THE COUPLING BOLTS. TAKE AND            RECORD THE INITIAL ALIG            NMENT READINGS2 BEFORE ANY FURTHER</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500701  
**DATE** : 13.03.2025  
**REQ No** : 1032501207  
**REQ TITLE** : M-Station Desal requests Over  
**DELIVERY LOCATION**  
**CLOSING DATE** : 19.03.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DISASSEMBLY / DISCONNECTION, MARK AND RECORD ALL POSITIONS OF JOINTS, LEADS AND TERMINALS OF MOTOR AND PUMP PARTS TO FACILITATE REASSEMBLY.3 REMOVE THE COUPLING SPACER4 DISCONNECT ALL AUXILIARY PIPING FOR COOLING, VENTING, SEALING ETC5 REMOVE THE PUMP AND SHIFT TO CONTRACTOR WORKSHOP6 DISMANTLE THE PUMP ACCORDING TO PUMP MANUFACTURER#S PROCEDURES7 CHECK AND RECORD INITIAL RUNNING CLEARANCES BETWEEN IMPELLER AND CASING WEAR RINGS8 DISMANTLE THE PUMP ACCORDING TO PUMP MANUFACTURER#S PROCEDURES CONFIRM REFERENCE MARKS ACROSS EACH JOINT TO FACILITATE REASSEMBLY. ALL PARTS SHALL BE CLEANED THOROUGHLY AND PRESERVED AND PROTECTED AGAINST DUST AND ACCIDENTS. WHEREVER REQUIRED, TEMPORARY RUST PREVENTION COATING SHALL BE APPLIED. CLEAN ALL PUMP PARTS AND ABRASIVE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500701  
**DATE** : 13.03.2025  
**REQ No** : 1032501207  
**REQ TITLE** : M-Station Desal requests Over  
**DELIVERY LOCATION**  
**CLOSING DATE** : 19.03.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BLAST AS REQUIRED<sup>9</sup> AFTER COMPLETE DISASSEMBLY INSPECT PUMP SHAFT AND SLEEVES VISUALLY FOR ANY MECHANICAL DAMAGE. MEASURE THE CLEARANCE S BETWEEN SHAFTS AND SLEEVES AND BETWEEN IMPELLER AND CASING WEAR RINGS. <sup>10</sup> CHECK AND RECORD THE RUN OUT OF SHAFT (STRAIGHTEN ALL DEFLECTIONS). <sup>11</sup> INSPECT IMPELLERS FOR CORROSION, EROSION OR WEAR AND REPAIR OR REPLACE. CHECK KEYWAYS BY DPI OR MPI AS APPLICABLE, INSPECT IMPELLER WEAR RINGS AND CASING RINGS AND REPAIR OR REPLACE AS DIRECTED BY DEWA. <sup>12</sup> INSPECT PUMP CASING, AND ALL OTHER PARTS OF THE PUMP FOR CORROSION, WEAR, EROSION, CRACKS, COATING DAMAGE ETC... REPLACE OR REPAIR AS DIRECTED BY DEWA AND APPLY NEW COATING WHEREVER THE ORIGINAL IS DAMAGED. <sup>13</sup> CLEAN AND INSPECT ALL BOLTS, NUTS AND FASTENERS FOR DISTORTION AND DAMAGE TO THREADS AND</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500701  
**DATE** : 13.03.2025  
**REQ No** : 1032501207  
**REQ TITLE** : M-Station Desal requests Over  
**DELIVERY LOCATION**  
**CLOSING DATE** : 19.03.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>HEADS. REPLACE A  S NECESSARY. ANY SUBSTITUTIONS OF TYPE AND  MATERIAL MUST BE APPROVED BY DEWA BEFORE  USE. 14 REPLACE BEARINGS. 15 INSPECT  MECHANICAL SEA  LS AND REPLACE OR REPAIR THE WEARING  PARTS IF FOUND NECESSARY 16 CARRY OUT DPI  FOR PARTS OF THE PUMP SUCH AS IMPELLERS,  SHAFTS, COUPL  ING BOLTS AND ALL THE PARTS DEEMED  NECESSARY. ANY EVIDENCE OF CRACKING SHALL  BE EITHER REPAIRED OR REPLACED. REPAIRS  CARRIED OUT BY CO  NTRACTOR SHALL BE CONSIDERED AS  ADDITIONAL WORKS AND SUBJECT TO ADDITIONAL  COSTS. SIMILAR FOR PARTS NOT AVAILABLE IN  DEWA STOCK AND SU  PLIED BY CONTRACTOR, IF ANY, AFTER  APPROVAL FROM DEWA. CONSUMABLES LIKE  GASKETS, FASTNERS, O-RINGS SUPPLY SHALL BE  IN CONTRACTOR SCO  PE OF WORK. 17 ON RECEIPT OF THE DEWA  INSTRUCTION TO PROCEED WITH THE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500701  
**DATE** : 13.03.2025  
**REQ No** : 1032501207  
**REQ TITLE** : M-Station Desal requests Over  
**DELIVERY LOCATION**  
**CLOSING DATE** : 19.03.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RE-ASSEMBLY,THE CONTRACTOR SHALL RE-ASSEMBLE THE PUMP USING NEW AND REPAIRCOMPONENT AS DETAILED IN APPROVED REPORT.18 CLEAN, LUBRICATE AND GREASE PUMP PARTS AS REQUIRED, PRIOR TOREASSEMBLY.19 RE-ASSEMBLE IN ACCORDANCE WITH THE MANUFACTURERS# PROCEDURE ANDDRAWINGS, TAKING INTO CONSIDERATION ALL SPECIFIED CLEARANCES ANDTOLERANCES. AT EACH STAGE, FREE ROTATION OF COMPONENTS IS TO BE CHECKEDAND RECORDED. CHECK, ADJUST AND RECORD THE CLEARANCE BETWEEN SHAFTS AND BEARINGS BETWEEN IMPELLERS AND CASING. THE PUMP SHALL ROTATE FREELYWITHOUT RUBBING AFTER FINAL ASSEMBLY.20 SHIFT THE PUMP FROM CONTRACTOR WORKSHOP TO DEWA SITE21 RE-INSTALL THE PUMP.22 RECONNECT ALL AUXILIARY PIPING WITH NEW FLANGE GASKETS FREE ISSUED BYDEWA.4.7 REALIGN THE MOTOR AND PUMP PRIOR TO</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500701  
**DATE** : 13.03.2025  
**REQ No** : 1032501207  
**REQ TITLE** : M-Station Desal requests Over  
**DELIVERY LOCATION**  
**CLOSING DATE** : 19.03.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>COUPLE. TIGHTENING OF COUPLINGS SHALL BE DONE USING ADEQUATE TORQUE WRENCHES, TO SPECIFIED VALUES</p> <p>.4.8 REFILL BEARING OIL WITH FREE ISSUED OIL BY DEWA.4.9 CONTRACTOR SHALL SUPPLY SUPERVISOR TO SUPPORT THE COMMISSIONING TO CUSTOMERS</p> <p>SATISFACTION. FOLLOWING REPORT SHALL BE SUBMITTED, BOTH IN HARD AND SOFT COPY CONTAINING: A) #SITE REMOVAL REPORT B) #STRIP DOWN/OPENING REPAIR REPORT ON COMPLETION OF EACH STRIP DOWN AND INSPECTION OF PUMP, CONTRACTOR SHALL PREPARE AND SUBMIT TO DEWA FOR APPROVAL, A COMPREHENSIVE STRIPDOWN REPORT. THIS REPORT SHALL INCLUDE AS A MINIMUM: - COMPONENT GENERAL CONDITIONS. - DETAILED DESCRIPTION OF WEAR AND TEAR AND ANY DAMAGE. C) ASSEMBLY REPORT D) SITE INSTALLATION REPORT E) COMMISSIONING REPORT</p>						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500701  
**DATE** : 13.03.2025  
**REQ No** : 1032501207  
**REQ TITLE** : M-Station Desal requests Over  
**DELIVERY LOCATION**  
**CLOSING DATE** : 19.03.2025  
**CLOSING TIME** : 10:00:00

### **SPECIAL NOTES / INSTRUCTIONS:**

M-Station Desal requests Overhauling service for 3Nos of Distillate  
Booster Pumps in Blending Plant  
For More information please contact:  
Tamer Gamal El Din El Sayed , 0504611507  
TamelE@dewa.gov.ae

### **STANDARD TERMS & CONDITIONS**

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500701  
**DATE** : 13.03.2025  
**REQ No** : 1032501207  
**REQ TITLE** : M-Station Desal requests Over  
**DELIVERY LOCATION**  
**CLOSING DATE** : 19.03.2025  
**CLOSING TIME** : 10:00:00

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**