

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATIONS, OUTSOURCING WORK L STATION PHASE II, JEBEL ALINAME OF WORK:INSPECTION, REFURBISHMENT AND TESTI</p> <p>NG OF HRSG# 83 -DIVERTER DAMPER HPUAND ITS COMPONENTS, L-2 MBRPERIOD OF WORK: #HRSG 83-1 NOS DD HPU REFURBISHMENT (TENTATIVE DATE 11</p> <p>/2025) 4 DAYSADVANCE NOTOFICATION: #4 CALENDAR DAYS SCOPE OF WORK:1.#THIS SCOPE INCLUDES COMPLETE INSPECTION OF HRSG-83 DIVERTER DAM</p> <p>PERHPU UNIT AND OVERHAULING OF ALL HPU COMPONENTS.2.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WOR</p> <p>K SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETYMEASURES ETC., BEFORE HE SUBMITS HIS BID.3.#SUBMIT DETAILED SCHEDULE AND RISK</p> <p>ASSESSMENT / METHOD STATEMENT OFTHE WORK IN ADVANCE TO DEWA.4.#OBTAIN GATE PASS FOR THE STAFF AND PERMIT TO WORK. (FOR</p>	1	AU				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THIS CONTRACTOR HAS TO SUBMIT THE NECESSARY GATE ENTRY PASS DOCUMENTS TO DEWA ENGINEER WELL IN ADVANCE) 5. #CHECKING OF DIVERTER DAMPER OPERATION (NORMAL OPENING/ CLOSING, FAST CLOSING AND RECORDING THE OPERATING TIME) BEFORE START OF THE WORK. 6. #MOBILIZE SKILLED MANPOWER, TOOLS &amp; SPECIAL TOOLS. ETC. REQUIRED FOR REMOVAL OF HPU COMPONENTS. 7. #CONDUCT DAILY TOOLBOX TALKS PRIOR TO START OF WORK. 8. #PRIOR TO STARTING THE WORK, PROPER PHYSICAL INSPECTION TO BE CARRIED OUT AND REPORT OF ANY ISSUE / OBSERVATION TO BE INFORMED TO THE DEWA REPRESENTATIVE. 9. #CLEANING OF HPU AND ALL COMPONENTS EXTERNALLY. 10. #DRAINING OF HYDRAULIC OIL. MAKE SURE THAT DURING DRAINING NO OIL SHOULD LEAK OUTSIDE. 11. #OPENING OF THE MANHOLE DOOR OF THE TANK. 12. #CLEANING OF TANK INTERNAL,</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MANHOLE DOOR SEATING SURFACE.13.#REMOVAL OF PUMP SUCTION STRAINER (03 NOS), TANK LEVEL GAUGE.CLEANING OF SUCTION STRAINERS LEVEL GAUGE AND PUT IT BACK.14.#REMOVAL, SERVICE AND TESTI NG OF TANK DRAIN VALVE.15.#REMOVAL OF HPU TOP COVER TO REMOVE PUMP MOTORS.16.#REMOVAL OF PUMP MOTORS. REMOVAL OF ELECTRIC AND CONTRO L CABLESSHALL BE ARRANGED BY DEWA.17.#REMOVAL OF THE PUMPS (2 NOS OF HYDRAULIC MAIN PUMP AND ONE NO OFHYDRAULIC CHARGING PUMP) SENT TO CONTRACTOR WORKSHOP TO CHECK THEIRPERFORMANCE. (MAX OPERATING PRESSURE FOR BOTH THE PUMPS ARE 190 BARS) IFFOUND ANY ABNORMALITY, PUMP MAINTENANCE SHALL BE CARRIED OUT BY THECONTRACTOR. NON-REPAIRABLE INSURANCE SPARES WILL BE SUPPLIED BY DEWA.CONSUMABLES LIKE O RINGS. OIL SEALS AND PUMP COUPLING SPIDERS						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHALL BEARRANGED BY THE CONTRACTOR.  AFTER OVERHAULING AND TESTING FIXING  BACK.18.#REPLACE  MENT OF HIGH PRESSURE (03 NOS) AND DOUBLE  RETURN OIL LINEFILTERS. ALL FILTERS WILL BE  SUPPLIED BY DEWA. INSPECTION AND  SERVICINGOF R  ETURN OIL FILTER CHANGE OVER  LEVER19.#INSPECTION AND CLEANING OF AIR  VENTING FILTER.20.#REMOVAL OF THE RELIEF  MANIFOLD BLOCK, INSPEC  TION, REPLACEMENT OFTHE SEALS, TEST THE  BLOCK AND FIX IT BACK.21.#REMOVAL OF THE  MAIN MANIFOLD WITH 3/2 DIRECTION POPPET  VALVES (05N  OS), INSPECTION, REPLACEMENT OF THE SEALS,  TEST THE BLOCK AND FIX ITBACK.22.#REMOVAL,  OVERHAULING AND TESTING OF THE SAFETY  VALVES (  03 NOS) ANDFIX IT BACK. SAFETY VALVE TEST  PRESSURE SHALL BE 210 BAR.23.#DISMANTLE OF  HYDRAULIC PIPES, INSPECTION, CLEANING,  REPLACEM</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ENT OFO RINGS AND FIX IT BACK.24.#</p> <p>25.#INSPECTION OF THE CHECK VALVES ITS SERVICE. (03 NOS)25.# 26.#INSPECTION OF THE RESTRICTOR VALVE AND ITS SERVICE AND ITSADJUSTMENT AS REQUIRED. (02 NOS)26.# 27.#REMOVAL, INSPECTION OF THE COUNTERBALANCE VALVE BLOCK VALVE(01 NOS), REPLACEMENT OF SEAL, SET THE PRESSURES AS PER RECOMMENDATION.27.# 28.#INSPECTION OF PILOT OPERATED CHECK VALVE AND ITS SERVICING .(01 NOS).28.# 29.#INSPECTION AND SERVICING OF THE CARTRIDGE VALVE. (02 NOS).29.# 30.#INSPECTION OF ALL HYDRAULIC HOSES, REPLACEMENT OF HOSE AND ORINGS IF REQUIRED.30.# 31.#INSPECTION AND OVERHAULING OF OIL COOLING AIR FANS (02 NO),OIL COOLERS (02 NOS), REPLACEMENT OF SEALS, FILTER ELEMENTS, ASSEMBLEBACK AND CHECK FOR ANY LEAKAGE.31.# 32.#ALL ACCUMULATOR N2 PRESSURE CHECKING, FILLING</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OF N2 AND REPLACEMENT OF ACCUMULATOR BLADDER IF REQUIRED. 33.#INSPECTION AND SERVICING AND TESTING OF ACCUMULATOR ISOLATIONVALVES AND REPLACEMENT OF SEAL AS REQUIRED.32.# 34. INSPECTION OF THE HAND PUMP (01 NOS) AND FLOW CONTROL VALVES,REPLACEMENT OF EXTERNAL SE ALS, ASSEMBLING &amp; TEST.33.# 35.#ALL FITTINGS AND PIPES TO BE DISMANTLED &amp; REPLACE THE SEALO-RINGS AND ASSEMBLE IT BACK.34.# 36.#CLEA NING OF ALL THE EXTERNAL PART OF HPU AND TANK INTERNALSAND INSITU PAINTING (IF REQUIRED).35.# 37.#RESTORER ALL THE EQUIPMENT REMOVED FROM THE HPU UNIT FOROVERHAULING / SERVICING AS PER INITIAL CONDITION.36.# 38.#FILL IN THE SYSTEM WITH THE NEW HYDRAULIC OIL (NEW O IL WILLBE SUPPLIED BY DEWA) TO THE LEVEL, COMMISSION THE SYSTEM INCLUDINGDIVERTER</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DAMPER OPERATION CHECKING LIKE NORMAL OPENING/ CLO SING, FASTCLOSING TO THE SATISFACTION OF DEWA ENGINEER AND OPERATION.37.# 39.#ALL REQUIRED HIGH-PRESSURE OIL SEALS, O-RINGS; PUMP-CO UPLINGSPIDERS WILL BE IN THE SCOPE OF CONTRACTOR.38.# 40.#ALL NON-REPAIRABLE INSURANCE SPARES WILL BE PROVIDED BY DEWA.39.# WARRANTY 40.# 1.THE WARRANTY PERIOD FOR THE WORK/REPAIR SHALL BE ONE YEAR FROMTHE DATE OF COMPLETION OF WORKS CERTIFIED BY DEWA.41.# 2. IN CA SE OF ANY DAMAGE/DEFECT OF THE WORK / HPU COMPONENTSCARRIED OUT UNDER THIS CONTRACT WITHIN THIS WARRANTY PERIOD, THECONTRACTOR SHALL ATTEND AND CARRY OUT THE NECESSARY REPAIR WORK AND MAKETHE DEFECT GOOD WITHIN A SHORT PERIOD WITHOUT AFFECTING THE PRODUCTIONOF ELE CTRICITY AND WATER.42.# GENERAL TERMS &amp;</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONDITIONS43.# 1.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLYFAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES,SAFETY MEASURES ETC., BEFORE HE SUBMITS HIS BID.44.# 2.#THE CONTRACTOR SHALL ENSURE HOUSEKEEPING ON A DAILY BASIS ANDTHE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSALS TODesignated PLACES.45 .# 3.#ALL DEWA SAFETY &amp; ENVIRONMENT POLICY, RULES AND REGULATIONS SHALL BE FOLLOWED AT WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR#S ENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILEWORKING IN A HAZARDOUS AREA.46.# 4.#SCAFFOLDING SHALL BE ARRAN GED BY DEWA. ALL RIGGING ANDTRANSPORTING EQUIPMENT SHOULD BE ARRANGED BY THE CONTRACTOR. THISEQUIPMENT SHOULD BE DULY TESTED AND CER</p>						



## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TIFIED BY THE 3RD PARTY INSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCED ON DEMAND. QUALIFIED RIGGER, MECHANICS SHOULD BE PROVIDED. 47. # 5. # THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PER QUALITY / SCHEDULE REQUIREMENT. 48. # 6. # CONTRACTOR'S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THE PERIOD OF WORK. 49. # 7. # ENTRY PERMITS FOR THE STAFF/WORKERS SHOULD BE APPLIED WITH PASSPORT COPIES HAVING VALID VISA. PEOPLE WHOSE NAMES ARE NOT AVAILABLE ON THE LIST, WILL NOT BE ALLOWED TO ENTER THE POWERHOUSE. 50. # 8. # ENTRY PERMITS FOR THE VEHICLE SHOULD BE APPLIED WITH COPIES OF VEHICLE REGISTRATION. 51. # 9. # DEWA WILL ARRANGE NECESSARY PTW / LC / HWP FROM OPERATION, CHEMICAL LAB / FIRE DEPARTMENT CLEARANCES TO CARRY OUT THE SCOPE OF WORK UNDER THIS CONTRACT. 52. #</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>10.#THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRSTENSURE A SAFE WORKING CONDITION.53.# 11.#ALL THE PEOPLE SHOULD WEAR ALL THE REQUIRED PPE W HILE ATWORK.54.# 12.#ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT THEPOWER STATION SECURITY GATE AND THE LIST OF THESE ITE MS SHALL BE SIGNEDBY DEWA SECURITY. THE COPIES OF THESE DOCUMENTS SHALL BE LODGED WITHDEWA ENGINEER IN CHARGE DAILY. THIS DOCUMENT W ILL BE THE BASIS FOR THECLEARANCE (GATE PASS) TO TAKE THEM OUT ON COMPLETION OF THE JOB.55.# 13.#TRANSPORTATION OF ANY REMOVED ITEMS FROM THE HPU UNIT TOCONTRACTOR WORKSHOP AND RETURN BACK TO DEWA SITE AFTEROVERHAULING/TESTING WILL BE UNDER CONTRACTOR SCOPE. DEWA WILL ARRANGERETURNABLE GATE PASS FOR THOSE MATERIALS.56.# 14.#SERVICE AIR,</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ELECTRICITY AND WATER FOR WORK AT DEWA SITE. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO HAVE HIS OWN ARRANGEMENT IN EXTENDING THE ELECTRICITY AND WATER UTILITY TO HIS PLACES OF WORK.						
2		ITEM-00001	NAME OF WORK: INSPECTION, REFURBISHMENT AND TESTING OF HRSG# 84 - DIVERter DAMPER HPU AND ITS COMPONENTS, L-2 MBR PERIOD OF WORK: #HRSG 84 -1 NOS DD HPU REFURBISHMENT (TENTATIVE DATE 02/2026) 4 DAYS ADVANCE NOTIFICATION: #4 CALENDAR DAYS SCOPE OF WORK: 1.#THIS SCOPE INCLUDES COMPLETE INSPECTION OF HRSG-84 DIVERter DAMPER HPU UNIT AND OVERHAULING OF ALL HPU COMPONENTS. 2.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE HE SUBMITS HIS BID. 3.#SUBMIT DETAILED SCHEDULE AND	1	AU				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RISK ASSESSMENT / METHOD STATEMENT OF THE WORK IN ADVANCE TO DEWA.4.#OBTAIN GATE PASS FOR THE STAFF AND PERMIT TO WORK. (FOR THIS CONTRACTOR HAS TO SUBMIT THE NECESSARY GATE ENTRY PASS DOCUMENTS TO DEWA ENGINEER WELL IN ADVANCE)5.#CHECKING OF DIVERTER DAMPER OPERATION (NORMAL OPENING/ CLOSING, FAST CLOSING AND RECORDING THE OPERATING TIME) BEFORE START OF THE WORK.6.#MOBILIZE SKILLED MANPOWER, TOOLS &amp; SPECIAL TOOLS. ETC. REQUIRED FOR REMOVAL OF HPU COMPONENTS.7.#CONDUCT DAILY TOOLBOX TALKS PRIOR TO START OF WORK.8.#PRIOR TO STARTING THE WORK, PROPER PHYSICAL INSPECTION TO BE CARRIED OUT AND REPORT OF ANY ISSUE / OBSERVATION TO BE INFORMED TO THE DEWA REPRESENTATIVE.9.#CLEANING OF HPU AND ALL COMPONENTS EXTERNALLY.10.#DRAINING OF HYDRAULIC OIL.</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MAKE SURE THAT DURING DRAINING NO OILSHOULD LEAK OUTSIDE.11.#OPENING OF THE MANHOLE DOOR OF THE TANK.12.#CLEANING OF TANK INTERNAL, MANHOLE DOOR SEATING SURFACE.13.#REMOVAL OF PUMP SUCTION STRAINER (03 NOS), TANK LEVEL GAUGE.CLEANING OF SUCTION STRAINERS LEVEL GAU GE AND PUT IT BACK.14.#REMOVAL, SERVICE AND TESTING OF TANK DRAIN VALVE.15.#REMOVAL OF HPU TOP COVER TO REMOVE PUMP MOTORS.16.#REMOV AL OF PUMP MOTORS. REMOVAL OF ELECTRIC AND CONTROL CABLESSHALL BE ARRANGED BY DEWA.17.#REMOVAL OF THE PUMPS (2 NOS OF HYDRAULIC MAIN PUMP AND ONE NO OFHYDRAULIC CHARGING PUMP) SENT TO CONTRACTOR WORKSHOP TO CHECK THEIRPERFORMANCE. (MAX OPERATING PRESSURE FOR BOTH THE PUMPS ARE 190 BARS) IFFOUND ANY ABNORMALITY, PUMP MAINTENANCE SHALL BE CARRIED OUT BY THECONTRACTOR.</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NON-REPAIRABLE INSURANCE SP ARES WILL BE SUPPLIED BY DEWA.CONSUMABLES LIKE O RINGS. OIL SEALS AND PUMP COUPLING SPIDERS SHALL BEARRANGED BY THE CONTRACTOR. AFTE R OVERHAULING AND TESTING FIXING BACK.18.#REPLACEMENT OF HIGH PRESSURE (03 NOS) AND DOUBLE RETURN OIL LINEFILTERS. ALL FILTERS WILL BE SUPPLIED BY DEWA. INSPECTION AND SERVICINGOF RETURN OIL FILTER CHANGE OVER LEVER19.#INSPECTION AND CLEANING OF AIR VENTING FILTER .20.#REMOVAL OF THE RELIEF MANIFOLD BLOCK, INSPECTION, REPLACEMENT OFTHE SEALS, TEST THE BLOCK AND FIX IT BACK.21.#REMOVAL OF THE MA IN MANIFOLD WITH 3/2 DIRECTION POPPET VALVES (05NOS), INSPECTION, REPLACEMENT OF THE SEALS, TEST THE BLOCK AND FIX ITBACK.22.#REMOVA L, OVERHAULING AND TESTING OF THE SAFETY VALVES (03 NOS) ANDFIX IT BACK. SAFETY VALVE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TEST PRESSURE SHALL BE 210 BAR.23.#DISMANTLE OF HYDRAULIC PIPES, INSPECTION, CLEANING, REPLACEMENT OF RINGS AND FIX IT BACK.24.# 25.#INSPECTION OF THE CHECK VALVES ITS SERVICE.</p> <p>(03 NOS)25.# 26.#INSPECTION OF THE RESTRICTOR VALVE AND ITS SERVICE AND ITSADJUSTMENT AS REQUIRED. (02 NOS)26.# 27.#REMOVAL, INSPECTION OF THE COUNTERBALANCE VALVE BLOCK VALVE(01 NOS), REPLACEMENT OF SEAL, SET THE PRESSURES AS PER RECOMMENDATION.27.# 28.#INSPECTION OF PILOT OPERATED CHECK VALVE AND ITS SERVICING.(01 NOS).28.# 29.#INSPECTION AND SERVICING OF THE CARTRIDGE VALVE. (02 NOS).29.# 30.#INSPECTION OF ALL HYDRAULIC HOSES, REPLACEMENT OF HOSE AND ORINGS IF REQUIRED.30.# 31.#INSPECTION AND OVERHAULING OF OIL COOLING AIR FANS (02 NO),OIL COOLERS (02 NOS), REPLACEMENT OF SEALS, FILTER ELEMENTS,</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ASSEMBLEBACK AND CHECK FOR ANY LEAKAGE.31.# 32.#ALL AC CUMULATOR N2 PRESSURE CHECKING, FILLING OF N2 ANDREPLACEMENT OF ACCUMULATOR BLADDER IF REQUIRED. 33.#INSPECTION AND SERVICING AND TE STING OF ACCUMULATOR ISOLATIONVALVES AND REPLACEMENT OF SEAL AS REQUIRED.32.# 34. INSPECTION OF THE HAND PUMP (01 NOS) A ND FLOW CONTROL VALVES,REPLACEMENT OF EXTERNAL SEALS, ASSEMBLING &amp; TEST.33.# 35.#ALL FITTINGS AND PIPES TO BE DISMANTLED &amp; REPLACE T HE SEALO-RINGS AND ASSEMBLE IT BACK.34.# 36.#CLEANING OF ALL THE EXTERNAL PART OF HPU AND TANK INTERNALSAND INSITU PAINTING (IF REQU IRED).35.# 37.#RESTORER ALL THE EQUIPMENT REMOVED FROM THE HPU UNIT FOROVERHAULING / SERVICING AS PER INITIAL CONDITION.36.# 38.#FIL L IN THE SYSTEM WITH THE NEW HYDRAULIC OIL (NEW OIL WILLBE SUPPLIED BY DEWA) TO THE</p>						



## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>LEVEL, COMMISSION THE SYSTEM INCLUDING DIVERTER D AMPER OPERATION CHECKING LIKE NORMAL OPENING/ CLOSING, FASTCLOSING TO THE SATISFACTION OF DEWA ENGINEER AND OPERATION.37.# 39.#ALL R EQUIRED HIGH-PRESSURE OIL SEALS, O-RINGS; PUMP-COUPLINGSPIDERS WILL BE IN THE SCOPE OF CONTRACTOR.38.# 40.#ALL NON-REPAIRABLE INSURANCE SPARES WILL BE PROVIDED BY DEWA.39.# WARRANTY40.# 1.THE WARRANTY PERIOD FOR THE WORK/REPAIR SHALL BE ONE YEAR FROMTHE DATE OF COMPLETION OF WORKS CERTIFIED BY DEWA.41.# 2. IN CASE OF ANY DAMAGE/DEFECT OF THE WORK / HPU COMPONENTSCARRIED OUT UNDER THIS CONTRACT WITHIN THIS WARRANTY PERIOD, THECONTRACTOR SHALL ATTEND AND CARRY OUT THE NECESSARY REPAIR WORK AND MAKE THE DEFECT GOOD WITHIN A SHORT PERIOD WITHOUT AFFECTING THE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PRODUCTIONOF ELECTRICITY AND WATER.42.# GENERAL TERMS &amp; CONDITIONS43.# 1.#THE CONTRACTOR SHALL V ISIT THE SITE AND MAKE HIMSELF FULLYFAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES,SAFETY MEASURES ETC., BEFOR E HE SUBMITS HIS BID.44.# 2.#THE CONTRACTOR SHALL ENSURE HOUSEKEEPING ON A DAILY BASIS ANDTHE CONTRACTOR SHALL BE RESPONSIBLE FOR AL L WASTE MATERIAL DISPOSALS TODesignated PLACES.45.# 3.#ALL DEWA SAFETY &amp; ENVIRONMENT POLICY, RULES AND REGULATIONSHALL BE FOLLOWED A T WORK SITE DURING THE EXECUTION OF THE WORK. THECONTRACTOR#S ENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILEWORKING IN A HAZARDOUS AREA.46.# 4.#SCAFFOLDING SHALL BE ARRANGED BY DEWA. ALL RIGGING ANDTRANSPORTING EQUIPMENT SHOULD BE ARRANGED BY THE CONTRA</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CTOR. THISEQUIPMENT SHOULD BE DULY TESTED AND CERTIFIED BY THE 3RD PARTYINSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCED ON DEMAND.QUALIFIED RIGGER, MECHANICS SHOULD BE PROVIDED.47.# 5.#THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PERQUALITY / SCHEDULE REQUIREMENT.48.# 6.#CONTRACTOR#S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUTTHE PERIOD OF WORK.49.# 7.#ENTRY PERMITS FOR THE STAFF/WORKERS SHOULD BE APPLIED WITHPASSPORT COPIES HAVING VALID VISA. PEOPLE WHOSE NAMES ARE NOT AVAILABLEON THE LIST, WILL NOT BE ALLOWED TO ENTER THE POWERHOUSE.50.# 8.#ENTRY PERMITS FOR THE VEHICLE SHOULD BE APPLIED WITH COPIES OFVEHICLE REGISTRATION.5 1.# 9.#DEWA WILL ARRANGE NECESSARY PTW / LC / HWP FROM OPERATION,CHEMICAL LAB / FIRE DEPARTMENT CLEARANCES TO CARRY OUT THE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SCOPE OF WORK UNDER THIS CONTRACT.52.# 10.# THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE A SAFE WORKING CONDITION.53.# 11.# ALL THE PEOPLE SHOULD WEAR ALL THE REQUIRED PPE WHILE AT WORK.54.# 12.# ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT THE POWER STATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BY DEWA SECURITY. THE COPIES OF THESE DOCUMENTS SHALL BE LODGED WITH DEWA ENGINEER IN CHARGE DAILY. THIS DOCUMENT WILL BE THE BASIS FOR THE CLEARANCE (GATE PASS) TO TAKE THEM OUT ON COMPLETION OF THE JOB.55.# 13.# TRANSPORTATION OF ANY REMOVED ITEMS FROM THE HPU UNIT TO CONTRACTOR WORKSHOP AND RETURN BACK TO DEWA SITE AFTER OVERHAULING/TESTING WILL BE UNDER CONTRACTOR SCOPE. DEWA WILL ARRANGE RETURNABLE GATE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PASS FOR THOSE MATERIALS.56.# 14.#SERVICE AIR, ELECTRIC ITY AND WATER FOR WORK AT DEWA SITE. ITIS THE RESPONSIBILITY OF THE CONTRACTOR TO HAVE HIS OWN ARRANGEMENT INEXTENDING THE ELECTRIC ITY AND WATER UTILITY TO HIS PLACES OF WORK.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### **SPECIAL NOTES / INSTRUCTIONS:**

Inspection, Refurbishment and testing of HRSG 83 <(>&<)> 84 -diverter damper HPU and its components during 2025-2026 outage for L-2 MBR

Note: Site visit required

Contact ehab.bahour@dewa.gov.ae Tel: 0567375091

### **STANDARD TERMS & CONDITIONS**

1) Prices should be 'DDP' delivery duty paid at DEWA stores.

**MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.**

Page21 of 22

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501649  
**DATE** : 01.07.2025  
**REQ No** : 1032503095  
**REQ TITLE** : Inspection, Refurbishment and  
**DELIVERY LOCATION**  
**CLOSING DATE** : 07.07.2025  
**CLOSING TIME** : 10:00:00

- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**