

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK L 2 STATION, JEBEL ALI POWER STATION TITLE: #IN-SERVICE / EXTERNAL INSPECTION OF JAPS MAKE UP WATER TANK # A & B80GCL21BB001&80GCL22B001 IN COMPLIANCE WITH API 653 AT L 2 STATION, DEWA, JEBEL ALIA. #QUANTITY & SPECIFICATION: #MAKE UP WATER TANK # A & B. #QTY: 02 TANKS. #TANK SIZE: 18 METER Ø X 17.2 METER HIGH. #TANK TYPE: FIXED CONE ROOF # VERTICAL ATMOSPHERIC STORAGE TANK. #DESIGN CODE: API STD 650, 10TH EDITION. #DESIGN PRESSURE: ATMB. #DURATION: #1 DAY FOR EACH TANK. #PRE-BID SITE INSPECTION: #THE CONTRACTOR MUST VISIT THE SITE AND BECOME FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, AND COMPLEXITIES BEFORE SUBMITTING THE BID. DEWA WILL NOT ACCEPT ANY CLAIMS FOR ADDITIONAL COSTS BEYOND THE AGREED RATES/PRICES</p>	2	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DURING AND AFTER THE EXECUTION OF THE WORK.D.#QUALIFICATION OF BIDDER:#THE BIDDER MUST HAVE PROVEN EXPERIENCE WITH SIMILAR JOBS IN DEWA OR OTHER WELL-KNOWN COMPANIES.#ALL INSPECTIONS MUST BE CONDUCTED BY AN AUTHORIZED API INSPECTOR.#NDE IF REQUIRED MUST BE DONE CARRIED OUT BY AN EIAC ACCREDITED CONTRACTOR.#PERSONNEL PERFORMING NDE SHALL MEET THE QUALIFICATIONS IDENTIFIED AS ASME V AND API 653. THE RESULTS OF ANY NDE WORK MUST BE CONSIDERED IN THE EVALUATION OF THE TANK BY AN AUTHORIZED INSPECTOR.E.#SCOPE OF WORK.#COLLECT DATA ON THE ORIGINAL DESIGN AND FABRICATION PRACTICES, MATERIALS OF CONSTRUCTION, AND SERVICE HISTORY BEFORE THE SITE INSPECTION.#PREPARE INSPECTION TEST PROTOCOL (ITP)#ITP SHALL HAVE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NECESSARY INSPECTION-RELATED INFORMATION DETAILING ALL THE COMPONENTS/STRUCTURES WITHOUT ANY EXCEPTION AS PER API 653.#SUBMIT ITP TO DEWA.#MOBILIZE PERSONNEL AND EQUIPMENT WITHIN 01 DAY OF RECEIVING ADVANCE NOTICE.#OBTAIN PTW (PERMIT TO WORK) / LC (LINE CLEARANCE) FROM DEWA.#THE FOLLOWING DOCUMENTS ARE TO BE SUBMITTED TO OBTAIN PTW, O#METHOD STATEMENT#RI SK ASSESSMENT OF THE WORK#TOOLBOX TALK REPORT.#ENSURE WORK AREA IS CORRECTLY SECURE AND SAFE TO WORK IN ALL ASPECTS.#CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT.#IF THE WORKING ENVIRONMENT IS SAFE, THEN PROCEED WITH THE FOLLOWING STEPS.#MOBILIZE THE API AUTHORIZED INSPECTOR WITH SUITABLE INSPECTION TOOLS, PPES AND CONSUMABLES, ETC. FOR INSPECTION.#ALL EQUIPMENTS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>T NECESSARY TO EXECUTE INSPECTION AND MEASUREMENT SHALL BE IN THE SCOPE OF THE CONTRACTOR.#CARRY OUT EXTERNAL IN-SERVICE INSPECTION AS PER API 653.#THE EXTERNAL CONDITION OF THE TANK SHALL BE MONITORED BY CLOSE VISUAL INSPECTION FROM THE GROUND.#THIS IN-SERVICE INSPECTION SHALL INCLUDE</p> <p>1.#A VISUAL INSPECTION OF THE TANK'S EXTERIOR SURFACES.2.#EVIDENCE OF LEAKS; SHELL DISTORTIONS; SIGNS OF SETTLEMENT; CORROSION; AND CONDITION OF THE FOUNDATION, PAINT COATINGS, INSULATION IF APPLICABLE.3.#SYSTEMS, AND APPURTENANCES SHOULD BE DOCUMENTED FOR FOLLOW-UP ACTION BY AN AUTHORIZED INSPECTOR.#INSPECT THE FOLLOWING, BUT NOT LIMITED TO</p> <p>#FOUNDATION #SHELL #SHELL APPURTENANCES (LIKE MANWAYS, NOZZLES, TANK PIPING MANIFOLD SETC.) #ROOF #PIPELINES, VALVES AND EXPANSION JOINTS CONNECTED TO</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TANK.#DEWA ENGI NEER SHALL BE CONSULTED IN CASE OF ANY INDICATION OF DAMAGE.#DE-MOBILIZE MEN AND EQUIPMENT AFTER COMPLETION OF THE JOB.#INSPECTION REPORT TO BE SUBMITTED TO DEWA WITHIN 02 DAYS AFTERINSPECTION.#INSPECTION REPORT SHALL INCLUDE THE FOLLOWING INFORMATION, BUT NOTLI MITED TO,O#DATE OF INSPECTION.O#TYPE OF INSPECTIONO#SCOPE OF INSPECTION.O#EXTERNAL INSPECTION CHECKLIST AS PER API 653O#DESCRIPTION OF THE TANK (NUMBER, SIZE, CAPACITY, YEAR CONSTRUCTED,MATERIALS OF CONSTRUCTION, SERVICE HISTORY, ROOF AND BOTTOM DESIGN,ETC.)O#LIST OF COMPONENTS INSPECTED, AND CONDITIONS FOUND#INSPECTION METHODS AND TESTS USED AND RESULTS OF EACH INSPECTIONMETHOD OR TEST. REQU IREMENTS FOR REPAIR OR MAINTENANCE (IF ANY)O#A TIME FRAME FOR THE NEXT INSPECTION</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BASED ON INSPECTION AND IN LINE WITH API 653.0#SETTLEMENT SURVEY MEASUREMENTS AND ANALYSIS (IF PERFORMED) O#NAME, COMPANY, API 653 CERTIFICATION NUMBER AND SIGNATURE OF THE AUTHORIZED INSPECTOR RESPONSIBLE FOR THE INSPECTION. O#DRAWINGS, PHOTOGRAPHS, NDE REPORTS, AND OTHER PERTINENT INFORMATION SHALL BE APPENDED TO THE REPORT. O#API INSPECTOR RECOMMENDATIONS. #SAFETY: #A WORK PERMIT IS ALWAYS REQUIRED. #A SAFETY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED IN METHODS TO BE USED. RISK ASSESSMENT AND METHOD OF STATEMENT TO BE REVIEWED PRIOR TO STARTING THE INSPECTION. #ENSURE AN ADEQUATE RISK ASSESSMENT HAS BEEN CONDUCTED AND DOCUMENTED TO MINIMIZE ALL RECOGNIZED RISKS BEFORE STARTING ANY ACTIVITY. #PPE SHOULD BE ALWAYS USED. #BEFORE STEPPING ON</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TOP OF THE ROOF OF A CONE-ROOF TANK A VISUAL CHECKSHALL BE MADE FOR EXTERNAL CORROSION OR H OLES. USE A HAMMER TO CHECK THEROOF BEFORE ENTERING.#REGULAR HOUSEKEEPING SHALL BE MAINTAINED. DISPOSAL OF ANY HAZARDOUSMATERIALS SHALL BE DONE ACCORDING TO DUBAI MUNICIPALITY#S RULES ANDREGULATIONS.#THE DAILY TOOLBOX MEETING SHALL BE CONDUCTED TO DESCRIBE AND DISCUSS SAFETY RELATED ISSUES.#WHEN HANDLING ANY PRODUCT, A COPY OF THE RELEVANT MSDS MUST BEAVAILABLE AT WORK SITE.#AFTER HEARING THE SITE EMERGENCY SIREN OR ALL PERSONNEL SHOULD STOPTHE WORK AND LEAVE THE TANK IMMEDIATELY. THE SITE EMERGENCY PROCEDURES MUST THEN BE FOLLOWED.#ANY FIRE INCIDENT AT SITE SHALL BE REPORTED IMMEDIATELY.#REPORT ANY INCIDENTS, SPILLS, NEAR MISSES AND UNSAFE ACTS SH</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ALL BEREPORTEED IMMEDIATELY.#ALL SITE WORK SHALL BE UNDER CONTINUOUS DEWA CONTINUES SUPERVISION.G.#GENERAL TERMS & CONDITIONS.#THE CONTRACTOR MUST VISIT THE SITE AND BECOME FULLY FAMILIAR WITH THEWORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, AND SAFETY MEASUR ESBEFORE SUBMITTING THE BID.#THE CONTRACTOR MUST ENSURE DAILY HOUSEKEEPING AND IS RESPONSIBLE FORDISPOSING OF ALL WASTE MATERIALS I N DESIGNATED PLACES.#ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATIONS SHALL BEFOLLOWED AT WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR#SENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILE WORKING IN AHAZARDOUS AREA.#SCAFFOLDING IF REQUIRED SHALL BE ARRANGED BY DEWA BASED ON ADVANCENOTICE.#CRANE IF REQUIRED SHALL BE ARRANGED BY DEWA.#ALL RIGGING AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TRANSPORTING EQUIPMENT SHOULD BE ARRANGED BY THE CONTRACTOR. THIS EQUIPMENT SHOULD BE DULY TESTED AND CERTIFIED BY THE 3RD PARTY INSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCED ON DEMAND. QUALIFIED RIGGER, MECHANICS SHOULD BE PROVIDED. #THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PER QUALITY/SCHEDULE REQUIREMENT. #CONTRACTOR'S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THE PERIOD OF WORK. #ENTRY PERMITS FOR THE STAFF/WORKERS SHOULD BE APPLIED WITH PASSPORT COPIES HAVING VALID VISA. PEOPLE WHOSE NAMES ARE NOT AVAILABLE ON THE LIST WILL NOT BE ALLOWED TO ENTER THE POWERHOUSE. #ENTRY PERMITS FOR THE VEHICLE SHOULD BE APPLIED WITH COPY OF VEHICLE REGISTRATION. #DEWA WILL ARRANGE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NECESSARY PTW / LC.#THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE A SAFE WORKING CONDITION.#ALL THE PEOPLE SHOULD WEAR ALL THE REQUIRED PPE WHILE AT WORK.#ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT POWER STATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BY DEWAS SECURITY. THE COPIES OF THESE DOCUMENTS SHALL BE LODGED WITH DEWA ENGINEER IN-CHARGE ON DAILY BASIS. THIS DOCUMENT WILL BE THE BASIS FOR THE CLEARANCE (GATE PASS) TO TAKE THEM OUT ON COMPLETION OF THE JOB.#SERVICE AIR, ELECTRICITY AND WATER FOR WORK AT DEWA SITE. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO HAVE HIS OWN ARRANGEMENT IN EXTENDING THE ELECTRICITY AND WATER UTILITY TO HIS PLACES OF WORK INCLUDING LIGHTING.						
2		ITEM-00001	#IN-SERVICE / EXTERNAL INSPECTION OF JAPS	2	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CCCW HEAD TANK A & B80PGC91BB001 80PGC92BB001 IN COMPLIANCE WITH API 510 AT L 2 STATION,DEWA, JEBEL ALIA.#QUANTITY & SPECIFICATION:#CCCW HEAD TANK A & B.#QTY: 02 TANKS.#TANK SIZE: 2.8 METER Ø X 3.3 METER HIGH .#TANK TYPE: FIXED CONE ROOF ##CONSTRUCTION CODE: ASME SEC VIII DIV 1,2004 EDITION ADD 2005.#DESIGN PRESSURE: 145 PSIGB.#DURATION.# 1 DAY FOR EACH TANK						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

CCCW HEAD TANK EXTERNAL INSPECTION AS PER API 510 <(>&<)> MAKE UP WATER TANK A <(>&<)> B EXTERNAL INSPECTION AS PER API 653 FOR L2-
 MBR Contact ehab.bahour@dewa.gov.ae

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK L 2 STATION, JEBEL ALI POWER STATION TITLE: #IN-SERVICE / EXTERNAL INSPECTION OF JAPS MAKE UP WATER TANK # A & B80GCL21BB001&80GCL22B001 IN COMPLIANCE WITH API 653 AT L 2 STATION, DEWA, JEBEL ALIA. #QUANTITY & SPECIFICATION: #MAKE UP WATER TANK # A & B. #QTY: 02 TANKS. #TANK SIZE: 18 METER Ø X 17.2 METER HIGH. #TANK TYPE: FIXED CONE ROOF # VERTICAL ATMOSPHERIC STORAGE TANK. #DESIGN CODE: API STD 650, 10TH EDITION. #DESIGN PRESSURE: ATMB. #DURATION: #1 DAY FOR EACH TANK. #PRE-BID SITE INSPECTION: #THE CONTRACTOR MUST VISIT THE SITE AND BECOME FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, AND COMPLEXITIES BEFORE SUBMITTING THE BID. DEWA WILL NOT ACCEPT ANY CLAIMS FOR ADDITIONAL COSTS BEYOND THE AGREED RATES/PRICES</p>	2	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DURING AND AFTER THE EXECUTION OF THE WORK.D.#QUALIFICATION OF BIDDER:#THE BIDDER MUST HAVE PROVEN EXPERIENCE WITH SIMILAR JOBS IN DEWA OR OTHER WELL-KNOWN COMPANIES.#ALL INSPECTIONS MUST BE CONDUCTED BY AN AUTHORIZED API INSPECTOR.#NDE IF REQUIRED MUST BE DONE CARRIED OUT BY AN EIAC ACCREDITED CONTRACTOR.#PERSONNEL PERFORMING NDE SHALL MEET THE QUALIFICATIONS IDENTIFIED AS ASME V AND API 653. THE RESULTS OF ANY NDE WORK MUST BE CONSIDERED IN THE EVALUATION OF THE TANK BY AN AUTHORIZED INSPECTOR.E.#SCOPE OF WORK.#COLLECT DATA ON THE ORIGINAL DESIGN AND FABRICATION PRACTICES, MATERIALS OF CONSTRUCTION, AND SERVICE HISTORY BEFORE THE SITE INSPECTION.#PREPARE INSPECTION TEST PROTOCOL (ITP)#ITP SHALL HAVE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NECESSARY INSPECTION-RELATED INFORMATION DETAILING ALL THE COMPONENTS/STRUCTURES WITHOUT ANY EXCEPTION AS PER API 653.#SUBMIT ITP TO DEWA.#MOBILIZE PERSONNEL AND EQUIPMENT WITHIN 01 DAY OF RECEIVING ADVANCE NOTICE.#OBTAIN PTW (PERMIT TO WORK) / LC (LINE CLEARANCE) FROM DEWA.#THE FOLLOWING DOCUMENTS ARE TO BE SUBMITTED TO OBTAIN PTW, O#METHOD STATEMENT#RI SK ASSESSMENT OF THE WORK#TOOLBOX TALK REPORT.#ENSURE WORK AREA IS CORRECTLY SECURE AND SAFE TO WORK IN ALL ASPECTS.#CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT.#IF THE WORKING ENVIRONMENT IS SAFE, THEN PROCEED WITH THE FOLLOWING STEPS.#MOBILIZE THE API AUTHORIZED INSPECTOR WITH SUITABLE INSPECTION TOOLS, PPES AND CONSUMABLES, ETC. FOR INSPECTION.#ALL EQUIPMENTS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>T NECESSARY TO EXECUTE INSPECTION AND MEASUREMENT SHALL BE IN THE SCOPE OF THE CONTRACTOR.#CARRY OUT EXTERNAL IN-SERVICE INSPECTION AS PER API 653.#THE EXTERNAL CONDITION OF THE TANK SHALL BE MONITORED BY CLOSE VISUAL INSPECTION FROM THE GROUND.#THIS IN-SERVICE INSPECTION SHALL INCLUDE</p> <p>1.#A VISUAL INSPECTION OF THE TANK'S EXTERIOR SURFACES.2.#EVIDENCE OF LEAKS; SHELL DISTORTIONS; SIGNS OF SETTLEMENT; CORROSION; AND CONDITION OF THE FOUNDATION, PAINT COATINGS, INSULATION IF APPLICABLE.3.#SYSTEMS, AND APPURTENANCES SHOULD BE DOCUMENTED FOR FOLLOW-UP ACTION BY AN AUTHORIZED INSPECTOR.#INSPECT THE FOLLOWING, BUT NOT LIMITED TO</p> <p>#FOUNDATION #SHELL #SHELL APPURTENANCES (LIKE MANWAYS, NOZZLES, TANK PIPING MANIFOLD SETC.) #ROOF #PIPELINES, VALVES AND EXPANSION JOINTS CONNECTED TO</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TANK.#DEWA ENGI NEER SHALL BE CONSULTED IN CASE OF ANY INDICATION OF DAMAGE.#DE-MOBILIZE MEN AND EQUIPMENT AFTER COMPLETION OF THE JOB.#INSPECTION REPORT TO BE SUBMITTED TO DEWA WITHIN 02 DAYS AFTERINSPECTION.#INSPECTION REPORT SHALL INCLUDE THE FOLLOWING INFORMATION, BUT NOTLI MITED TO,O#DATE OF INSPECTION.O#TYPE OF INSPECTIONO#SCOPE OF INSPECTION.O#EXTERNAL INSPECTION CHECKLIST AS PER API 653O#DESCRIPTION OF THE TANK (NUMBER, SIZE, CAPACITY, YEAR CONSTRUCTED,MATERIALS OF CONSTRUCTION, SERVICE HISTORY, ROOF AND BOTTOM DESIGN,ETC.)O#LIST OF COMPONENTS INSPECTED, AND CONDITIONS FOUND#INSPECTION METHODS AND TESTS USED AND RESULTS OF EACH INSPECTIONMETHOD OR TEST. REQU IREMENTS FOR REPAIR OR MAINTENANCE (IF ANY)O#A TIME FRAME FOR THE NEXT INSPECTION</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BASED ON INSPECTION AND IN LINE WITH API 653.0#SETTLEMENT SURVEY MEASUREMENTS AND ANALYSIS (IF PERFORMED) O#NAME, COMPANY, API 653 CERTIFICATION NUMBER AND SIGNATURE OF THE AUTHORIZED INSPECTOR RESPONSIBLE FOR THE INSPECTION. O#DRAWINGS, PHOTOGRAPHS, NDE REPORTS, AND OTHER PERTINENT INFORMATION SHALL BE APPENDED TO THE REPORT. O#API INSPECTOR RECOMMENDATIONS. #SAFETY: #A WORK PERMIT IS ALWAYS REQUIRED. #A SAFETY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED IN METHODS TO BE USED. RISK ASSESSMENT AND METHOD OF STATEMENT TO BE REVIEWED PRIOR TO STARTING THE INSPECTION. #ENSURE AN ADEQUATE RISK ASSESSMENT HAS BEEN CONDUCTED AND DOCUMENTED TO MINIMIZE ALL RECOGNIZED RISKS BEFORE STARTING ANY ACTIVITY. #PPE SHOULD BE ALWAYS USED. #BEFORE STEPPING ON</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TOP OF THE ROOF OF A CONE-ROOF TANK A VISUAL CHECKSHALL BE MADE FOR EXTERNAL CORROSION OR H OLES. USE A HAMMER TO CHECK THEROOF BEFORE ENTERING.#REGULAR HOUSEKEEPING SHALL BE MAINTAINED. DISPOSAL OF ANY HAZARDOUSMATERIALS SHALL BE DONE ACCORDING TO DUBAI MUNICIPALITY#S RULES ANDREGULATIONS.#THE DAILY TOOLBOX MEETING SHALL BE CONDUCTED TO DESCRIBE AND DISCUSS SAFETY RELATED ISSUES.#WHEN HANDLING ANY PRODUCT, A COPY OF THE RELEVANT MSDS MUST BEAVAILABLE AT WORK SITE.#AFTER HEARING THE SITE EMERGENCY SIREN OR ALL PERSONNEL SHOULD STOPTHE WORK AND LEAVE THE TANK IMMEDIATELY. THE SITE EMERGENCY PROCEDURES MUST THEN BE FOLLOWED.#ANY FIRE INCIDENT AT SITE SHALL BE REPORTED IMMEDIATELY.#REPORT ANY INCIDENTS, SPILLS, NEAR MISSES AND UNSAFE ACTS SH</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE	
			<p>ALL BEREPORTEED IMMEDIATELY.#ALL SITE WORK SHALL BE UNDER CONTINUOUS DEWA CONTINUES SUPERVISION.G.#GENERAL TERMS & CONDITIONS.#THE CONTRACTOR MUST VISIT THE SITE AND BECOME FULLY FAMILIAR WITH THEWORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, AND SAFETY MEASURES BEFORE SUBMITTING THE BID.#THE CONTRACTOR MUST ENSURE DAILY HOUSEKEEPING AND IS RESPONSIBLE FOR DISPOSING OF ALL WASTE MATERIALS IN DESIGNATED PLACES.#ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATIONS SHALL BE FOLLOWED AT WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR#ENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILE WORKING IN AHAZARDOUS AREA.#SCAFFOLDING IF REQUIRED SHALL BE ARRANGED BY DEWA BASED ON ADVANCENOTICE.#CRANE IF REQUIRED SHALL BE ARRANGED BY DEWA.#ALL RIGGING AND</p>							

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TRANSPORTI NG EQUIPMENT SHOULD BE ARRANGED BY THECONTRACTOR. THIS EQUIPMENT SHOULD BE DULY TESTED AND CERTIFIED BY THE3RD PARTY INSPECTION AGEN CY AND THE CERTIFICATES SHOULD BE PRODUCED ONDEMAND. QUALIFIED RIGGER, MECHANICS SHOULD BE PROVIDED.#THE WORK SHALL BE EXECUTED UND ER DEWA SUPERVISION AND AS PERQUALITY/SCHEDULE REQUIREMENT.#CONTRACTOR#S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THEPERIOD OF WORK.#ENTRY PERMITS FOR THE STAFF/WORKERS SHOULD BE APPLIED WITH PASSPORTCOPIES HAVING VALID VISA. PEOPLE WHOSE NAMES ARE NOT A VAILABLE ON THELIST WILL NOT BE ALLOWED TO ENTER THE POWERHOUSE.#ENTRY PERMITS FOR THE VEHICLE SHOULD BE APPLIED WITH COPY OF VEHIC LEREGISTRATION.#DEWA WILL ARRANGE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NECESSARY PTW / LC.#THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE A SAFE WORKING CONDITION.#ALL THE PEOPLE SHOULD WEAR ALL THE REQUIRED PPE WHILE AT WORK.#ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT POWER STATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BY DEWAS SECURITY. THE COPIES OF THESE DOCUMENTS SHALL BE LODGED WITH DEWA ENGINEER IN-CHARGE ON DAILY BASIS. THIS DOCUMENT WILL BE THE BASIS FOR THE CLEARANCE (GATE PASS) TO TAKE THEM OUT ON COMPLETION OF THE JOB.#SERVICE AIR, ELECTRICITY AND WATER FOR WORK AT DEWA SITE. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO HAVE HIS OWN ARRANGEMENT IN EXTENDING THE ELECTRICITY AND WATER UTILITY TO HIS PLACES OF WORK INCLUDING LIGHTING.						
2		ITEM-00001	#IN-SERVICE / EXTERNAL INSPECTION OF JAPS	2	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CCCW HEAD TANK A & B80PGC91BB001 80PGC92BB001 IN COMPLIANCE WITH API 510 AT L 2 STATION,DEWA, JEBEL ALIA.#QUANTITY & SPECIFICATION:#CCCW HEAD TANK A & B.#QTY: 02 TANKS.#TANK SIZE: 2.8 METER Ø X 3.3 METER HIGH .#TANK TYPE: FIXED CONE ROOF ##CONSTRUCTION CODE: ASME SEC VIII DIV 1,2004 EDITION ADD 2005.#DESIGN PRESSURE: 145 PSIGB.#DURATION.# 1 DAY FOR EACH TANK						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

CCCW HEAD TANK EXTERNAL INSPECTION AS PER API 510 <(>&<)> MAKE UP WATER TANK A <(>&<)> B EXTERNAL INSPECTION AS PER API 653 FOR L2-
 MBR Contact ehab.bahour@dewa.gov.ae

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501657
DATE : 02.07.2025
REQ No : 1032503185
REQ TITLE : CCCW HEAD TANK
DELIVERY LOCATION
CLOSING DATE : 11.07.2025
CLOSING TIME : 10:00:00

- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP