

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501714  
**DATE** : 08.07.2025  
**REQ No** : 1032503218  
**REQ TITLE** : In-Service / External inspect  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK L 2 STATION,JEBEL ALI POWER STATIONTITLE:·#IN-SERVICE / EXTERNAL INSPECTION</p> <p>OF JAPS DFO TANK A &amp; B FOR EDG80XJN10BB001 &amp; 80XJN20BB001 IN COMPLIANCE WITH API 510 AT L 2 STATION,DEWA, DEWA, JEBEL ALIB.#QUANTITY &amp; SPECIFICATION:·#DFO TANK A &amp; B FOR EDG·#QTY: 02 TANKS·#TANK SIZE: 2.2 METER Ø X 6.27 METER LENGTH·#TANK TYPE: CYLINDER HORIZONTAL</p> <p>·#CONSTRUCTION CODE: ASME SEC VIII DIV 1,·#DESIGN PRESSURE: 1 BAR GC.#DURATION·#1 DAY FOR EACH TANKDFO TANK A FOR EDG#80XJN10BB001#J</p> <p>AN-26DFO TANK B FOR EDG#80XJN20BB001#JAN-26D.#PRE-BID SITE INSPECTION:·#THE CONTRACTOR MUST VISIT THE SITE AND BECOME FULLY FAMILIAR WITH THEWORK SCOPE, PLANT ACCESS, FACILITIES, AND COMPLEXITIES BEFORE SUBMITTINGTHE BID. DEWA WILL NOT ACCEPT ANY CLAIMS FOR ADDITI</p>	2	AU				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501714  
**DATE** : 08.07.2025  
**REQ No** : 1032503218  
**REQ TITLE** : In-Service / External inspect  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ONAL COSTS BEYOND THE AGREED RATES/PRICES DURING AND AFTER THE EXECUTION OF THE WORK.E.#QUALIFICATION OF BIDDER:#THE BIDDER MUST HAVE PROVEN EXPERIENCE WITH SIMILAR JOBS IN DEWA OR OTHER WELL-KNOWN COMPANIES.#ALL INSPECTIONS MUST BE CONDUCTED BY AN AUTHORIZED API INSPECTOR.#NDE IF REQUIRED MUST BE DONE CARRIED OUT BY AN EIAC ACCREDITED CONTRACTOR.#PERSONNEL PERFORMING NDE SHALL MEET THE QUALIFICATIONS IDENTIFIED AS ASME V AND API 510. THE RESULTS OF ANY NDE WORK MUST BE CONSIDERED IN THE EVALUATION OF THE TANK BY AN AUTHORIZED INSPECTOR.F.#SCOPE OF WORK.#COLLECT DATA ON THE ORIGINAL DESIGN AND FABRICATION PRACTICES, MATERIALS OF CONSTRUCTION, AND SERVICE HISTORY BEFORE THE SITE INSPECTION.#PREPARE INSPECTION TEST PROTOCOL (ITP)#ITP SHALL HAVE NECESSARY</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501714  
**DATE** : 08.07.2025  
**REQ No** : 1032503218  
**REQ TITLE** : In-Service / External inspect  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INSPECTION-RELATED INFORMATION  DETAILING ALLTHE COMPONENTS/STRUCTURES  WITHOUT ANY EXCEPTION AS PER API  510-#SUBMIT ITP TO DEWA-#MOBILIZE PERSONNEL  AND EQUIPMENT  WITHIN 01 DAY OF RECEIVING  ADVANCENOTICE-#OBTAIN PTW (PERMIT TO  WORK) / LC (LINE CLEARANCE) FROM DEWA-#THE  FOLLOWING DOCUMENTS ARE  TO BE SUBMITTED TO OBTAIN PTW,O#METHOD  STATEMENTO#RISK ASSESSMENT OF THE  WORKO#TOOLBOX TALK REPORT-#ENSURE WORK  AREA IS CORRECTLY  SECURE AND SAFE TO WORK IN ALL  ASPECTS-#CONDUCT SITE SURVEY AND SAFETY  INSPECTION TO ASSESS THE  WORKINGENVIRONMENT-#IF THE WORKING  ENVIRONMENT IS SAFE, THEN PROCEED WITH THE  FOLLOWINGSTEPS-#MOBILIZE THE API  AUTHORIZED INSPECTOR WITH SUITABLE  INSPECTION TOOLS,PP  ES AND CONSUMABLES, ETC. FOR  INSPECTION-#ALL EQUIPMENT NECESSARY TO</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501714  
**DATE** : 08.07.2025  
**REQ No** : 1032503218  
**REQ TITLE** : In-Service / External inspect  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			EXECUTE INSPECTION AND MEASUREMENT SHALL BE IN THE SCOPE OF THE CONTRACTOR. #CARRY OUT EXTERNAL IN-SERVICE INSPECTION AS PER API 510. #THE EXTERNAL CONDITION OF THE TANK SHALL BE MONITORED BY CLOSE VISUAL INSPECTION FROM THE GROUND. #THIS IN-SERVICE INSPECTION SHALL INCLUDE. 1. #A VISUAL INSPECTION OF THE TANK'S EXTERIOR SURFACES 2. #EVIDENCE OF LEAKS; SHELL DISTORTIONS; SIGNS OF SETTLEMENT; CORROSION; AND CONDITION OF THE FOUNDATION, PAINT COATINGS, INSULATION IF APPLICABLE 3. #SYSTEMS, AND APPURTENANCES SHOULD BE DOCUMENTED FOR FOLLOW-UP ACTION BY AN AUTHORIZED INSPECTOR. #INSPECT THE FOLLOWING, BUT NOT LIMITED TO #FOUNDATION #SHELL #SHELL APPURTENANCES (LIKE MANWAYS, NOZZLES, TANK PIPING MANIFOLD SETC.) #PIPELINES, VALVES						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501714  
**DATE** : 08.07.2025  
**REQ No** : 1032503218  
**REQ TITLE** : In-Service / External inspect  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			, AND EXPANSION JOINTS CONNECTED TO TANK.#DEWA ENGINEER SHALL BE CONSULTED IN CASE OF ANY INDICATION OF DAMAGE.#DE-MOBILIZE MEN AND EQUIPMENT AFTER COMPLETION OF THE JOB.#INSPECTION REPORT TO BE SUBMITTED TO DEWA WITHIN 02 DAYS AFTER INSPECTION.#INSPECTION REPORT SHALL INCLUDE THE FOLLOWING INFORMATION, BUT NOT LIMITED TO, O#DATE OF INSPECTION.O#TYPE OF INSPECTIONO#SCOPE OF INSPECTION.O#EXTERNAL INSPECTION CHECKLIST AS PER API 510O#DESCRIPTION OF THE TANK (NUMBER, SIZE, CAPACITY, YEAR CONSTRUCTED, MATERIALS OF CONSTRUCTION, SERVICE HISTORY, ROOF AND BOTTOM DESIGN, ETC.)O#LIST OF COMPONENTS INSPECTED, AND CONDITIONS FOUND O#INSPECTION METHODS AND TESTS USED AND RESULTS OF EACH INSPECTION METHOD OR TEST. REQUIREMENTS FOR REPAIR OR MAINTENANCE (IF ANY)O#A TIME FRAME FOR THE						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501714  
**DATE** : 08.07.2025  
**REQ No** : 1032503218  
**REQ TITLE** : In-Service / External inspect  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NEXT INSPECTI ON BASED ON INSPECTION AND IN LINEWITH API 510.O#SETTLEMENT SURVEY MEASUREMENTS AND ANALYSIS (IF PERFORMED)O#NAME, COMPANY, API 510 CERTIFICATION NUMBER AND SIGNATURE OF THEAUTHORIZED INSPECTOR RESPONSIBLE FOR THE INSPECTION.O#DRAWINGS, PHOTOGRAPHS, NDE REPORTS, A ND OTHER PERTINENT INFORMATIONSHALL BE APPENDED TO THE REPORT.O#API INSPECTOR RECOMMENDATIONSG.#SAFETY:.#A WORK PERMIT IS ALWAYS REQ UIRED.#A SAFETY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED INMETHODS TO BE USED. RISK ASSESSMENT AND METHOD OF STATEMENT TO BEREVIEWED PRIOR TO STARTING THE INSPECTION.#THE USE OF CAMERAS AND OTHER ELECTRONIC EQUIPMENT (NON-INTRINSICALLYSAFE) IS NOT PERM ITTED UNLESS AUTHORIZED BY MANAGEMENT AND UNDER THESTRICT #PERMIT TO WORK#</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501714  
**DATE** : 08.07.2025  
**REQ No** : 1032503218  
**REQ TITLE** : In-Service / External inspect  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONDITIONS-#ENSURE AN ADEQUATE RISK ASSESSMENT HAS BEEN CONDUCTED AND DOCUMENTED TO MINIMIZE ALL RECOGNIZED RISKS BEFORE STARTING ANY ACTIVITY-#PPE SHOULD BE ALWAYS USED-#NON SPARKING TOOLS AND EQUIPMENT SHALL BE USED-#BEFORE STEPPING ON TOP OF THE ROOF OF A CONE-ROOF TANK A VISUAL CHECK SHALL BE MADE FOR EXTERNAL CORROSION OR HOLES. USE A HAMMER TO CHECK THE ROOF BEFORE ENTERING-#REGULAR HOUSEKEEPING SHALL BE MAINTAINED. DISPOSAL OF ANY HAZARDOUS MATERIALS SHALL BE DONE ACCORDING TO DUBAI MUNICIPALITY'S RULES AND REGULATIONS-#THE DAILY TOOLBOX MEETING SHALL BE CONDUCTED TO DESCRIBE AND DISCUSS SAFETY RELATED ISSUES-#WHEN HANDLING ANY PRODUCT, A COPY OF THE RELEVANT MSDS MUST BE AVAILABLE AT WORK SITE-#AFTER HEARING THE SITE EMERGENCY SIREN OR ALL</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501714  
**DATE** : 08.07.2025  
**REQ No** : 1032503218  
**REQ TITLE** : In-Service / External inspect  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PERSONNEL SHOULD STOP THE WORK AND LEAVE THE TANK IMMEDIATELY. THE SITE EMERGENCY PROCEDURES MUST THEN BE FOLLOWED. #ANY FIRE INCIDENT AT SITE SHALL BE REPORTED IMMEDIATELY. #REPORT ANY INCIDENTS, SPILLS, NEAR MISSES AND UNSAFE ACTS SHALL BE REPORTED IMMEDIATELY! #ALL SITE WORK SHALL BE UNDER CONTINUOUS DEWA CONTINUES SUPERVISION. #IF THE GAS DETECTOR ALARM SOUNDS, ALL PERSONNEL SHOULD LEAVE THE TANK IMMEDIATELY. #GENERAL TERMS &amp; CONDITIONS #THE CONTRACTOR MUST VISIT THE SITE AND BECOME FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, AND SAFETY MEASURES BEFORE SUBMITTING THE BID. #THE CONTRACTOR MUST ENSURE DAILY HOUSEKEEPING AND IS RESPONSIBLE FOR DISPOSING OF ALL WASTE MATERIALS IN DESIGNATED PLACES. #ALL DEWA SAFETY &amp;</p>						



## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501714  
**DATE** : 08.07.2025  
**REQ No** : 1032503218  
**REQ TITLE** : In-Service / External inspect  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ENVIRONMENT POLICY, RULES AND REGULATIONS SHALL BE FOLLOWED AT WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR#SENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILE WORKING IN AHAZARDOUS AREA.#SCAFFOLDING IF REQUIRED SHALL BE ARRANGED BY DEWA BASE D ON ADVANCENOTICE.#CRANE IF REQUIRED SHALL BE ARRANGED BY DEWA.#ALL RIGGING AND TRANSPORTING EQUIPMENT SHOULD BE ARRANGED BY THE CONTRACTOR. THIS EQUIPMENT SHOULD BE DULY TESTED AND CERTIFIED BY THE3RD PARTY INSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCED ONDEMAND. QUALIFIED RIGGER, MECHANICS SHOULD BE PROVIDED.#THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PERQUALITY/SCHEDULE REQUIREMENT.#CONTRACTOR#SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THEPERIOD OF WORK.#ENTRY</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501714  
**DATE** : 08.07.2025  
**REQ No** : 1032503218  
**REQ TITLE** : In-Service / External inspect  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PERMITS FOR THE STAFF/ WORKERS SHOULD BE APPLIED WITH PASSPORTCOPIES HAVING VALID VISA. PEOPLE WHOSE NAMES ARE NOT AVAILABLE ON THELIST WILL NOT BE ALLOWED TO ENTER THE POWERHOUSE.#ENTRY PERMITS FOR THE VEHICLE SHOULD BE APPLIED WITH COPY OF VEHICLEREGISTRATION.#DEWA WILL ARRANGE NECESSARY PTW / LC.#THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE A SAFE WORKING CONDITION.#ALL THE PEOPLE SHOULD WEAR ALL THE REQUIRED PPE WHILE AT WORK.#ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT POWER STATIONSECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BY DEWASECURITY. THE COPIES OF THESE DOCUMENTS SHALL BE LODGED WITH DEWAENGINEER IN-CHARGE ON DAILY BASIS. THIS DOCUMENT WILL BE THE BASIS FOR THE CLEARANCE (GATE PASS) TO TAKE THEM</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501714  
**DATE** : 08.07.2025  
**REQ No** : 1032503218  
**REQ TITLE** : In-Service / External inspect  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.07.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OUT ON COMPLETION OF THE JOB. #SERVICE AIR, ELECTR ICITY AND WATER FOR WORK AT DEWA SITE. IT IS THERESPONSIBILITY OF THE CONTRACTOR TO HAVE HIS OWN ARRANGEMENT INEXTENDING THE ELECTRI CITY AND WATER UTILITY TO HIS PLACES OF WORKINCLUDING LIGHTING.						
2		ITEM-00001	IN-SERVICE / EXTERNAL INSPECTION OF JAPS DFO RECIRCULATION TANK#80EGB20BB001 IN COMPLIANCE WITH API 653 AT L 2 STATION, DEWA, JEBEL A LIA.#QUANTITY & SPECIFICATION:#TANK NO.: DFO RECIRCULATION TANK-#QTY: 01 TANKS-#TANK SIZE: 7.880 M OD X 7.950 M HIGH-#TYPE OF TANK: RAFTER SUPPORTED FIXED CONE ROOF-#TANK CAPACITY (TOTAL): 22800 CU. M-#DESIGN CODE: API 650 (10TH EDITION) + ADD. 4-#DESIGN PRESSURE : ATMB.#DURATION-#1 DAY-#DFO RECIRCULATION TANK#80EGB20BB001#NOV-2025	1	AU				

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page11 of 13

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501714  
**DATE** : 08.07.2025  
**REQ No** : 1032503218  
**REQ TITLE** : In-Service / External inspect  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.07.2025  
**CLOSING TIME** : 10:00:00

### **SPECIAL NOTES / INSTRUCTIONS:**

In-Service / External inspection of DFO Recirculation Tank in Compliance with API 653 <(>&<)> DFO Tank A <(>&<)> B for EDG in compliance with API 510 at L 2 Station,

Note: Site visit required  
Contact ehab.bahour@dewa.gov.ae

### **STANDARD TERMS & CONDITIONS**

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332501714  
**DATE** : 08.07.2025  
**REQ No** : 1032503218  
**REQ TITLE** : In-Service / External inspect  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.07.2025  
**CLOSING TIME** : 10:00:00

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**