

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502089
DATE : 18.08.2025
REQ No : 1032503919
REQ TITLE : Sealing of G Station (Siemens)
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	APPLICATION OF NEW SEALING OF GT ENCLOSURE FOR SIEMENS V94.2 GT, GSTATIONTHE GAS TURBINES OF G STATION ARE ENCLOSED IN SOUNDPROOF AIR-CONDITIONED ENCLOSURE. INTEGRITY OF THIS ENCLOSURE IS CRITICAL FOR FLOODED CO2 FIREPROTECTION SYSTEM ENVISAGED FOR THE GTS.THE ENCLOSED ENCLOSURES ARE CONSTRUCTED WITH STRUCTURAL FRAME MOUNTED WITH INSULATED CS-GALVANISED PANELS. THE PANEL JOINTS WITH FRAMES AND DOORS ARE SEALED WITH SEALING TAPES AND ALL OTHER GAPS AND VARIOUS OTHER SERVICE LINE PENETRATION HOLES ARE SEALED BY FIRE RETARDANT FOAM TO ENSURE A LEAK TIGHT ENCLOSURE REQUIRED FOR CO2 PROTECTION SYSTEM.CURRENTLY INTEGRITY OF THE ENCLOSURE IS AFFECTED BY DEGRADED SEALS DUE TO AGING AND UNEVEN SEALING SURFACES OF THE PANELS DUE TO REPEATED DISMANTLING AND REERECTION OF THE ENCLOSURE OF THE PANELS.	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502089
DATE : 18.08.2025
REQ No : 1032503919
REQ TITLE : Sealing of G Station (Siemens)
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DEWA WANT EDRESTORE INTEGRITY OF THE ENCLOSURE BY APPLICATION OF NEW SEALS FOR THEENTIRE ENCLOSURE PANEL SEALING SURFACES.BIDDERS WITH PREVIOU S EXPERIENCE WITH SIMILAR WORKS WILL BE PREFERRED.THE SCOPE OF WORKS ARE EXPLAINED BELOW BUT NOT LIMITED TO;1.#REMOVE THE EXISTING S EALS FROM THE PANEL AND STRUCTURE AND CLEAN THEJOINT SURFACE.2.#DISMANTLING OF THE OF THE ENCLOSURE PANELS WITH PROPERIDENTIFICATION NUMBERING TO ENABLE RE-INSTALLATION IN THE SAME LOCATION3.#MINOR REPAIR OF THE PANELS LIKE LEVELLING OF THE UNEVEN SEALINGSURFACE A ND CORRECTION OF THE PANEL FIXTURES CLAMPS TO ENSURE PROPERSEATING OF THE PANELS TO FRAME.4.#TOUCH UP PAINTING OF THE ANY CORRODED A REA IF ANY ON THE STRUCTUREOR PANEL.5.#SUPPLY OF NEW FIRE-RETARDANT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502089
DATE : 18.08.2025
REQ No : 1032503919
REQ TITLE : Sealing of G Station (Siemens)
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SEALING TAPES LIKE EXISTING ONES FOR THE COMPLETE ENCLOSURE PANEL .6.#REMOVING EXISTING FOAM SEALANTS (WHEREVER DAMAGED) FROM THE EXISTING ENTRY HOLES.7.#SUPPLY OF FIRE-RETARDANT FOAM SEALANT TO SEAL GAPS AND PIPE/DUCT/CABLE HOLES OF THE ENCLOSURE8.#RE-ERECT THE ENCLOSURE PANELS WITH APPLICATION OF NEW SEALING TAPES.ENSURE TIGHT SEALING OF THE JOINT SURFACE BETWEEN STRUCTURAL FRAME AND ENCLOSURE PANEL9.#APPLY FOAM SEALANT ON PIPE/DUCT/CABLE HOLES AND GAPS ON THE ENCLOSURE.10.#CARRY OUT SMOKE TEST AND CORRECT THE SEALING WHEREVER SMOKE LEAKS ARE OBSERVED ON THE ENCLOSURE11.##TO ASSESS THE QUANTITY OF THE WORKS, A COPY OF THE AS BUILT DRAWING OF THE ENCLOSURE IS ATTACHED WITH THIS ENQUIRY.12.#THE WORK MUST BE CARRIED ALONG WITH MAJOR OVERHAUL SCHEDULED DURING THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502089
DATE : 18.08.2025
REQ No : 1032503919
REQ TITLE : Sealing of G Station (Siemens)
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SAME TIME. HENCE WORKS HAS TO BE DONE IN COORDINATION WITH OTHERPARTIES WORKING IN SAME AREA.</p> <p>13.#BIDDER TO SPECIFY THE EXPECTED DURATION OF THE WORKS IN THE BID.14.#THE DATA SHEET OF THE PROPOSED TAPE AND FOAM SEALS SHALL BEP</p> <p>ROVIDED ALONG WITH BID FOR THE DEWA REVIEW AND APPROVAL.15.#TO AVOID DELAYS OVERHAULING WORKS, PANEL REMOVAL MAY BE PARTIALLYDONE BY</p> <p>DEWA. HOWEVER COMPLETE RE-ERECTION WILL BE DONE BY THE BIDDER.16.#OBJECTIVE OF THE REPAIR WORKS TO ESTABLISH INTEGRITY OF THEENCLOS</p> <p>URE THROUGH DOOR-FAN TEST . BIDDERS WHO CAN DO DOOR FAN TEST CANQUOTE FOR DOOR-FAN TEST AS AN OPTIONAL ITEM.FOR MOR INFORMATION PLEA</p> <p>SE CONTACT: EISA ALHASMI</p> <p>050-2706066/DAVIS052-2068441/LIAKOT 055-8085126</p>						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page4 of 6

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502089
DATE : 18.08.2025
REQ No : 1032503919
REQ TITLE : Sealing of G Station (Siemens)
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SPECIAL NOTES / INSTRUCTIONS:

Sealing of G Station (Siemens 2000E gas turbine) Enclosure - Jebel Ali Power Station. The job is to be done as per the actual approved outage schedule.

For any clarification please contact: Eisa 050-2706066/Davis 052-2068441

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502089
DATE : 18.08.2025
REQ No : 1032503919
REQ TITLE : Sealing of G Station (Siemens)
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP