

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502152
DATE : 21.08.2025
REQ No : 1032503895
REQ TITLE : Battery 1032503895 / 945-46
DELIVERY LOCATION
CLOSING DATE : 27.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>BATTERY CELL REGENERATION AND REPLACEMENT FOR SBH865-1 AT VARIOUSSUBSTATIONOBJECTIVE:THE OBJECTIVE OF THIS PROJECT IS TO REGENERATE AVAILABLE SBH865-1BATTERY FROM CENTRAL STORE AND UTILIZE AS REPLACEMENT OF FAULTY CELLSIDENTIFIED DURING BATTERY CAPACITY TEST AT VA</p> <p>RIOUS SUBSTATION.BATTERY DETAILS:MAKE: SAFTTYPE: SBH865-1CAPACITY: 865AHNUMBER OF BATTERIES: 70PROJECT OVERVIEWREGENERATION OF BATTE</p> <p>RY CELLS SBH65 OF SAFT MAKES TO BE USED ASREPLACEMENT FOR THE FAULTY CELLS AT SITE.SCOPE OF WORK:1.#BATTERY CELL REGENERATION TO BE TAKEN FROM CENTRAL STORE.2.#REPLACEMENT WORK AT SITE (LOCATION AS PER ATTACHED).3.#SCRAPPING OF FAULTY CELLS AT DEWA RUWAYYA SCRAP Y</p> <p>ARD.REGENERATION OF BATTERY:.#VENDORS SHALL COLLECT THE BATTERY CELLS AT CENTRAL STORE FOR A TOTALOF 70 CELLS FOR</p>	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502152
DATE : 21.08.2025
REQ No : 1032503895
REQ TITLE : Battery 1032503895 / 945-46
DELIVERY LOCATION
CLOSING DATE : 27.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REGENERATION AT TH EIR FACILITY. #SUPPLY OF ELECTROLYTE WILL BE PROVIDED BY DEWA, HENCE, VENDOR TOQUANTIFY THE TOTAL REQUIREMENT BASED ON THE BATTERY D ETAILS PROVIDED ANDQUANTITY AND TO BE INFORMED TO TAM-PERFORMANCE PRIOR TO BATTERYCOLLECTION FOR GATEPASS AND OTHER REQUIRED DOCUMEN T PREPARATION.REPLACEMENT WORK AT SITE: #UPON SUCCESSFUL BATTERY REGENERATION, VENDORS SHALL REPLACED THEBATTERY CELLS AT RESPECTIVE SITES AS PER ANNEXURE1. #REMAINING REGENERATED CELLS WILL BE KEPT AND HANDED BACK TO CENTRALSTORE FOR STOCKING.DISPOSAL OF REMOVED BATTERY CELLS #THE DISPOSAL OF ALL REMOVED BATTERY CELLS SHALL BE PART OF THE SCOPEAND DISPOSED OF AS PER DEWA IMS POLICY AT DEWA SC RAP YARD. #THE VENDOR IS RESPONSIBLE FOR THE PROPER DISPOSAL OF ELECTROLYTE ASPER</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502152
DATE : 21.08.2025
REQ No : 1032503895
REQ TITLE : Battery 1032503895 / 945-46
DELIVERY LOCATION
CLOSING DATE : 27.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DM STANDARD. PLEASE NOTE THAT DEWA RUWAYYAH SCRAP YARD WILL ONLY ACCEPT EMPTY CELL FOR SCRAPPING. WARRANTY AND GUARANTEE.#ALL SERVICES UNDER THIS CONTRACT MUST BE GUARANTEED FOR TWO (2) YEARS FROM THE DATE OF FINAL ENERGIZATION. VENDOR RESPONSIBILITIES.#THE VENDOR SHALL BE RESPONSIBLE FOR ALL SUPPLY AND LOGISTICS, INCLUDING LOADING, UNLOADING, AND SHIFTING OF MATERIALS NECESSARY FOR THE WORK.#THE VENDOR SHALL ARRANGE ALL NECESSARY TOOLS AND INSTRUMENTS FOR EXECUTING THE JOB.#VENDOR SHALL OBTAIN THE ENTRY PERMIT (PERMIT TO WORK - PTW) APPROVAL FROM DEWA IN THE PRESCRIBED FORMAT PRIOR TO STARTING WORK.#UPON APPROVAL OF PTW, THE WORKS SHALL BE CARRIED OUT IN THE PRESENCE OF DEWA STAFF. HEALTH, SAFETY, AND SECURITY REQUIREMENTS.#SUCCESSFUL VENDORS						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502152
DATE : 21.08.2025
REQ No : 1032503895
REQ TITLE : Battery 1032503895 / 945-46
DELIVERY LOCATION
CLOSING DATE : 27.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MUST SUBMIT A SAMPLE METHOD STATEMENT, RISKASSESSMENT, AND OUTAGE REQUIREMENT TO DEWA. #THE MET HOD STATEMENT, RISK ASSESSMENT, AND OUTAGE REQUIREMENT FORSPECIFIC WORK SHALL BE SUBMITTED AT AN APPROPRIATE STAGE DURINGEXECUTION.</p> <p>#VENDORS SHALL FOLLOW ALL HEALTH & SAFETY REQUIREMENTS WHILE CARRYINGOUT THE JOB. #ONLY FULLY TRAINED AND QUALIFIED PERSONS WITH PRO PER PPE AND TESTEQUIPMENT SHALL PERFORM THE ACTIVITY. TESTING AND COMMISSIONING. #BATTERY TEST REPORT WILL BE PROVIDED TO DEWA TAM-PER FORMANCE PRIOR TOINSTALLATION AT SITE. THIS INCLUDES BATTERY CHARGE AND DISCHARGE TESTRESULT. BATTERY CELL REGENERATION AND REPLACEME</p> <p>NT FOR SBH865-1 AT VARIOUS SUBSTAOBJECTIVE: THE OBJECTIVE OF THIS PROJECT IS TO REGENERATE AVAILABLESBH865-1</p> <p>BATTERBATTERY DETAILS:</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502152
DATE : 21.08.2025
REQ No : 1032503895
REQ TITLE : Battery 1032503895 / 945-46
DELIVERY LOCATION
CLOSING DATE : 27.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MAKE: SAFT TYPE: SBH865-1 CAPACITY:865AH NUMBER OF BATTERIES: 70 PROJECT OVERVIEW REGENERATION OF BATTERYCELLS SBH65 OF SAFT MAKES T O BE USED AS REPLACEMENTSCOPE OF WORK: 1. 2. 3.REGENERATION OF BATTERY: # # REPLACEMENT WORK AT SITE: # # DISPOSAL OFREMOVED BATTERY CE LLS # # WARRANTY AND GUARANTEE # VENDORRESPONSIBILITIES # # # # HEALTH, SAFETY, AND SECURITY REQUIREMENTS # # ## TESTING AND COMMISS IONING #FOR ANY DETAILS PLEASE CONTACT NOEL ORCALES AMPER PHONE: 04-32-21701 #FAX: # MOBILE: +971523601282 EMAIL: NOEL.AMPER@DEWA.GO V.AE						
2		ITEM-00001	REPLACEMENT OF FAULTY CELLS - BANK 1	1	AU				
3		ITEM-00001	REPLACEMENT OF FAULTY CELLS - BANK 2	1	AU				
4		ITEM-00002	BATTERY CELL REGENERATION AND REPLACEMENT FOR SBH865-1 AT VARIOUSSUBSTATIONOBJECTIVE:THE OBJECTIVE OF THIS PROJECT IS TO REGENERATE	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502152
DATE : 21.08.2025
REQ No : 1032503895
REQ TITLE : Battery 1032503895 / 945-46
DELIVERY LOCATION
CLOSING DATE : 27.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AVAILABLE SBH865-1BATTERY FROM CENTRAL STORE AND UTILIZE AS REPLACEMENT OF FAULTY CELLS IDENTIFIED DURING BATTERY CAPACITY TEST AT VA</p> <p>RIOUS SUBSTATION.BATTERY DETAILS:MAKE: SAFTTYPE: SBH865-1CAPACITY: 865AHNUMBER OF BATTERIES: 70PROJECT OVERVIEWREGENERATION OF BATTERY CELLS SBH65 OF SAFT MAKES TO BE USED ASREPLACEMENT FOR THE FAULTY CELLS AT SITE.SCOPE OF WORK:1.#BATTERY CELL REGENERATION TO BE TAKEN FROM CENTRAL STORE.2.#REPLACEMENT WORK AT SITE (LOCATION AS PER ATTACHED).3.#SCRAPPING OF FAULTY CELLS AT DEWA RUWAYYA SCRAP Y</p> <p>ARD.REGENERATION OF BATTERY:#VENDORS SHALL COLLECT THE BATTERY CELLS AT CENTRAL STORE FOR A TOTAL OF 70 CELLS FOR REGENERATION AT TH</p> <p>EIR FACILITY.#SUPPLY OF ELECTROLYTE WILL BE PROVIDED BY DEWA, HENCE, VENDOR TO QUANTIFY THE TOTAL REQUIREMENT BASED ON</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502152
DATE : 21.08.2025
REQ No : 1032503895
REQ TITLE : Battery 1032503895 / 945-46
DELIVERY LOCATION
CLOSING DATE : 27.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE BATTERY D ETAILS PROVIDED AND QUANTITY AND TO BE INFORMED TO TAM-PERFORMANCE PRIOR TO BATTERY COLLECTION FOR GATEPASS AND OTHER REQUIRED DOCUMENT T PREPARATION. REPLACEMENT WORK AT SITE: #UPON SUCCESSFUL BATTERY REGENERATION, VENDORS SHALL REPLACE THE BATTERY CELLS AT RESPECTIVE SITES AS PER ANNEXURE 1. #REMAINING REGENERATED CELLS WILL BE KEPT AND HANDED BACK TO CENTRAL STORE FOR STOCKING. DISPOSAL OF REMOVED BATTERY CELLS #THE DISPOSAL OF ALL REMOVED BATTERY CELLS SHALL BE PART OF THE SCOPE AND DISPOSED OF AS PER DEWA IMS POLICY AT DEWA SC RAP YARD. #THE VENDOR IS RESPONSIBLE FOR THE PROPER DISPOSAL OF ELECTROLYTE AS PER DM STANDARD. PLEASE NOTE THAT DEWA RUWAYYAH SCRAP YARD WILL ONLY ACCEPT EMPTY CELL FOR SCRAPPING. WARRANTY AND GUARANTEE #ALL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502152
DATE : 21.08.2025
REQ No : 1032503895
REQ TITLE : Battery 1032503895 / 945-46
DELIVERY LOCATION
CLOSING DATE : 27.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SERVICES UNDER THIS CONTRACT MUST BE GUARANTEED FOR TWO (2) YEARS FROM THE DATE OF FINAL ENERGIZATION.VENDOR RESPONSIBILITIES.#THE VENDOR SHALL BE RESPONSIBLE FOR ALL SUPPLY AND LOGISTICS,INCLUDING LOADING, UNLOADING, AND SHIFTING OF MATERIALS NECESSARY FOR THE WORK.#THE VENDOR SHALL ARRANGE ALL NECESSARY TOOLS AND INSTRUMENTS FOR EXECUTING THE JOB.#VENDOR SHALL OBTAIN THE ENTRY PERMIT (PERMIT TO WORK - PTW) APPROVAL FROM DEWA IN THE PRESCRIBED FORMAT PRIOR TO STARTING WORK.#UPON APPROVAL OF PTW, THE WORKS SHALL BE CARRIED OUT IN THE PRESENCE OF DEWA STAFF.HEALTH, SAFETY, AND SECURITY REQUIREMENTS.#SUCCESSFUL VENDORS MUST SUBMIT A SAMPLE METHOD STATEMENT, RISK ASSESSMENT, AND OUTAGE REQUIREMENT TO DEWA.#THE METHOD STATEMENT, RISK ASSESSMENT, AND						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502152
DATE : 21.08.2025
REQ No : 1032503895
REQ TITLE : Battery 1032503895 / 945-46
DELIVERY LOCATION
CLOSING DATE : 27.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OUTAGE REQUIREMENT FOR SPECIFIC WORK SHALL BE SUBMITTED AT AN APPROPRIATE STAGE DURING EXECUTION.</p> <p>#VENDORS SHALL FOLLOW ALL HEALTH & SAFETY REQUIREMENTS WHILE CARRYING OUT THE JOB. #ONLY FULLY TRAINED AND QUALIFIED PERSONS WITH PROPER PPE AND TEST EQUIPMENT SHALL PERFORM THE ACTIVITY. TESTING AND COMMISSIONING. #BATTERY TEST REPORT WILL BE PROVIDED TO DEWA TAM-PERFORMANCE PRIOR TO INSTALLATION AT SITE. THIS INCLUDES BATTERY CHARGE AND DISCHARGE TEST RESULT. FOR ANY DETAILS PLEASE CONTACT NOEL ORC</p> <p>ALES AMPER PHONE: 04-32-21701 #FAX: # MOBILE: +971523601282 NOEL.AMPER@DEWA.GOV.AE</p>						
5		ITEM-00002	REPLACEMENT FOR FAULTY CELLS: BANK 1,2	1	AU				
6		ITEM-00002	REPLACEMENT FOR FAULTY CELLS: BANK 2,1	1	AU				
7		ITEM-00002	REPLACEMENT FOR FAULTY CELLS: BANK 2.2	1	AU				
8		ITEM-00003	BATTERY CELL REGENERATION AND REPLACEMENT FOR SBH865-1 AT	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502152
DATE : 21.08.2025
REQ No : 1032503895
REQ TITLE : Battery 1032503895 / 945-46
DELIVERY LOCATION
CLOSING DATE : 27.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>VARIOUS SUBSTATION OBJECTIVE: THE OBJECTIVE OF THIS PROJECT IS TO REGENERATE AVAILABLE SBH865-1 BATTERY FROM CENTRAL STORE AND UTILIZE AS REPLACEMENT OF FAULTY CELLS IDENTIFIED DURING BATTERY CAPACITY TEST AT VA</p> <p>VARIOUS SUBSTATION. BATTERY DETAILS: MAKE: SAFT TYPE: SBH865-1 CAPACITY: 865 AH NUMBER OF BATTERIES: 70 PROJECT OVERVIEW REGENERATION OF BATTERY CELLS SBH65 OF SAFT MAKES TO BE USED AS REPLACEMENT FOR THE FAULTY CELLS AT SITE. SCOPE OF WORK: 1. # BATTERY CELL REGENERATION TO BE TAKEN FROM CENTRAL STORE. 2. # REPLACEMENT WORK AT SITE (LOCATION AS PER ATTACHED). 3. # SCRAPPING OF FAULTY CELLS AT DEWA RUWAYYA SCRAP YARD. REGENERATION OF BATTERY: # VENDORS SHALL COLLECT THE BATTERY CELLS AT CENTRAL STORE FOR A TOTAL OF 70 CELLS FOR REGENERATION AT THE AIR FACILITY. # SUPPLY OF ELECTROLYTE WILL BE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502152
DATE : 21.08.2025
REQ No : 1032503895
REQ TITLE : Battery 1032503895 / 945-46
DELIVERY LOCATION
CLOSING DATE : 27.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PROVIDED BY DEWA, HENCE, VENDOR TOQUANTIFY THE TOTAL REQUIREMENT BASED ON THE BATTERY D</p> <p>ETAILS PROVIDED ANDQUANTITY AND TO BE INFORMED TO TAM-PERFORMANCE PRIOR TO BATTERYCOLLECTION FOR GATEPASS AND OTHER REQUIRED DOCUMEN</p> <p>T PREPARATION.REPLACEMENT WORK AT SITE:~UPON SUCCESSFUL BATTERY REGENERATION, VENDORS SHALL REPLACED THEBATTERY CELLS AT RESPECTIVE SITES AS PER ANNEXURE1.~REMAINING REGENERATED CELLS WILL BE KEPT AND HANDED BACK TO CENTRALSTORE FOR STOCKING.DISPOSAL OF REMOVED BATTERY CELLS~THE DISPOSAL OF ALL REMOVED BATTERY CELLS SHALL BE PART OF THE SCOPEAND DISPOSED OF AS PER DEWA IMS POLICY AT DEWA SC RAP YARD.~THE VENDOR IS RESPONSIBLE FOR THE PROPER DISPOSAL OF ELECTROLYTE ASPER DM STANDARD. PLEASE NOTE THAT DEWA RUWAYYAH SCRAP</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502152
DATE : 21.08.2025
REQ No : 1032503895
REQ TITLE : Battery 1032503895 / 945-46
DELIVERY LOCATION
CLOSING DATE : 27.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			YARD WILL ONLY ACCEPT EMPTY CELL FOR SCRAPPING. WARRANTY AND GUARANTEE.#ALL SERVICES UNDER THIS CONTRACT MUST BE GUARANTEED FOR TWO (2) YEARS FROM THE DATE OF FINAL ENERGIZATION. VENDOR RESPONSIBILITIES.#THE VENDOR SHALL BE RESPONSIBLE FOR ALL SUPPLY AND LOGISTICS, INCLUDING LOADING, UNLOADING, AND SHIFTING OF MATERIALS NECESSARY FOR THE WORK.#THE VENDOR SHALL ARRANGE ALL NECESSARY TOOLS AND INSTRUMENTS FOR EXECUTING THE JOB.#VENDOR SHALL OBTAIN THE ENTRY PERMIT (PERMIT TO WORK - PTW) APPROVAL FROM DEWA IN THE PRESCRIBED FORMAT PRIOR TO STARTING WORK.#UPON APPROVAL OF PTW, THE WORKS SHALL BE CARRIED OUT IN THE PRESENCE OF DEWA STAFF. HEALTH, SAFETY, AND SECURITY REQUIREMENTS.#SUCCESSFUL VENDORS MUST SUBMIT A SAMPLE METHOD STATEMENT, RISK ASSESSMENT, AND OUTAGE REQUIREMENT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502152
DATE : 21.08.2025
REQ No : 1032503895
REQ TITLE : Battery 1032503895 / 945-46
DELIVERY LOCATION
CLOSING DATE : 27.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TO DEWA.#THE MET HOD STATEMENT, RISK ASSESSMENT, AND OUTAGE REQUIREMENT FORSPECIFIC WORK SHALL BE SUBMITTED AT AN APPROPRIATE STAGE DURINGEXECUTION. #VENDORS SHALL FOLLOW ALL HEALTH & SAFETY REQUIREMENTS WHILE CARRYINGOUT THE JOB.#ONLY FULLY TRAINED AND QUALIFIED PERSONS WITH PRO PER PPE AND TESTEQUIPMENT SHALL PERFORM THE ACTIVITY.TESTING AND COMMISSIONING.#BATTERY TEST REPORT WILL BE PROVIDED TO DEWA TAM-PER FORMANCE PRIOR TOINSTALLATION AT SITE. THIS INCLUDES BATTERY CHARGE AND DISCHARGE TESTRESULT.FOR ANY DETAILS PLEASE CONTACT NOEL ORC ALES AMPERPHONE: 04-32-21701 # FAX: # MOBILE: +971523601282EMAIL: NOEL.AMPER@DEWA.GOV.AE						
9		ITEM-00003	REPLACEMENT OF FAULTY CELLS NO. 15,44,81	1	AU				
10		ITEM-00003	REPLACEMENT OF FAULTY CELLS NO. 2,17,29,69	1	AU				
11		ITEM-00003	REPLACEMENT OF FAULTY CELLS NO.	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502152
DATE : 21.08.2025
REQ No : 1032503895
REQ TITLE : Battery 1032503895 / 945-46
DELIVERY LOCATION
CLOSING DATE : 27.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			8,12,58,73,53,81						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Battery Regeneration and Cell Replacement for JFZS, BKRA <(>&<)> LSTA
Please club PR Numbers 1032503945,1032503946 <(>&<)> 1032503895

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502152
DATE : 21.08.2025
REQ No : 1032503895
REQ TITLE : Battery 1032503895 / 945-46
DELIVERY LOCATION
CLOSING DATE : 27.08.2025
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP