

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332502296  
**DATE** : 11.09.2025  
**REQ No** : 1032504286  
**REQ TITLE** : FF system deluge valve overha  
**DELIVERY LOCATION**  
**CLOSING DATE** : 17.09.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORKAT M STATION, JEBEL ALI POWER STATIONTITLE: M STATION FF SYSTEM DELUGE VALVE OVERHAULING, WATER GONGOVERHAULING, STRAINERS INSPECTION, VALVES SERVICING/REPLACEMENT ANDTOUCH UP PAINTING.A.#QUANTITY &amp; SPECIFICAT ION:1.#M STATION LEB FOR HRSG BLDG. # 11 &amp; CABLE TUNNEL ZONE-70 FF SYSTEMDELUGE / STRAINER / VALVE YEARLY INSPECTION / SERVICING, (1 1SGC04AT001)2.#M STATION HRSG BURNER AREA # 11 FF SYSTEM DELUGE / STRAINER / VALVEYEARLY INSPECTION / SERVICING, (11SGC06AT001)3.#M STATION LEB FOR HRSG BLDG. # 12 &amp; CABLE TUNNEL ZONE-136 FF SYSTEMDELUGE / STRAINER / VALVE YEARLY INSPECTION / SERVICING, (12SGC04AT 001)4.#M STATION HRSG BURNER AREA # 12 FF SYSTEM DELUGE / STRAINER / VALVEYEARLY INSPECTION / SERVICING, (12SGC06AT001)5.#M</p>	1	LS				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332502296  
**DATE** : 11.09.2025  
**REQ No** : 1032504286  
**REQ TITLE** : FF system deluge valve overha  
**DELIVERY LOCATION**  
**CLOSING DATE** : 17.09.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>STATION LEB FOR HRSG BLDG. # 21 &amp; CABLE TUNNEL ZONE-207 FF SYSTEMDELUGE / STRAINER / VALVE YEARLY INSPECTION / SERVICING, (21SGC04AT001)6.#M STATION HRSG BURNER AREA # 21 FF SYSTEM DELUGE / STRAINER / VALVEYEARLY INSPECTION / SERVICING, (21SGC06AT001)7.#M STATION LEB FOR HRSG BLDG. # 22 &amp; CABLE TUNNEL ZONE-271 FF SYSTEMDELUGE / STRAINER / VALVE YEARLY INSPECTION / SERVICING, (22SGC04AT001)8.#M STATION HRSG BURNER AREA # 22 FF SYSTEM DELUGE / STRAINER / VALVEYEARLY INSPECTION / SERVICING, (22SGC06AT001)9.#M STATION LEB FOR HRSG BLD G. # 31 &amp; CABLE TUNNEL ZONE-342 FF SYSTEMDELUGE / STRAINER / VALVE YEARLY INSPECTION / SERVICING, (31SGC04AT001)10.#M STATION HRSG B URNER AREA # 31 FF SYSTEM DELUGE / STRAINER / VALVEYEARLY INSPECTION / SERVICING,</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332502296  
**DATE** : 11.09.2025  
**REQ No** : 1032504286  
**REQ TITLE** : FF system deluge valve overha  
**DELIVERY LOCATION**  
**CLOSING DATE** : 17.09.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			(31SGC06AT001)11.#M STATION HRSG BURNER AREA # 32 FF SYSTEM DELUGE / STRAINER / VALVE YEARLY INSPECTION / SERVICING, (32SGC06AT001)12.#M STATION LEB FOR GTG UNIT # 11 & CABLE TUNNEL Z ONE-43 FF SYSTEM DELUGE / STRAINER / VALVE YEARLY INSPECTION / SERVICING, (11SGC08AT001)13.#M STATION LEB FOR GTG UNIT # 12 & CABLE T UNNEL ZONE-97 FF SYSTEM DELUGE / STRAINER / VALVE YEARLY INSPECTION / SERVICING, (12SGC08AT001)14.#M STATION LEB FOR GTG UNIT # 21 & CABLE TUNNEL ZONE-180 FF SYSTEM DELUGE / STRAINER / VALVE YEARLY INSPECTION / SERVICING, (21SGC08AT001)15.#M STATION LEB FOR GTG UNIT # 31 & CABLE TUNNEL ZONE-315 FF SYSTEM DELUGE / STRAINER / VALVE YEARLY INSPECTION / SERVICING, (31SGC08AT001)16.#M STATION LEB FOR CENTRAL HVAC & M&E STORAGE BLDG.						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332502296  
**DATE** : 11.09.2025  
**REQ No** : 1032504286  
**REQ TITLE** : FF system deluge valve overha  
**DELIVERY LOCATION**  
**CLOSING DATE** : 17.09.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TRANSFORMER 1 &amp;2 FF SYSTEM DELUGE / STRAINER / VALVE YEARLY INSPECTION / SERVICING,(00SGC84AT001)17</p> <p>.#M STATION GTG TRANSFORMERS # 11 FF SYSTEM DELUGE / STRAINER / VALVEYEARLY INSPECTION / SERVICING, (11SGC00AT001) (STEP UP TRANSFOR</p> <p>MER, UAT1&amp; UAT2)18.#M STATION GTG TRANSFORMERS # 21 FF SYSTEM DELUGE / STRAINER / VALVEYEARLY INSPECTION / SERVICING, (21SGC00AT001)</p> <p>19.#M STATION GTG TRANSFORMERS # 12 FF SYSTEM DELUGE / STRAINER / VALVEYEARLY INSPECTION / SERVICING, (12SGC00AT001)20.#M STATION GT</p> <p>G TRANSFORMERS # 22 FF SYSTEM DELUGE / STRAINER / VALVEYEARLY INSPECTION / SERVICING, (22SGC00AT001)21.#M STATION GTG TRANSFORMERS #</p> <p>31 FF SYSTEM DELUGE / STRAINER / VALVEYEARLY INSPECTION / SERVICING, (31SGC00AT001)22.#M STATION GTG TRANSFORMERS # 32 FF SYSTEM DE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332502296  
**DATE** : 11.09.2025  
**REQ No** : 1032504286  
**REQ TITLE** : FF system deluge valve overha  
**DELIVERY LOCATION**  
**CLOSING DATE** : 17.09.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>LUGE / STRAINER / VALVE YEARLY INSPECTION / SERVICING, (32SGC00AT001)23.#M STATION CABLE TUNNEL, F.D. ZONE - 672 &amp; 673 FF SYSTEM DELUGE / STRAINER / VALVE YEARLY INSPECTION / SERVICING, (00SGC33AT001)24.#M STATION LEB FOR GPRS FF SYSTEM DELUGE / STRAINER / VALVE YEARLY INSPECTION / SERVICING, (00SGC73AT001)NOTE: SCOPE OF WORK MENTIONED HERE ONLY PROVIDES A BROAD OUTLINE OF THE TASK. THE BIDDER MUST REVIEW THE ADEQUACY OF THE PROPOSED SCOPE OF WORK TO CARRY OUT THE REQUIRED TASKS AND ADD ANY ADDITIONAL WORK THAT IS NEEDED FOR SATISFACTORY COMPLETION OF THIS PROJECT.B.#DURATION:##EACH SYSTEM TO BE COMPLETED IN 01 DAYC.#SCHEDULE##WORK TO BE STARTED IMMEDIATELY AFTER PO##01-DAY ADVANCE NOTICE WILL BE GIVEN.D.#PRE-BID SITE INSPECTION:##THE CONTRACTOR SHALL VISIT THE SITE AND MAKE THEMSELVES F</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332502296  
**DATE** : 11.09.2025  
**REQ No** : 1032504286  
**REQ TITLE** : FF system deluge valve overha  
**DELIVERY LOCATION**  
**CLOSING DATE** : 17.09.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ULLYFAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES,ETC., BEFORE SUBMITTING THE BID. DEWA WILL NOT ACCEPT ANY C</p> <p>LAIM FOREXTRAS BEYOND THE ORDER RATES / PRICES DURING AND AFTER THE EXECUTION OFWORK ORDERED.E.#QUALIFICATION OF BIDDER:##THE BIDDER</p> <p>MUST HAVE PROVEN EXPERIENCE WITH SIMILAR JOBS IN DEWA OROTHER WELL-KNOWN COMPANIES.F.#SCOPE OF WORK:##MOBILIZE MEN/EQUIPMENT WITHIN</p> <p>01 DAY OF ADVANCE NOTICE.##SUBMIT FOLLOWING DOCUMENTS TO OBTAIN</p> <p>PTW,A.#METHOD STATEMENTB.#RISK ASSESSMENT OF THE WORKC.#TOOLBOX TAL K REPORT.##OBTAIN LC (LINE CLEARANCE) FROM DEWA.##CONDUCT SITE SURVEY AND SAFETY INSPECTION, TO ASSESS THE WORKINGENVIRONMENT.##ENSU</p> <p>RE THE SITE IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALLRESPECTS.##IF THE WORKING ENVIRONMENT IS SAFE, PROCEED WITH THE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332502296  
**DATE** : 11.09.2025  
**REQ No** : 1032504286  
**REQ TITLE** : FF system deluge valve overha  
**DELIVERY LOCATION**  
**CLOSING DATE** : 17.09.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FOLLOWING STEPS.##BARRICADE THE AREA WITH SIGNAGE.##ENSURE PROPER ISOLATION OF THE LINE BEFORE START OF WORK.##DISMANTLE MAIN HEADER STRAINER , CLEAN AND BOX UP WITH NEW GASKET.##DISMANTLE STRAINERS IN THE DELUGE VALVE SYSTEM, CLEAN AND BOX UP.##REMOVE PIPE FITTINGS AS REQU IRED FOR DISMANTLING THE DELUGE VALVES.##DISMANTLE DELUGE VALVES, CLEAN ALL INTERNALS &amp; INSPECT FOR ANYABNORMALITY.##DISMANTLE WATER GONG, CLEAN ALL INTERNALS &amp; INSPECT FOR ANYABNORMALITY##INFORM DEWA FOREMAN/ENGINEER IF ANY ABNORMALITY OR DEFECT ISOBSERVED.##REPL ACE DIAPHRAGM AND SEAT IF REQUIRED.##BOX UP THE DELUGE VALVES.##BOX UP WATER GONG.##CARRY OUT EASING, LUBRICATION AND SERVICING OF A LL OTHER VALVES.##ANY VALVE IN THE DELUGE SYSTEM IF FOUND PASSING / HARD TO OPERATE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332502296  
**DATE** : 11.09.2025  
**REQ No** : 1032504286  
**REQ TITLE** : FF system deluge valve overha  
**DELIVERY LOCATION**  
**CLOSING DATE** : 17.09.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>/DEFECTIVE, IT SHALL BE REPLACED.##INSPECT FOR A REA WHERE PAINT IS DAMAGED, CLEAN THE SURFACE(MECHANICAL CLEANING) AND CARRY OUT TOUCH UP PAINTING.##FOR ANY HOT WORK LIKE GRINDING OR BUFFING ENSURE HWP IS OBTAINEDBEFORE START OF WORK.##AFTER WORK COMPLETION, WITNESS FF SYSTEM CHARGING AND IF THERE IS ANYISSUE T HEN TROUBLESHOOT ALONG WITH DEWA FOREMAN / ENGINEER &amp; RECTIFY IFANY DEFECTS.##LARGE UMBRELLA WITH STAND TO BE PROVIDED FOR THE TECHN ICIANS WORKINGIN OPEN AREA FOR SHADE.##A QUALIFIED JOB SUPERVISOR SHALL BE ASSIGNED FOR THE JOB.##SKILLED TECHNICIANS SHALL CARRY OU T ALL THE JOBS.##HOUSEKEEPING AND DISPOSAL OF WASTE TO BE DONE DAILY BEFORE SITECLEARANCE.##DE-MOBILIZE MEN AND EQUIPMENT AFTER COMP LETION OF THE JOB.##WORK COMPLETION</p>						



## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332502296  
**DATE** : 11.09.2025  
**REQ No** : 1032504286  
**REQ TITLE** : FF system deluge valve overha  
**DELIVERY LOCATION**  
**CLOSING DATE** : 17.09.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REPORTS TO BE SUBMITTED CONTAINING DETAILS OF ALLWORK CARRIED OUT, SPARES USED, AND ANY DEFECTS FOUND DURING SYSTEMCHARGING. THE REPORT SHALL ALSO CONTAIN RELEVANT PHOTOS.##ALL TOOLS &amp; TACKLES ARE IN THE CONTRACTOR#S SCOPE.##PRO</p> <p>PER AND TESTED TOOLS TO BE USED.##ALL LIFTING &amp; POWER TOOLS SHALL HAVE A VALID 3RD PARTY TESTCERTIFICATE.##DEWA</p> <p>SCOPE:A.#SPARESB.#PA</p> <p>INT##NOTE: SCOPE OF WORK MENTIONED HERE ONLY PROVIDES A BROAD OUTLINE OFTHE TASK. THE BIDDER MUST REVIEW THE ADEQUACY OF THE PROPOSE</p> <p>D SCOPE OFWORK TO CARRY OUT THE REQUIRED TASKS AND ADD ANY ADDITIONAL WORK THAT ISNEEDED FOR SATISFACTORY COMPLETION OF THIS PROJECT</p> <p>.G.#WARRANTY##THE WARRANTY PERIOD FOR THE WORK SHALL BE 01 YEAR FROM THE DATE OFCOMPLETION OF WORK CERTIFIED BY DEWA.##IN CASE OF AN</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332502296  
**DATE** : 11.09.2025  
**REQ No** : 1032504286  
**REQ TITLE** : FF system deluge valve overha  
**DELIVERY LOCATION**  
**CLOSING DATE** : 17.09.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			Y DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THIS CONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND AND CARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN A SHORT PERIOD. H.#SAFETY, HEALTH AND ENVIRONMENT##THE CONTRACTOR SHALL COMPLY WITH ALL THE REQUIREMENTS STIPULATED IN THE FOLLOWING OHS DOCUMENT FROM DEWA FOR HEALTH, SAFETY AND ENVIRONMENTAL REQUIREMENTS DURING THE EXECUTION OF THE PROJECT. O#IMSP01 # SP 06 # H&S PROCEDURE FOR CONTRACTOR AND CONSULTANT O#IMSP01 # SP 15 # CONTROL OF SUBSTANCES HAZARDOUS TO HEALTH (COSHS) O#JAPS/H-18 # ENVIRONMENTAL MANAGEMENT SYSTEM PROCEDURE##THE CONTRACTOR'S WORK WILL FALL WITHIN THE PURVIEW OF SAFETY SURVEYS CONDUCTED REGULARLY BY THE DEWA SAFETY SECTION. ALL THEIR SAFETY REQUIREMENTS SHALL BE PROMPTLY						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332502296  
**DATE** : 11.09.2025  
**REQ No** : 1032504286  
**REQ TITLE** : FF system deluge valve overha  
**DELIVERY LOCATION**  
**CLOSING DATE** : 17.09.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MET. THE CONTRACTOR SHALL CHECK THE CONDITIONS SUITABLE FOR CARRYING OUT THE WORK CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT.##NO WASTAGES SHALL BE LEFT ON THE GROUND OR IN ANY AREA BEING PART OF THE CONTRACTOR'S WORK AREA.##SUGGESTED TO USE TARP						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### SPECIAL NOTES / INSTRUCTIONS:

FF system deluge valve overhauling, water gong overhauling, strainers inspection, valves servicing/replacement and touch up painting at M Station, Jabel ali. For queries contact Mr Anton  
anton.jacob@dewa.gov.ae

### STANDARD TERMS & CONDITIONS

1) Prices should be 'DDP' delivery duty paid at DEWA stores.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332502296  
**DATE** : 11.09.2025  
**REQ No** : 1032504286  
**REQ TITLE** : FF system deluge valve overha  
**DELIVERY LOCATION**  
**CLOSING DATE** : 17.09.2025  
**CLOSING TIME** : 10:00:00

- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**