

RFQ NUMBER : 2332502322

DATE : 16.09.2025

REQ No : 1032504040

REQ TITLE : 1- KWSG:NFS-640 panel

DELIVERY LOCATION

CLOSING DATE : 22.09.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SCOPE OF WORK FOR REPLACEMENT OF FIRE	1	AU				
			ALARM PANELS IN KSWG						
			132KVSUBSTATION1.#REMOVAL OF EXISTING						
			FAULTY NOTIFIER, USA MAKE NFS 640						
			OBSOLETE FIREALARM CONTROL						
			PANEL.2.#SUPPLY, INSTALLATION, AND						
			COMMISSIONING OF DEWA-TP						
			APPROVEDNOTIFIER, USA FIELD COMPATIBLE FIRE						
			A						
			LARM CONTROL PANEL.3. NFS 640 BURNED						
			POWER SUPPLY TO BE REPAIRED AND INSTALLED						
			ANDCOMMISSION IN ITWN SUBSTATION.DEFECT AT						
			S						
			ITE : FACP AC FAIL FAULT IS PERSISTING SINCE						
			THE INBUILTPOWER SUPPLY IS BURNEDTHE						
			CONTRACTOR#S SCOPE ALSO INCLUDES, BUT NOT						
			LIMITED						
			TO THE FOLLOWINGS.1.#REQUIRED						
			MODIFICATIONS AND ADDITION OF CABLING TO						
			ACCOMMODATE NEWCONTROL PANEL.2.#DEWA						
			PTW AND HEALTH AND SAFET						
			Y PROCEDURES TO BE FOLLOWED3.#NEW CABLE						
			SHALL BE OF FP 200 FIRE RATED CABLE. USE GI						



RFQ NUMBER : 2332502322

DATE : 16.09.2025

REQ No : 1032504040

REQ TITLE : 1- KWSG:NFS-640 panel

DELIVERY LOCATION

CLOSING DATE : 22.09.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONDUITS FOROUTSIDE AREAS AND WHEREVER						
			REQUIR						
			ED.4.#IF REQUIRED, REPLACEMENT OF FIELD						
			DEVICES TO MAKE COMPATIBLE WITHNEW FIRE						
			ALARM CONTROL PANEL.5.#RELATED CIVIL						
			WORKS, IF ANY.6						
			.#ALL TOOLS, SCAFFOLDINGS AND LADDERS						
			REQUIRED FOR INSTALLATION.7.#PANEL DRAWING						
			AND SCHEMATIC DRAWING OF THE INSTALLATION						
			SHALL BES						
			UBMITTED FOR APPROVAL.8.#CAUSE AND EFFECT						
			PROGRAMMING AND TESTING OF ALL FIELD						
			DEVICES TO BEDONE BY NOTIFIER CERTIFIED						
			ENGINEER9.#SU						
			PPLY OF FIRE ALARM CONTROL PANEL SOFTWARE						
			AND SOFTWARE TRAINING.10.#OPERATION AND						
			MAINTENANCE TRAINING AT SITE.11.#AS BUILT						
			DRAWING,						
			O&M AND SAT TO BE PROVIDED.12.#INSTALLATION						
			AND TESTING TO BE CARRIED OUT BY DEWA						
			APPROVEDENGINEER13.#24 MONTHS WARRANTY						
			FOR SUPPLY						
			COMPONENTS AND SYSTEM.14. 6 MONTHS						





RFQ NUMBER : 2332502322

DATE : 16.09.2025

REQ No : 1032504040

REQ TITLE : 1- KWSG:NFS-640 panel

DELIVERY LOCATION

CLOSING DATE : 22.09.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WARRANTY FOR NFS 640 REPAIRED.FOR SITE VISIT AND ENTRY PERMIT, CONTACT THE FOLLOWING ENGIN EERS1. SHERIEF C HAMZA [MOB:0529219010] . 2.						
			AND ENTRY PERMIT, CONTACT THE FOLLOWING						

TOTAL AMOUNT IN WORDS: TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

1- KWSG:NFS-640 panel replacement

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.



RFQ NUMBER : 2332502322

DATE : 16.09.2025

REQ No : 1032504040

REQ TITLE : 1- KWSG:NFS-640 panel

DELIVERY LOCATION

CLOSING DATE : 22.09.2025

CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS:

SUPPLIER'S SIGNATURE AND STAMP