

RFQ NUMBER : 2332502654

DATE : 20.10.2025

REQ No : 1032504820

REQ TITLE : 1-Calibration & TG Instrument

DELIVERY LOCATION

CLOSING DATE : 24.10.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SPECIALIST SERVICE FROM THE OEM (M/S. GE GLOBAL SERVICE) FORCONFIGURATION, ADJUSTMENT/SETTINGS & CALIBRATION OF TURBINE HP & LPSTEAM INLET CONTROL VALVES (SPEED/LOAD GOVERNOR VALVES) RELATED TOE-STATION STEAM TURBINE-06(ST-6).THERE ARE TWO HP & TWO LP STEAM CONTRO L VALVES INSTALLED INST-6. FOR HP: E3MAA11AA011 & E3MAA12AA011. FOR LP: E3MAA21AA011 &E3MAA22AA011.SCOPE OF THE SERVICE ARE AS FOLLO WING:1. STROKING THE ABOVE CONTROL VALVES (DURING TURBINE SHUTDOWN) ANDRECORDING ALL NECESSARY READINGS (PRIOR TO CARRYING OUT ANY C ALIBRATIONACTIVITIES). IF REQUIRED, DATA CAN BE COLLECTED FROM SYSTEM WHEN TURBINEIN SERVICE AS WELL.2. PERFORMING ALL NECESSARY ADJ USTMENTS, SETTINGS & CALIBRATIONS (ONVICKER MODULES & LVDT'SETC). ANY SETTING & CALIBRATION SHOULD BEACCORDING	2	DAY				



RFQ NUMBER : 2332502654

DATE : 20.10.2025

REQ No : 1032504820

REQ TITLE : 1-Calibration & TG Instrument

DELIVERY LOCATION

CLOSING DATE : 24.10.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TO SPECIFIC MANUFAC						
			TURING DESIGN OF ST-6.3. RE-STROKING OF						
			CONTROL VALVES AFTER CALIBRATIONS AND						
			RECORDING ALLPARAMETERS TO ENSURE						
			PROPER VALVES PERFOR						
			MANCE.4. ATTENDING THE STARTUP (UP TO FSNL						
			& AT FULL LOAD) TO ENSURE						
			SMOOTHPERFORMANCE & RESPONSE OF TURBINE						
			SPEED/LOAD GOVERNOR (WH						
			ICH SHOULD BEMATCHING WITH OEM						
			RECOMMENDATION).SCOPE OF DEWA:A.						
			PROVIDING GATEPASSES, SHUTDOWN, STARTUP,						
			LCETCB. PROVIDING VICKER						
			AMPLIFIER MODULES, VICKER PROPORTIONAL						
			VALVES,LVDT'S.C. ANY NECESSARY ACTIVITIES						
			RELATED TO CONTROL SYSTEM.NOTES:A. THE						
			CALIBRATION						
			S SHALL BE DONE ON NEW VICKERS MODULES.						
			THE EXISTINGVICKER MODULES NOT TO BE						
			DISTURBED.B. IT IS NOT RECOMMENDED TO						
			CHANGE THE EXISTI						
			NG SETTINGS/PARAMETERS INGOVERNOR						
			CONTROL SYSTEM UNLESS ITS REALLY						



RFQ NUMBER : 2332502654

DATE : 20.10.2025

REQ No : 1032504820

REQ TITLE : 1-Calibration & TG Instrument

DELIVERY LOCATION

CLOSING DATE : 24.10.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NECESSARY.C. THE FINAL PAYMENT WILL BE						
			BASED ON ACTUAL WORKING DA						
			YS AT SITE.ST-6 TURBINE TECHNICAL						
			DETAILS:MANUFACTURER: ABBMACHINE NUMBER:						
			GM01704TYPE: DKZ1-1N31COMMISSIONING DATE:						
			1996RATED TERMI						
			NAL OUTPUT: 112 MWPEAK LOAD: 123 MWNOMINAL						
			LIVE STEAM PRESSURE: 60 BAR ABSMAXIMUM LIVE						
			STEAM PRESSURE: 69.7 BAR ABSLIVE STEAM						
			TEMPER						
			ATURE: 520 DEG. CRATED SPEED: 3000						
			RPMDIRECTION OF ROTATION: CLOCKWISESINGLE						
			CASING HP/LP TURBINEEXISTING TURBINE						
			GOVERNOR CONTROL S						
			YSTEM: ABB PROCONTROL P13 (TURBOTROL6).						
			THIS SYSTEM WILL BE REPLACED WITH ABB S+ SD						
			CONTROL SYSTEM IN APRIL2026.FOR MORE						
			TECHNICAL I						
			NFORMATION KINDLY CONTACT FOLLOWING						
			STAFF:MR. SEYED ESMAEEL (055-1442323,						
			SAYED.HOSEYNI@DEWA.GOV.AE)MR. KARIM						
			ELGAMASY (052-4844344,						
			KARIM.ELGAMASY@DEWA.GOV.AE)		1				



RFQ NUMBER : 2332502654

DATE : 20.10.2025

REQ No : 1032504820

REQ TITLE : 1-Calibration & TG Instrument

DELIVERY LOCATION

CLOSING DATE : 24.10.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
2		ITEM-00001	OEM (M/S. GE GLOBAL SERVICE) SPECIALIST	2	DAY				
			SERVICE FOR:1. IMPLEMENTATION OF						
			RECOMMENDATION (AS PER GE FIELD SERVICE						
			REPORTCFSR-M-GM/202						
			50325) WHICH IS RELATED TO INSTRUMENTATION						
			PART OF TURBINE(ST-6) TURNING GEAR.2.						
			ADJUSTMENT/SETTINGS OF TURNING GEAR PINION						
			POSITION						
			FEEDBACK SENSOR(IF NEEDED).3. INSTALLATION						
			& SETTING OF PROXIMITY SWITCH FOR INDICATION						
			OF TURNINGGEAR ENGAGEMENT.NOTE:THE FINAL						
			PA						
			YMENT WILL BE BASED ON ACTUAL WORKING						
			DAYS AT SITE.FOR MORE TECHNICAL						
			INFORMATION KINDLY CONTACT FOLLOWING						
			STAFF:MR. SEYED ESMAEEL (
			055-1442323, SAYED.HOSEYNI@DEWA.GOV.AE)MR.						
			KARIM ELGAMASY (052-4844344,						
			KARIM.ELGAMASY@DEWA.GOV.AE)						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

1-Calibration <(>&<)> TG Instruments



RFQ NUMBER : 2332502654

DATE : 20.10.2025

REQ No : 1032504820

REQ TITLE : 1-Calibration & TG Instrument

DELIVERY LOCATION

CLOSING DATE : 24.10.2025

CLOSING TIME : 10:00:00

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6)Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.



RFQ NUMBER : 2332502654

DATE : 20.10.2025

REQ No : 1032504820

REQ TITLE : 1-Calibration & TG Instrument

DELIVERY LOCATION

SUPPLIER'S REMARKS:

SUPPLIER'S SIGNATURE AND STAMP