

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	COMPLETE OVERHAULING OF BOOSTER PUMP OF NAD AL SHEBA PUMPING STATION.PUMP DETAILS: MAKE- CLYDEUNION, MODEL-SDK 400/600, CAPACITY-526 L/SEC,HEAD-66M, RPM-980.PLEASE CONTACT MR. NOOR UDDIN (04-3229439) FOR FURTHER CLARIFICATION.1.0#SCOPE OF WORKTHE SCOPE OF WORK (MANDATORY & OPTIONAL) FOR THE OVERHAUL OF BOOSTERPUMPS AND THEIR ACCESSORIES OF BOOSTER PUMPING STATION.#A)#THE CONTRACTOR HAS TO TAKE THE PUMP ASSEMBLY FROM DEWA SITE TO THEIRWORKSHOP & VICE VERSA. DEWA SHALL NOT PROVIDE ANY TRANSPORT TO SHIFT THESAME. FOR LOADING & UNLOADING CONTRACTOR CAN USE DEWA OVERHEAD CRANEAVAILABLE AT PUMPING STATIONS IN COORDINATION WITH THE DEWAREPRESENTATIVES.B)#MECHANICAL SEAL REPLACEMENT, COUPLING BUSH RENEWAL & GLAND PACKINGRENEWAL, BEARING REPLACEMENT AS REQUIRED.C)#OVERHAULING	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OF PUMP (SEE A NNEXURE I-MANDATORY & II-OPTIONAL)D)#PAINTING OF PUMP EXTERNALLYE)#RECTIFICATION OF THE PUMP FOR ANY COMPLAINT ROSE AFTER INSTALLATI ON.F)#IF ANY PART IS FOUND DEFECTIVE, THE CONTRACTOR HAS TO REPAIR/REPLACETHE SAME. AVAILABLE SPARE SHALL BE SUPPLIED BY DEWA. IF AN Y SPARE IS NOTAVAILABLE WITH DEWA THE CONTRACTOR HAS TO ARRANGE THE SAME. ADDITIONALCOST OF SPARE TO BE SUBMITTED TO DEWA FOR APPROV AL BEFORE PLACING THEORDER.2.0#PRIOR TO SUBMISSION OF QUOTATION, THE FOLLOWING SHALL BE DETERMINEDCAREFULLY:A)#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WORK SCOPE, PLANT ACCESS FACILITIES, COMPLEXITIES, ETC., BEFORESUBMITTING THE QUOTATION.B)#DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			/PRICES DURING AND AFTER THE EXECUTION OF WORK ORDERE D.C)#THE CONTRACTOR WILL BE PROVIDED WITH THE EQUIPMENT SHUTDOWN PROGRAMIN COORDINATION WITH OPERATION & MAINTENANCE DEPARTMENT OF W ATERDIVISION.D)# THE CONTRACTOR SHOULD SUBMIT THE TIME SCHEDULE /BAR CHARTINDICATING EACH ACTIVITY.E)#ON COMPLETION OF THE WORK, THE INSPECTION CHECKLIST OF QUALITYPROCEDURES, WHEREVER APPLICABLE SHOULD BE FILLED IN AND SUBMITTED.F)#SITE SUPERVISION, CO-ORDINATION OF FIELD ACTIVITIES, SUPPLY OFREQUIRED TECHNICIANS, TOOLS, EQUIPMENTS, TACKLES ETC. REQUIRED FOREXECUTION OF THE CONTRACT WORKS SHA LL BE SUITABLY CONSIDERED.4.0#TAKE OVERON COMPLETION OF ALL WORK WITHIN THE SCOPE OF THE CONTRACT, FORACCEPTANCE OF THE MAINTENANCE WORK, CONTRACTOR SHALL NOTIFY DEWA						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			IN WRITING. A CERTIFICATE OF COMPLETION WILL BE ISSUED BY DEWA ON FINAL INSPECTION ONLY WHEN THE CONTRACT WORK IS DEEMED TO HAVE BEEN TAKEN OVER BY DEWA AFTER NECESSARY CONDITION MONITORING CHECKS WHEREVER & WHENEVER REQUIRED. 5.0# WARRANTY A) # ALL THE WORK CARRIED OUT SHALL CARRY A WARRANTY FOR 8000 HOURS OF OPERATION OR 1 YEAR WHICHEVER IS EARLIER. B) # THE GUARANTEE WILL TAKE EFFECT FROM THE DATE OF TAKEOVER BY DEWA OF THE JOB CARRIED OUT BY THE CONTRACTOR. C) # WHEN A DEFECT IS NOTICED DURING THE PERIOD OF WARRANTY, THE CONTRACTOR MUST RECTIFY THE DEFECT WITHIN A REASONABLE AMOUNT OF TIME FIXED BY DEWA WITH NO CLAIM OR COMPENSATION. 6.0# DOCUMENTS: # ON SATISFACTORY COMPLETION OF THE WORK & HANDING OVER, THE CONTRACTOR SHOULD SUBMIT THE FOLLOWING TO DEWA.						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			##A)#INSPECTION REPORT.B)#OVERHAUL REPORT.C)#JOB COMPLETION REPORT FOR JOBS OTHER THAN ROUTINE INSPECTION &OVERHAULSD)##AS-FITTED# BILL OF MATERIALS FOR CONSUMPTION OF SPARESE)#REQUISITION FOR PLANNING OF SPARES BY DEWA BASED ON CURRENTCONDITION OF THE EQUIPMENT FOR WHICH MAINTENANCE WORK WAS TAKEN UP.ANNEXURE # IDetail SCOPE OF WORK (MANDATORY)FOR OVERHAUL THE BOOSTER PUMP OF P UMPING STATIONS.L.NO#ACTIVITY#REMARKS#01#DISMANTLING OF THE PUMP#DISMANTLING OF THE PUMP AS PER DEWA ENGINEER#S INSTRUCTION###PUMP S HALL BE REMOVED AS PER SEQUENCE WITH SKILLED WORKMANSHIP &CARE.#02#OVERHAULING OF PUMP#THE CONTRACTOR SHALL DISMANTLE THE COMPLETERO TATING ASSEMBLY AT THEIR WORKSHOP AND RECORD ALL FINDINGS IN A TRACKSHEET WITH						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PHOTOGRAPHS OF DETERIORATED COMPONENTS.####THE CONTRACTOR HAS TO CHECK FOR SHAFT STRAIGHTNESS AND IDENTIFYWORN-OUT AREAS IF ANY. RECONDITIONING OF THE SHAFT SHALL BE CARRIED OUTIN COMPLIANCE WITH THE LATEST STANDARDS & PROCEDURES.####THE CONTRACTOR HAS TO CHECK THE IMPELLER THOROUGHLY FOR ANYRECONDITIONING REQUIRED. # ###BEARING CONDITION TO BE CHECKED & REPLACE THE BEARINGS IF REQUIRED.####MECHANICAL SEAL / GLAND SLEEVE CONDITION TO BE CHECKED & TO BEREPLACED IF REQUIRED.####WEAR RINGS DIMENSIONS TO BE CHECKED FOR CLEARANCE & TO BE REPLACEDIF REQUIRED.####IF ANY PART IS FOUND DEFECTIVE, THE CONTRACTOR HAS TO REPAIR/REPLACETHE SAME. AVAILABLE SPARE SHALL BE SUPPLIED BY DEWA. IF ANY SPARE IS NOTAVAILABLE WITH DEWA THE CONTRACTOR HAS TO ARRANGE THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SAME. ADDITIONALCOST OF SPARE TO BE SUBMITTED TO DEWA FOR APPROVAL BEFORE PLACING THEORDER.###P UMP CASING SHALL BE CLEANED & INSPECTED FOR ANY DAMAGES. IFREQUIRED DAMAGE SURFACE TO BE REQUIRED BY SANDBLASTING & COATING WITHFOOD GRADE EPOXY.#03#ASSEMBLY OF THE EQUIPMENT#ASSEMBLY OF THE EQUIPMENT TO BE CARRIEDOUT AS PER STANDARD PROCEDURE & MAINTAIN THE FIT & CLEARANCE AS PERMANUAL. ###DYNAMICALLY BALANCE THE ROTOR ASSEMBLY AS PER ISO1940/1 BALANCEQUALITY GRADE G 2.5/G1.0 WHEREVER POSSIBL E OR CHECK THE BALANCING OF THEINDIVIDUAL ITEMS.###PREPARE THE RECORD FOR THE ACTIVITIES CARRIED OUT.###DEVIATION TO THE SET #VALUES # SHALL BE DECIDED BY DEWA. #ANNEXURE # IIDETAIL SCOPE FOR MACHINING WORKS (OPTIONAL)SL.NO#ACTIVITY#REMARKS#01#IMPELLER MACHINING WO						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RKS#IMPELLER GRIT BLASTING & NDT TO FIND OUTANY CRACKS EXIST####IMPELLER SKIMMING ON BOTH SIDES OF WEAR RING AREAS & FIX NEW RINGAND SECURE#02#SHAFT MACHINING WORKS#SHAFT CHROME PLATING ON BEARING SEATING AREAS& MACHINING####SHAFT CHROME PLATING ON MECHANICAL SEAL S EATING AREAS & MACHINING####SHAFT WORN OUT PLACE METAL REBUILDING & MACHINING####SHAFT BEND STRAIGHTENING UP TO (4THOU) MAXIMUM BEND#0 3#BEARING HOUSING MACHINING WORKS#DE BEARING HOUSING BORE MACHINING & RESLEEING####NDE BEARING HOUSING BORE MACHINING & RESLEEING# 04#MECHANICAL SEAL FACE#MACHINING AND REPAIRING OF PUMP TOP AND BOTTOMCASINGS HALVES ON MECHANICAL SEAL FACE#05#PUMP CASINGS#SKIMMIN G AND GROOVING OF BOTH SUCTION AND DISCHARGEFLANGES ON PUMP CASING#06#CONSUMABLE ACCESSORIES &						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FITTINGS#MANUFACTURING OF MECHANICAL SEALCOOLING PIPE-FITTINGS, SHAFT LOCK NUT, LOCK WASHER AND RETAINING RING,DOWELL PINS, BEARING SPACER, HOLDING DOWN BOLTS AND BEARIN G HOUSINGGASKETS ETC. SUPPLY OF ALL TYPES OF O-RINGS.#7.0#MACHINING WORKS: ALL THE MACHINING WORKS SHALL BE CARRIED OUT INCOMPLIANCE WITH THE LATEST STANDARDS & PROCEDURES. PRIOR APPROVAL SHALLBE TAKEN FROM DEWA ENGINEER, BEFORE CARRYING OUT ANY KIND OF MACHININGW ORKS.						
2		ITEM-00001	MACHINING & ASSEMBLY OF PUMP CASE WEAR RING WITH COMPLETE PUMP ASSEMBLYNAS CLYDE PUMP.PLEASE CONTACT MR. NOOR (04-3229439) FOR FURTH ER CLARIFICATION.SCOPE OF WORKS:1. MACHINING & ASSEMBLY OF PUMP CASE WEAR RING2. MATERIAL & DIMENSIONS SHALL BE FOLLOWED AS PER SAMP LE3. TESTING OF THE ROTOR ASSEMBLY AFTER	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INSTALLATION OF CASE WEAR RING.4. PAYMENTS SHALL BE MADE BASED ON THE DEWA ENGINEER APPROVA L5. WARRANTY 1YEAR SHALL BE CONSIDERED AFTER INSTALLATION & TESTING OFTHE PUMP						
3		ITEM-00001	MACHINING & ASSEMBLY OF PUMP SHAFT SLEEVES WITH COMPLETE PUMP ASSEMBLYNAS CLYDE PUMP.PLEASE CONTACT MR. NOOR (04-3229439) FOR FURTHER CLARIFICATION.SCOPE OF WORKS:1. MACHINING & ASSEMBLY OF PUMP SHAFT SLEEVE2. MATERIAL & DIMENSIONS SHALL BE FOLLOWED AS PER SAMPLE3 . TESTING OF THE ROTOR ASSEMBLY AFTER INSTALLATION OF SHAFT SLEEVE4. PAYMENTS SHALL BE MADE BASED ON THE DEWA ENGINEER APPROVAL5. WARRANTY 1YEAR SHALL BE CONSIDERED AFTER INSTALLATION & TESTING OFTHE PUMP	2	EA				
4		ITEM-00001	PUMP SHAFT BOT DE & NDE SIDE REPAIRING FOR NAS CLYDE PUMP.PLEASE CONTACT MR. NOOR (04-3229439) FOR FURTHER CLARIFICATION.SCOPE OF W	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ORKS:1. PUMP SHAFT BOTH SIDE NDE & DE ANY KIND BEND STRAIGHTENING2. MATERIAL & DIMENSIONS SHALL BE FOLLOWED AS PER SAMPLE3. TESTING OF THE ROTOR ASSEMBLY AFTER INSTALLATION OF PUMP SHAFT4. PAYMENTS SHALL BE MADE BASED ON THE DEWA ENGINEER APPROVAL5. WARRANTY 1YEAR SHALL BE CONSIDERED AFTER INSTALLATION & TESTING OFTHE PUMP						
5		ITEM-00001	PUMP M/SEAL COOLING LINE FABRICATION & INSTALLATION FOR NAS CLYDE PUMPPLEASE CONTACT MR. NOOR (04-3229439) FOR FURTHER CLARIFICATIO N.SCOPE OF WORKS:1. PUMP M/SEAL COOLING LINE FABRICATION & INSTALLATION2. MATERIAL & DIMENSIONS SHALL BE FOLLOWED AS PER SAMPLE3. TE STING OF THE ROTOR ASSEMBLY AFTER INSTALLATION4. PAYMENTS SHALL BE MADE BASED ON THE DEWA ENGINEER APPROVAL5. WARRANTY 1YEAR SHALL B E CONSIDERED AFTER INSTALLATION & TESTING	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OF THE PUMP						
6		ITEM-00001	INTERNAL & EXTERNAL COATING OF BOOSTER PUMP OF NAS CLYDE PUMP PLEASE CONTACT MR. NOOR (04-3229439) FOR FURTHER CLARIFICATIONS. SCOPE OF WORKS: SPECIFICATION FOR INTERNAL COATING OF PUMPS/ VALVES GENERAL THESE PUMPS & VALVES ARE USED IN WATER BOOSTER PUMPING STATIONS. THE FLUID HANDLED BY THESE PUMPS IS POTABLE WATER OF MAXIMUM TEMPERATURE UP TO 50 °C. NORMALLY THE WATER IS CLEAN BUT SOME TIME IT IS NOTICED TO HAVE SAND AND SOLIDS IN STREAM FROM PIPELINE. THESE PUMPS ARE IN OPERATION SINCE COMMISSIONING OF THE STATION. SCOPE OF WORK COLLECTION & TRANSPORTATION THE CONTRACTOR SHALL COLLECT THE PUMP CASING THROUGH SUITABLE PICKUP/CRANE MOUNTED TRUCK FROM EMS WORKSHOP AT AWEER. THE CONTRACTOR PICKUP SHALL HAVE SUITABLE AND SAFE LIFTING	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SLING/BELT OF SUFFICIENT LOAD CAPACITY. LOADING AND UNLOADING OF PUMP CASING TO BE CARRIED OUT BY CONTRACTOR. SURFACE PREPARATION BEFORE APPLYING ANY COATING, THE CONTRACTOR HAS TO DO NECESSARY SURFACE PREPARATION BY SAND OR GRIT BLASTING OR ANY OTHER SUITABLE MECHANICAL SYSTEM TO REMOVE ALL RUST & LOOSE MATERIALS. AFTER SAND BLASTING THE CONTRACTOR HAS TO INTIMATE DEWA ENGINEER FOR INSPECTION OF THE SURFACE BEFORE APPLYING ANY COATING. DURING SANDBLASTING IT IS REQUIRED TO PROTECT ALL MACHINED SURFACE, SEAT AREA AND ALL OTHER CRITICAL AREAS AND PARTS FROM DAMAGE BY SUITABLE METHOD. BUILDUP OF FILLING OF ERODED/PITTED SURFACE THE SUPPLIER HAS TO BUILDUP ERODED SURFACE BY SUITABLE COMPOSITE MATERIALS UP TO ORIGINAL LEVEL BEFORE APPLYING ANY COATING. THE COMPOSITE MATERIAL SHALL HAVE THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FOLLOWING PROPERTIES: #THE CURRIED COMPOSITE MUST BE SUITABLE FOR CONTINUOUS IMMERSION IN THE FOLLOWING CHEMICALS AT 21 0C (70 0F): FERRIC CHLORIDE, 10%HYDROCHLORIC ACID, 10% SULFURIC ACID, 5% NITRIC ACID, 50% SODIUMHYDROXIDE AND 28% AMMONIUM HYDROXIDE. #THE COMPOSITE SHALL SHOW NO BLISTERS WHEN EXPOSED TO DE-MINERALIZED WATER IN AN ASTM C 868 CORROSION TEST AT 43 0C (110 0 F) FOR A MINIMUM PERIOD OF 6 MONTHS. #ADHESION OF THE COMPOSITE PER ASTM D1002 SH ALL BE GREATER THAN 183KG/CM2 (2,600 PSI) #THE CURVED COMPOSITE MUST MEET OR EXCEED THE FOLLOWING PHYSICAL REQUIREMENTS: COMPRESSIVE STRENGTH (ASTM D 695) 914 KG/CM2 (13,000 PSI). TENSILE STRENGTH (ASTM D 638) 431 KG/CM2 (6,136 PSI) FLEXURAL STRENGTH (ASTM D 790) 620 KG/CM2 (8,800 PSI) FLEXURAL MODULUS (ASTM D 790) 6.9 X 104 KG/CM2 (9.87 X 105 PSI). DURING THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PHASES OF SURFACE PREPARATION, APPLICATION, AND CURING, ENVIRONMENTAL CONDITIONS WILL REQUIRE CAREFUL MONITORING AND MAY REQUIRE SUPPLEMENTAL CONTROLS. CRITICAL AREAS OF CONCERN ARE RELATIVE HUMIDITY, DEW POINT, SURFACE TEMPERATURE OF THE SUBSTRATE, AND AIR PURITY. CONTRACTOR SHALL CARRY OUT ALL THE PROCEDURES IN A CONTROLLED ENVIRONMENT IN ACCORDANCE WITH THE LATEST STANDARDS AND PROCEDURES. FINAL INTERNAL COATING AFTER SURFACE PREPARATION AND FILLING UP THE ERODED SURFACE IT IS REQUIRED TO APPLY THE CERAMIC REINFORCED COMPOSITE MATERIALS FOR FINAL COATING. THE COMPOSITE COATING MATERIALS SHALL HAVE FOLLOWING PROPERTIES: #THE CURED COMPOSITE MUST BE SUITABLE FOR CONTINUOUS IMMERSION IN THE FOLLOWING CHEMICALS AT 210C(700F): FERRIC CHLORIDE, 10% HYDROCHLORIC ACID, 10% SULFURIC ACID, 5%						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NITRIC ACID, 50% SODIUM HYDROXIDE AND 28%AMM ONIUH HYDROXIDE.#THE COMPOSITE MUST EXCEED 10,000 HRS IN AN ASTM B 117 SALT FOG TEST(SCORED) WITH NO SIGNS OF UNDER FILM CORROSION AT THE SCORE.#THE COMPOSITE MUST PASS ASTM G 8 CATHODIC DISBANDMENT TEST FOR NOTLESS THAN 60 DAYS.#THE COMPOSITE SHALL SHOW NO BLI STERS WHEN EXPOSED TO DEMINERALIZEDWATER IN AN ASTM C 868 CORROCELL TEST AT 430C (1100F) FOR A MINIMUMPERIOD OF 6 MONTHS.#ADHESION OF THE COMPOSITE PER ASTM D 4541 SHALL BE GREATER THAN 140KG/CM2 (2,000 PSI).#THE LINEAR CO-EFFICIENT OF THERMAL EXPANSION (ASTM C 531) SHALL NOTEXCEED 5.0 X 10-5 CM/CM/0C (2.8 X 10-5 IN/IN/0F).#THICKNESS OF COATING 800-1000 MICRONS.#SURFACE FINISHING OF THE COA TING SHALL BE SMOOTH GLASS SURFACEFINISHED AND ABRASION						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RESISTANT. #THE CURED COMPOSITE MUST MEET OR EXCEED THE FOLLOWING PHYSICAL REQUIREMENTS: COMPRESSIVE STRENGTH: (ASTM D 695) 844 KG/CM2 (12,000 PSI) TENSILE STRENGTH: (ASTM D 638) 240 KG/CM2 (3,420 PSI) FLEXURAL STRENGTH: (ASTM D 790) 562 KG/CM2 (8,000 PSI) #THE COMPOSITE SHALL BE AUTHORIZED FOR USDA APPLICATION FOR INCIDENTAL CONTACT. #THE COMPOSITE IS REQUIRED TO HAVE POTABLE WATER CERTIFICATION FROM INTERNATIONAL/LOCAL AUTHORITIES, WRAS (WATER REGULATORY ADVISORY SOCIETY). EXTERNAL COATING EPOXY POWDER COATING IN BLUE COLOUR AT LEAST 300-400 MICRON THICK FOR BOTH PUMPS AND VALVES. ALL NECESSARY SURFACE PREPARATIONS TO BE DONE BEFORE COATING. WARRANTY THE SUPPLIER HAS TO PROVIDE AT LEAST 24 MONTHS OF SERVICE WARRANTY AGAINST ANY DAMAGE/ DEFECTS FOR THE COATING. IF THE COATING						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ISFOUND TO FAIL WITHIN THIS PERIOD THE SUPPLIER HAS TO RECOAT THEEQUIPMENT AT FREE OF CHARGE TO DEWA.METHOD STATEMENTTHE SUPPLIER HAS TO PROVIDE METHOD STATEMENT OF COATING AND MATERIALDE TAILS ALONG WITH THEIR OFFER FOR TECHNICAL EVALUATION AND APPROVAL.INSPECTION AT SITEBEFORE DELIVERY OF COATED PUMPS/VALVES, THE COA TING WORKS TO BEINSPECTED BY DEWA ENGINEER AT SUPPLIER WORKSHOP FOR FINAL ACCEPTANCE. CONTRACTOR SHALL PROVIDE WITH ALL REQUIRED NEC ESSARY INSPECTION TOOLSAS REQUIRED ON SITE.REPORTS & DOCUMENTS DURING DELIVERY THE FOLLOWING DOCUMENTS TO BE SUBMITTED.1.# MATERIAL DATA SHEET.2.#PHOTO OF CASING BEFORE AND AFTER COATING.3.#WARAS CERTIFICATE FOR COATING MATERIALS.4.#ALL TEST REPORTS.*****						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Complete overhauling of Booster pump of NAD AL SHEBA pumping station.
Pump details: Make- CLYDEUNION, Model-SDK 400/600, Capacity-526l/sec,
Head-66M, RPM-980.
Equipment No. 50353407
Contact Mr Noor Phone: 04-3229439 #
Md.NoorUddin@dewa.gov.ae

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502695
DATE : 21.10.2025
REQ No : 1032505126
REQ TITLE : Complete overhauling of Boost
DELIVERY LOCATION
CLOSING DATE : 27.10.2025
CLOSING TIME : 10:00:00

limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP