

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	1.#INTRODUCTIONTHE BRIEF SCOPE OF THE ENQUIRY IS AS BELOW,A.#SUPPLY AND SERVICES SCOPE: G RO CHILLER- 2, YORK MAKE, MODEL:YVAA0413HB F50BAV IS EQUIPPED WITH 20 NOS. ALUMINUM MICROCHANNEL TYPECONDENSER COILS. WE PROPOSE REPLACING THESE COILS WITH THERMO-GUARDCOATED COPPER TUBES WITH ALUMINUM FINS CONDENSER COILS WITH THERMO-GUARDCOATING.THIS CHILLER VFD COOLING SYSTEM USES 4 NOS. GLYCOL CONDENSER COILS WITHCOPPER TUBES & ALUMINUM FINS. WE PROPOSE REPLACING THESE CONDENSER COILSWITH THE SAME CONDENSER COILS TYPE WITH THERMO-GUARD COATING.B.#SUPPLY SCOPE: SUPPLY OF 3 NOS. ALUMINUM MICROCHANNEL TYPE CONDENSERCOILS WITH THERMO-GUARD COATING AS A SPARE FOR R EPLACING IN G ROCHILLER- 1, YORK MAKE, MODEL: YVAA0413HBF50BAV AND OTHER CHILLERS IN THEPLANT.2.#DETAILED	20	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SCOPE:A.#SUPPLY AND SERVIC ES SCOPE:1.#REMOVAL OF 20 NOS. EXISTING MICROCHANNEL TYPE CONDENSER COILS OFG-RO PLANT YORK MAKE VFD CHILLER-2 AFTER RECOVERY OF REF RIGERANT (R-134AGAS) FROM THE SYSTEM. (TECHNICAL SPECIFICATION TABLE ITEM#1)2.#SUPPLY, INSTALLATION & COMMISSIONING OF 20 NOS. NEW C OPPER TUBESWITH ALUMINUM FIN TYPE CONDENSER COILS WITH THERMO-GUARD COATING.3.#REMOVAL OF FOUR EXISTING GLYCOL CONDENSER COILS OF CO PPER TUBES &ALUMINUM FINS FOR VFD COOLING SYSTEM AFTER RECOVERY OF GLYCOL FROM THESYSTEM AND SUPPLY, INSTALLATION & COMMISSIONING OF NEW COILS OF SAMETYPE. (REFER TECHNICAL SPECIFICATION TABLE ITEM- 2).4.#IT IS THE CONTRACTOR#S RESPONSIBILITY TO DESIGN THE NEW COP PER TUBESWITH ALUMINUM FIN CONDENSER COILS TO MATCH THE SPECIFICATIONS						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ANDPERFORMANCE OF THE EXISTING MICROCHANNEL TYPE COILS.5.#THE NEW COILS MUST BE EQUIVALENT IN BOTH PERFORMANCE AND DESIGN TOTHE ORIGINAL MICROCHANNEL COILS CURRENTLY INSTALLED IN THE SYSTEM.B.# SUPPLY SCOPE: THE CONTRACTOR SHALL SUPPLY 3 NOS. OF ALUMINUMMICROCHANNEL COILS WITH THERMOS-GUARD COATING. (REFER TECHNICALSPECIFICATION TABLE ITEM-3) AS SPARE CONDENSER COIL FOR THE REMAININGCHILLERS.C.#ALL THE MECHANICAL & ELECTRICAL WORK REQUIRED FOR COMPLETING THE JOBSUCH AS CLEANING OF THE BASE, CUTTING, BRAZING REFRIGERANT PIPES,DISCONNECTION, RECONNECTION, REMOVAL, REINSTALLATION OF CONDENSERCOOLING FANS & MOTORS AND TESTING & RE-COMMISSIONING OF THE CHILLERSHALL BE CARRIED OUT BY CONTRACTOR.D.#REMOVED EXISTING CONDENSER COIL TO BE TRANSPORTED TO THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DEWAD-STATION SCRAP YARD BY THE CONTRACTOR. MATERIAL RETURN NOTE WILL BE PROVIDED BY DEWA.E.#THE CONTRACTOR SHALL CARRY OUT THE REPLACEMENT OF FILTER DRIER CORE,OIL FILTER & COMPRESSOR OIL FOR CHILLERS.F.#BIDDERS MUST SUBMIT RECORDS OF PREVIOUSLY COMPLETED SIMILAR JOBS TO SUPPORT THEIR QUALIFICATION AND ENABLE EVALUATION OF THEIR OFFER.G.#ONLY BIDDERS WITH A DOCUMENTED HISTORY OF SIMILAR JOBS, SPECIFICALLY THE REPLACEMENT OF MICROCHANNEL TYPE COILS WITH COPPER TUBES WITH ALUMINUM FIN CONDENSER WILL BE CONSIDERED FOR THIS PROJECT.H.#THE BIDDERS SHALL SUBMIT THE EXPECTED LIFETIME OF THEIR PROPOSED CONDENSER COILS TO EVALUATE THEIR OFFER.I.#PRESSURE TESTS WITH NITROGEN GAS SHALL BE CARRIED OUT AT 400 PSI AND RESTORE THE UNIT IN NORMAL WORKING CONDITION.J.						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			#IT IS THE CONTRACTOR#S RESPONSIBILITY TO TAKE ACTUAL MEASUREMENTS OF COILS REQUIRED TO COMPLETE THE JOB AS PER SITE REQUIREMENTS.K.# ANY ITEM NOT MENTIONED IN THE SCOPE BUT NECESSARY FOR THE INSTALLATION & COMMISSIONING OF CONDENSER COILS SHALL BE IN THE CONTRACTOR'S SCOPE.3.#TECHNICAL SPECIFICATION OF EXISTING AND REQUIRED CONDENSER COILSSR.#UNIT DESCRIPTION#TYPE OF EXISTING CONDENSER COIL#NO. OF COILS#SIZE- L X H X W OF COIL IN MM#TYPE OF REQUIRED CONDENSER COILS1#CHILLER- 2YORK CHILLER MODEL: YVAA0413HBF50BAV(SUPPLY & SERV ICES SCOPE)#ALUMINUM MICROCHANNEL#20#2115 X1211X 25#THERMO-GUARD COATED COPPER TUBES WITH ALUMINUM FINS CONDENSER COILS2#CHILLER- 2YORK CHILLER MODEL: YVAA0413HBF50BAV(SUPPLY & SERVICES SCOPE)#CU TUBE & AL FINS (GLYCOL)#4#450 X 600 X 25#THERMO-GUARD						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COATED COPPER TUBES WITH ALUMINUM FINS CONDENSER COILS3#SPARE CONDENSER COIL (SUPPLY SCOPE ONLY)#ALUMINUM MICROCHANNEL#3#2115 X1211X25#THERMO-GUARD COATED ALUMINUM MICROCHANNEL COILS4.#GENERAL CONDITIONS:A.#SITE VISIT: THE PROSPECTIVE BIDDERS MAY VISIT THE SITE TO FULLYUNDERSTAND THE SITE CONDITIONS, JOB SCOPE, JOB COMPLEXITIES AND EXTENTOF THE WORK PRIOR TO SUBMISSION OF THEIR BIDS. SUBMISSION OF BIDS SHALL BE DEEMED TO HAVE CONSIDERED THE ABOVE. PLANT/SITE VISIT AND PRE-BIDCLARIFICATION CORRESPONDENCE SHALL BE COMMUNICATED TO MR. AHMED MOHAMED EL-KARWY, SR. ENG-EM (G),AHMED.ELKARWY@DEWA.GOV.AE WITH COPY TO MR.RAHUL PATHAK, M-EM (G), RAHUL.PATHAK@DEWA.GOV.AE. AS A BACK-UP OF EMAILCOMMUNICATION, THE CONTRACTOR MAY CONTACT MR. KUTTAN RAJU,						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TELE:04-3226051, MOB: 0554283639.B.#DEWA WILL NOT ACCEPT ANY CLAIMS FOR EXTRAS BEYOND THE ORDER RATES /PRICES AFTER THE EXECUTION OF ORDER.5.#DOCUMENTS:A.#THE SUPPLIERS SHALL SUBMIT METHOD- STATEMENT AND JOB COMPLETION SCHEDULE ALONG WITH THEIR OFFERS.B.#THE SUPPLIER SHALL SUBMIT THE COMPLETE SPECIFICATION OF THE PROPOSED MATERIAL WITH THE NECESSARY CATALOGUES ALONG WITH THEIR OFFER.C.#ON JOB COMPLETION, THE SUPPLIERS SHALL SUBMIT PERFORMANCE REPORT OF THE CHILLER.D.#ON JOB COMPLETION, THE SUPPLIERS SHALL SUBMIT SERVICE ENTRY IN THE SAP WITH JOB COMPLETION CERTIFICATE INCLUDING NECESSARY PHOTOS AND DEWA SECURITY STAMPED CONTRACTOR MATERIAL GATE PASS ENTRY FOR THE PROJECT AS EVIDENCE OF CONTRACTOR'S MATERIAL USED FOR THE PROJECT.6.#PERIOD OF						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COMPLETION:A.#THE SUPPLY & INSTALLATION JOB SHALL BE DONE WITHIN 30 DAYS FROM THE DATE OF THE ORDER.B.#THE BIDDERS SHALL MENTION THE PERIOD OF COMPLETION OF THE JOB IN THEIR OFFER.7.#WARRANTY:A.#THE INSTALLATION WORK SHALL BE GUARANTEED FOR PERFORMANCE, WORKMANSHIP AND MANUFACTURING DEFECTS FOR 2 YEARS PERIOD.B.#THE CONDENSER COILS THERMO-GUARD COATING SHALL HAVE WARRANTY OF 8 YEARS.C.#THE GUARANTEE WILL TAKE EFFECT FROM THE DATE OF TAKEOVER AFTER JOB COMPLETION.D.#WHEN A DEFECT IS NOTICED DURING THE PERIOD OF WARRANTY, THE CONTRACTOR MUST RECTIFY THE FAULT WITHIN A REASONABLE AMOUNT OF TIME FIXED BY DEWA WITH NO CLAIMS OR COMPENSATION. AFTER REPLACEMENT OF THE FAULTY PART OR RECTIFICATION OF THE FAULT, WARRANTY OF THE CONCERNED PART SHALL BE RESTARTED FOR ONE YEAR.						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			R.8.#PAYMENTS: THE PAYMENT SHALL BE AS PER DEWA TERMS AND CONDITIONS						
2		ITEM-00001	1.#INTRODUCTIONTHE BRIEF SCOPE OF THE ENQUIRY IS AS BELOW,A.#SUPPLY AND SERVICES SCOPE: G RO CHILLER- 2, YORK MAKE, MODEL:YVAA0413HB F50BAV IS EQUIPPED WITH 20 NOS. ALUMINUM MICROCHANNEL TYPECONDENSER COILS. WE PROPOSE REPLACING THESE COILS WITH THERMO-GUARDCOATED COPPER TUBES WITH ALUMINUM FINS CONDENSER COILS WITH THERMO-GUARDCOATING.THIS CHILLER VFD COOLING SYSTEM USES 4 NOS. GLYCOL CONDENSER COILS WITHCOPPER TUBES & ALUMINUM FINS. WE PROPOSE REPLACING THESE CONDENSER COILSWITH THE SAME CONDENSER COILS TYPE WITH THERMO-GUARD COATING.B.#SUPPLY SCOPE: SUPPLY OF 3 NOS. ALUMINUM MICROCHANNEL TYPE CONDENSERCOILS WITH THERMO-GUARD COATING AS A SPARE FOR R EPLACING IN G ROCHILLER- 1, YORK MAKE,	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MODEL: YVAA0413HBF50BAV AND OTHER CHILLERS IN THE PLANT. 2. # DETAILED SCOPE: A. # SUPPLY AND SERVICES SCOPE: 1. # REMOVAL OF 20 NOS. EXISTING MICROCHANNEL TYPE CONDENSER COILS OF FG-RO PLANT YORK MAKE VFD CHILLER-2 AFTER RECOVERY OF REFRIGERANT (R-134A GAS) FROM THE SYSTEM. (TECHNICAL SPECIFICATION TABLE ITEM #1) 2. # SUPPLY, INSTALLATION & COMMISSIONING OF 20 NOS. NEW COPPER TUBES WITH ALUMINUM FIN TYPE CONDENSER COILS WITH THERMO-GUARD COATING. 3. # REMOVAL OF FOUR EXISTING GLYCOL CONDENSER COILS OF COPPER TUBES & ALUMINUM FINS FOR VFD COOLING SYSTEM AFTER RECOVERY OF GLYCOL FROM THE SYSTEM AND SUPPLY, INSTALLATION & COMMISSIONING OF NEW COILS OF SAME TYPE. (REFER TECHNICAL SPECIFICATION TABLE ITEM- 2). 4. # IT IS THE CONTRACTOR'S RESPONSIBILITY TO DESIGN THE NEW COP						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PER TUBESWITH ALUMINUM FIN CONDENSER COILS TO MATCH THE SPECIFICATIONS ANDPERFORMANCE OF THE EXISTING MICROCHANNEL TYPE COILS.5.#THE NEW COILS MUST BE EQUIVALENT IN BOTH PERFORMANCE AND DESIGN TOTHE ORIGINAL MICROCHANNEL COILS CURRENTLY INSTALLED IN THE SYSTEM.B.# SUPPLY SCOPE: THE CONTRACTOR SHALL SUPPLY 3 NOS. OF ALUMINUMMICROCHANNEL COILS WITH THERMOS-GUARD COATING. (REFER TECHNICALSPECIFICA TION TABLE ITEM-3) AS SPARE CONDENSER COIL FOR THE REMAININGCHILLERS.C.#ALL THE MECHANICAL & ELECTRICAL WORK REQUIRED FOR COMPLETING THE JOBSUCH AS CLEANING OF THE BASE, CUTTING, BRAZING REFRIGERANT PIPES,DISCONNECTION, RECONNECTION, REMOVAL, REINSTALLATION OF CON DENSERCOOLING FANS & MOTORS AND TESTING & RE-COMMISSIONING OF THE CHILLERSHALL BE CARRIED OUT BY CONTRACTOR.D.#REMOVED						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			EXISTING COND ENSER COIL TO BE TRANSPORTED TO THE DEWAD-STATION SCRAP YARD BY THE CONTRACTOR. MATERIAL RETURN NOTE WILL BEPROVIDED BY DEWA.E.#THE CONTRACTOR SHALL CARRY OUT THE REPLACEMENT OF FILTER DRIER CORE,OIL FILTER & COMPRESSOR OIL FOR CHILLERS.F.#BIDDERS MUST SUBMIT RECO RDS OF PREVIOUSLY COMPLETED SIMILAR JOBS TOSUPPORT THEIR QUALIFICATION AND ENABLE EVALUATION OF THEIR OFFER.G.#ONLY BIDDERS WITH A D OCUMENTED HISTORY OF SIMILAR JOBS, SPECIFICALLYTHE REPLACEMENT OF MICROCHANNEL TYPE COILS WITH COPPER TUBES WITHALUMINUM FIN CONDENS ER WILL BE CONSIDERED FOR THIS PROJECT.H.#THE BIDDERS SHALL SUBMIT THE EXPECTED LIFETIME OF THEIR PROPOSEDCONDENSER COILS TO EVALUAT E THEIR OFFER.I.#PRESSURE TESTS WITH NITROGEN GAS SHALL BE CARRIED OUT AT 400 PSI						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ANDRESTORE THE UNIT IN NORMAL WORKING CONDITION.J. #IT IS THE CONTRACTOR#S RESPONSIBILITY TO TAKE ACTUAL MEASUREMENTS OFCOILS REQUIRED TO COMPLETE THE JOB AS PER SITE REQUIREMENTS.K.# ANY ITEM NOT MENTIONED IN THE SCOPE BUT NECESSARY FOR THEINSTALLATION & COMMISSIONING OF CONDENSER COILS SHALL BE IN THECONTRACTOR'S SCOPE.3.#TECHNICAL SPECIFICATION OF EXISTING AND REQUIRED CONDENSER COILSSR.#UNIT DESCRIPTION#TYPE OF EXISTING CONDENSER COIL#NO. O F COILS#SIZE- L X H X W OF COIL IN MM#TYPE OF REQUIRED CONDENSER COILS1#CHILLER- 2YORK CHILLER MODEL: YVAA0413HBF50BAV(SUPPLY & SERV ICES SCOPE)#ALUMINUM MICROCHANNEL#20#2115 X1211X 25#THERMO-GUARD COATED COPPER TUBES WITH ALUMINUMFINS CONDENSER COILS2#CHILLER- 2YO RK CHILLER MODEL: YVAA0413HBF50BAV(SUPPLY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			& SERVICES SCOPE)#CU TUBE & AL FINS (GLYCOL)#4#450 X 600 X 25#THERMO-GUARD COATED COPPER TUBES WITH ALUMINUM FINS CONDENSER COILS3#SPARE CONDENSER COIL (SUPPLY SCOPE ONLY)#ALUMINUM MICROCHANNEL#3#2115 X1211X 25#THERMO-GUARD COATED ALUMINUM MICROCHANNEL COILS4.#GENERAL CONDITIONS:A.#SITE VISIT: THE PROSPECTIVE BIDDERS MAY VISIT THE SITE TO FULLYUNDERSTAND THE SITE CONDITIONS, JOB SCOPE, JOB COMPLEXITIES AND EXTENTOF THE WORK PRIOR TO SUBMISSION OF THEIR BIDS. SUBMISSION OF BIDS SHALL BE DEEMED TO HAVE CONSIDERED THE ABOVE. PLANT/SITE VISIT AND PRE-BIDCLARIFICATION CORRESPONDENCE SHALL BE COMMUNICATED TO MR. AHMED MOHAMED EL-KARWY, SR. ENG-EM (G),AHMED.ELKARWY@DEWA.GOV.AE WITH COPY TO MR.RAHUL PATHAK, M-EM (G), RAHUL.PATHAK@DEWA.GOV.AE. AS A						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BACK-UP OF EMAILCOMMUNICATION, THE CONTRACTOR MAY CONTACT MR. KUTTAN RAJU, TELE:04-3226051, MOB: 0554283639.B.#DEWA WILL NOT ACCEPT ANY CLAIMS FOR EXTRAS BEYOND THE ORDER RATES /PRICES AFTER THE EXECUTION OF ORDER.5.#DOCUMENTS:A.#THE SUPPLIERS SHALL SUBMIT METHOD- STATEMENT AND JOB COMPLETIONSCCHEDULE ALONG WITH THEIR OFFERS.B.#THE SUPPLIER SHALL SUBMIT THE COMPLETE SPECIFICATION OF THE PROPOSED MATERIAL WITH THE NECESSARY CATALOGUES ALONG WITH THEIR OFFER.C.#ON JOB COMPLETION, THE SUPPLIERS SHALL SUBMIT PERFORMANCE REPORT OF THE CHILLER.D.#ON JOB COMPLETION, THE SUPPLIERS SHALL SUBMIT SERVICE ENTRY IN THESAP WITH JOB COMPLETION CERTIFICATE INCLUDING NECES SARY PHOTOS AND DEWASECURITY STAMPED CONTRACTOR MATERIAL GATE PASS ENTRY FOR THE PROJECT ASEVIDENCE OF CONTRACTOR#S						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MATERIAL USED FOR THE PROJECT.6.#PERIOD OF COMPLETION:A.#THE SUPPLY & INSTALLATION JOB SHALL BE DONE WITHIN 30 DAYS FROM THE DATE OF THE ORDER.B.#THE BIDDERS SHALL MENTION THE PERIOD OF COMPLETION OF THE JOB IN THEIR OFFER.7.#WARRANTY:A.#THE INSTALLATION WORK SHALL BE GUARANTEED FOR PERFORMANCE, WORKMANSHIP AND MANUFACTURING DEFECTS FOR 2 YEARS PERIOD.B.#THE CONDENSER COILS THERMO-GUARD COATING SHALL HAVE WARRANTY OF 8 YEARS.C.#THE GUARANTEE WILL TAKE EFFECT FROM THE DATE OF TAKEOVER AFTER JOB COMPLETION.D.#WHEN A DEFECT IS NOTICED DURING THE PERIOD OF WARRANTY, THE CONTRACTOR MUST RECTIFY THE FAULT WITHIN A REASONABLE AMOUNT OF TIME FIXED BY DEWA WITH NO CLAIMS OR COMPENSATION. AFTER REPLACEMENT OF THE FAULTY PART OR RECTIFICATION OF THE FAULT, WARRANTY OF						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE CONCERNEDPART SHALL BE RESTARTED FOR ONE YEA R.8.#PAYMENTS: THE PAYMENT SHALL BE AS PER DEWA TERMS AND CONDITIONS						
3		ITEM-00001	1.#INTRODUCTIONTHE BRIEF SCOPE OF THE ENQUIRY IS AS BELOW,A.#SUPPLY AND SERVICES SCOPE: G RO CHILLER- 2, YORK MAKE, MODEL:YVAA0413HB F50BAV IS EQUIPPED WITH 20 NOS. ALUMINUM MICROCHANNEL TYPECONDENSER COILS. WE PROPOSE REPLACING THESE COILS WITH THERMO-GUARDCOATED COPPER TUBES WITH ALUMINUM FINS CONDENSER COILS WITH THERMO-GUARDCOATING.THIS CHILLER VFD COOLING SYSTEM USES 4 NOS. GLYCOL CONDENSER COILS WITHCOPPER TUBES & ALUMINUM FINS. WE PROPOSE REPLACING THESE CONDENSER COILSWITH THE SAME CONDENSER COILS TYPE WITH THERMO-GUARD COATING.B.#SUPPLY SCOPE: SUPPLY OF 3 NOS. ALUMINUM MICROCHANNEL TYPE CONDENSERCOILS WITH THERMO-GUARD	3	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COATING AS A SPARE FOR R EPLACING IN G ROCHILLER- 1, YORK MAKE, MODEL: YVAA0413HBF50BAV AND OTHER CHILLERS IN THEPLANT.2.#DETAILED SCOPE:A.#SUPPLY AND SERVIC ES SCOPE:1.#REMOVAL OF 20 NOS. EXISTING MICROCHANNEL TYPE CONDENSER COILS OFG-RO PLANT YORK MAKE VFD CHILLER-2 AFTER RECOVERY OF REF RIGERANT (R-134AGAS) FROM THE SYSTEM. (TECHNICAL SPECIFICATION TABLE ITEM#1)2.#SUPPLY, INSTALLATION & COMMISSIONING OF 20 NOS. NEW C OPPER TUBESWITH ALUMINUM FIN TYPE CONDENSER COILS WITH THERMO-GUARD COATING.3.#REMOVAL OF FOUR EXISTING GLYCOL CONDENSER COILS OF CO PPER TUBES &ALUMINUM FINS FOR VFD COOLING SYSTEM AFTER RECOVERY OF GLYCOL FROM THESYSTEM AND SUPPLY, INSTALLATION & COMMISSIONING OF NEW COILS OF SAMETYPE. (REFER TECHNICAL SPECIFICATION TABLE ITEM- 2).4.#IT IS THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONTRACTOR#S RESPONSIBILITY TO DESIGN THE NEW COP PER TUBESWITH ALUMINUM FIN CONDENSER COILS TO MATCH THE SPECIFICATIONS ANDPERFORMANCE OF THE EXISTING MICROCHANNEL TYPE COILS.5.#THE NEW COILS MUST BE EQUIVALENT IN BOTH PERFORMANCE AND DESIGN TOTHE ORIGINAL MICROCHANNEL COILS CURRENTLY INSTALLED IN THE SYSTEM.B.# SUPPLY SCOPE: THE CONTRACTOR SHALL SUPPLY 3 NOS. OF ALUMINUMMICROCHANNEL COILS WITH THERMOS-GUARD COATING. (REFER TECHNICALSPECIFICA TION TABLE ITEM-3) AS SPARE CONDENSER COIL FOR THE REMAININGCHILLERS.C.#ALL THE MECHANICAL & ELECTRICAL WORK REQUIRED FOR COMPLETING THE JOBSUCH AS CLEANING OF THE BASE, CUTTING, BRAZING REFRIGERANT PIPES,DISCONNECTION, RECONNECTION, REMOVAL, REINSTALLATION OF CON DENSERCOOLING FANS & MOTORS AND TESTING &						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RE-COMMISSIONING OF THE CHILLERS SHALL BE CARRIED OUT BY CONTRACTOR. D.#REMOVED EXISTING CONDENSER COIL TO BE TRANSPORTED TO THE DEWAD-STATION SCRAP YARD BY THE CONTRACTOR. MATERIAL RETURN NOTE WILL BE PROVIDED BY DEWA. E.#THE CONTRACTOR SHALL CARRY OUT THE REPLACEMENT OF FILTER DRIER CORE, OIL FILTER & COMPRESSOR OIL FOR CHILLERS. F.#BIDDERS MUST SUBMIT RECORDS OF PREVIOUSLY COMPLETED SIMILAR JOBS TO SUPPORT THEIR QUALIFICATION AND ENABLE EVALUATION OF THEIR OFFER. G.#ONLY BIDDERS WITH A DOCUMENTED HISTORY OF SIMILAR JOBS, SPECIFICALLY THE REPLACEMENT OF MICROCHANNEL TYPE COILS WITH COPPER TUBES WITH ALUMINUM FIN CONDENSER WILL BE CONSIDERED FOR THIS PROJECT. H.#THE BIDDERS SHALL SUBMIT THE EXPECTED LIFETIME OF THEIR PROPOSED CONDENSER COILS TO EVALUATE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			E THEIR OFFER.I.#PRESSURE TESTS WITH NITROGEN GAS SHALL BE CARRIED OUT AT 400 PSI ANDRESTORE THE UNIT IN NORMAL WORKING CONDITION.J. #IT IS THE CONTRACTOR#S RESPONSIBILITY TO TAKE ACTUAL MEASUREMENTS OFCOILS REQUIRED TO COMPLETE THE JOB AS PER SITE REQUIREMENTS.K.# ANY ITEM NOT MENTIONED IN THE SCOPE BUT NECESSARY FOR THEINSTALLATION & COMMISSIONING OF CONDENSER COILS SHALL BE IN THECONTRACTOR'S SCOPE.3.#TECHNICAL SPECIFICATION OF EXISTING AND REQUIRED CONDENSER COILSSR.#UNIT DESCRIPTION#TYPE OF EXISTING CONDENSER COIL#NO. O F COILS#SIZE- L X H X W OF COIL IN MM#TYPE OF REQUIRED CONDENSER COILS1#CHILLER- 2YORK CHILLER MODEL: YVAA0413HBF50BAV(SUPPLY & SERV ICES SCOPE)#ALUMINUM MICROCHANNEL#20#2115 X1211X 25#THERMO-GUARD COATED COPPER TUBES WITH ALUMINUMFINS CONDENSER						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COILS2#CHILLER- 2YO RK CHILLER MODEL: YVAA0413HBF50BAV(SUPPLY & SERVICES SCOPE)#CU TUBE & AL FINS (GLYCOL)#4#450 X 600 X 25#THERMO-GUARD COATED COPPER TUBES WITH ALUMINUM FINS CONDENSER COILS3#SPARE CONDENSER COIL (SUPPLY SCOPE ONLY)#ALUMINUM MICROCHANNEL#3#2115 X1211X 25#THERMO-GUARD COATED ALUMINUM MICROCHANNEL COILS4.#GENERAL CONDITIONS:A.#SITE VISIT: THE PROSPECTIVE BIDDERS MAY VISIT THE SITE TO FULLYUNDERSTAND THE SITE CONDITIONS, JOB SCOPE, JOB COMPLEXITIES AND EXTENTOF THE WORK PRIOR TO SUBMISSION OF THEIR BIDS. SUBMISSION OF BIDS SHALL BE DEEMED TO HAVE CONSIDERED THE ABOVE. PLANT/SITE VISIT AND PRE-BIDCLARIFICATION CORRESPONDENCE SHALL BE COMMUNICATED TO MR. AHMED MOHAMED EL-KARWY, SR. ENG-EM (G),AHMED.ELKARWY@DEWA.GOV.AE WITH COPY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TO MR.RAHUL PATHAK, M-EM (G), RAHUL.PATHAK@DEWA.GOV.AE. AS A BACK-UP OF EMAILCOMMUNICATION, THE CONTRACTOR MAY CONTACT MR. KUTTAN RAJU, TELE:04-3226051, MOB: 0554283639.B.#DEWA WILL NOT ACCEPT ANY CLAIMS FOR EXTRAS BEYOND THE ORDER RATES /PRICES AFTER THE EXECUTION OF ORDER.5.#DOCUMENTS:A.#THE SUPPLIERS SHALL SUBMIT METHOD- STATEMENT AND JOB COMPLETIONSCCHEDULE ALONG WITH THEIR OFFERS.B.#THE SUPPLIER SHALL SUBMIT THE COMPLETE SPECIFICATION OF THE PROPOSED MATERIAL WITH THE NECESSARY CATALOGUES ALONG WITH THEIR OFFER.C.#ON JOB COMPLETION, THE SUPPLIERS SHALL SUBMIT PERFORMANCE REPORT OF THE CHILLER.D.#ON JOB COMPLETION, THE SUPPLIERS SHALL SUBMIT SERVICE ENTRY IN THESAP WITH JOB COMPLETION CERTIFICATE INCLUDING NECES SARY PHOTOS AND DEWASECURITY STAMPED						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONTRACTOR MATERIAL GATE PASS ENTRY FOR THE PROJECT ASEVIDENCE OF CONTRACTOR#S MATERIAL USED FOR THE PROJECT.6.#PERIOD OF COMPLETION:A.#THE SUPPLY & INSTALLATION JOB SHALL BE DONE WITHIN 30 DAYS FROM THE DATE OF THE ORDER.B.#THE BIDDERS SHALL MENTION THE PERIOD OF COMPLETION OF THE JOB IN THEIR OFFER.7.#WARRANTY:A.#THE INSTALLATION WORK SHALL BE GUARANTEED FOR PERFORMANCE,WORKMANSHIP AND MANUFACTURING DEFECTS FOR 2 YEARS PERIOD.B.#THE CONDENSER COILS THERMO-GUARD COATING SHALL HAVE WARRANTY OF 8YEARS.C.#THE GUARANTEE WILL TAKE EFFECT FROM THE DATE OF TAKEOVER AFTER JOBCOMPLETION.D.#WHEN A DEFECT IS NOTICED DURING THE PERIOD OF WARRANTY, THE CONTRACTOR MUST RECTIFY THE FAULT WITHIN A REASONABLE AMOUNT OF TIME FIXED BY DEWA WITH NO CLAIMS OR COMPENSATION						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ION. AFTER REPLACEMENT OF THEFAULTY PART OR RECTIFICATION OF THE FAULT, WARRANTY OF THE CONCERNEDPART SHALL BE RESTARTED FOR ONE YEA R.8.#PAYMENTS: THE PAYMENT SHALL BE AS PER DEWA TERMS AND CONDITIONS						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Replacement of Condenser Coils of York VFD Chiller at G RO Plant.

Enquiry may send to Dolphin Radiators along with other parties

STANDARD TERMS & CONDITIONS

- Prices should be 'DDP' delivery duty paid at DEWA stores.
- Quotation to be submitted only in local currency U.A.E Dirhams
- DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page25 of 26

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502807
DATE : 31.10.2025
REQ No : 1032505262
REQ TITLE : Replacement of Condenser Coil
DELIVERY LOCATION
CLOSING DATE : 12.11.2025
CLOSING TIME : 10:00:00

6)Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by theSupplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP