

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502901
DATE : 13.11.2025
REQ No : 1032505328
REQ TITLE : E'STATION PHASE#1
DELIVERY LOCATION
CLOSING DATE : 19.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	PLEASE, FIND THE SPECIFICATION BELOW IS FOR THE PARTIAL RE-BUILDING OF THE ONE OF THE CCW PUMP FOUNDATION OF GAS TURBINE AFTER REMOVING CRACKED PART OF FOUNDATION ABOVE THE FLOOR SLAB LEVEL. THE FOUNDATION IS FOR FOUNDATION FOR A NEW 75KW PUMP WEIGHING ABOUT KG.1.#THE NEW PUMPS IS SIMILAR TO THE EXISTING PUMP IN DESIGN AND CONSTRUCTION.2.#CONTRACTOR SHALL BE WELL EXPERIENCED CIVIL ENGINEERING COMPANY WITH PROVEN EXPERIENCE IN DESIGN CONSTRUCTION OF EQUIPMENT FOUNDATIONS.3.#THE SPECIFIC PROVIDED HERE AS GENERIC, IF EXPERIENCED CONTRACTOR CAN RECOMMEND ADDITIONAL MEASURES IF NECESSARY TO ENSURE INTEGRITY OF THE PUMP.4.#GENERAL SPECIFICATION FOR CONCRETE PUMP FOUNDATION IS ATTACHED WITH THIS ENQUIRY AND SHALL BE STRICTLY FOLLOWED.5.#PREPARE AS BUILT DRAWING OF THE EXISTING CCW PUMP	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502901
DATE : 13.11.2025
REQ No : 1032505328
REQ TITLE : E'STATION PHASE#1
DELIVERY LOCATION
CLOSING DATE : 19.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FOUNDING CL EARLYCOORDINATES AND ELECTION. COORDINATES MAY BE MARKED WITH REFERENCE TOEXISTING COOLER SUPPORT FRAME COLUMNS. CENTRE LINES OF PUM P, MOTOR ANDFOUNDATION BOLTS SHALL BE MARKED IN THE DRAWING. DRAWING TO BE COMPAREDWITH NEW PUMP DIMENSIONAL DRAWINGS AND ANY CHANGE S SHALL BE NOTIFIED TODEWA. FINAL DRAWING SHALL BE SUBMITTED FOR DEWA APPROVAL PRIOR TOSTARTING ANY WORKS6.#ELECTRICAL AND MECHANICA L ISOLATION OF THE PUMP (BY DEWA).7.#DISMANTLING OF THE OLD PUMP WITHOUT ANY DAMAGES (BY DEWA)8.#DISMANTLE THE EXISTING PUMP FOUNDA TION KEEPING THE REINFORCEMENT ASIT IS UP TO A DEPTH OF 100 BELOW THE FLOOR LEVEL. FOUNDATION BELOW THISLEVEL WILL BE RETAINED WILL SERVE AS PART OF NEW FOUNDATION9.#REINFORCEMENT OF THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502901
DATE : 13.11.2025
REQ No : 1032505328
REQ TITLE : E'STATION PHASE#1
DELIVERY LOCATION
CLOSING DATE : 19.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			EXISTING FOUNDATION BE RETAINED FOR THE NEW FOUNDATION 10. #SINCE AS BUILT DRAWING OF THE FOUNDATION DESIGN IS NOT AVAILABLE, EXPERIENCED CIVIL ENGINEERING CONTRACTOR IS EXPECTED TO MAKE HIS OWN REASONABLE JUDGMENT ON THE ACTUAL QUANTUM OF THE WORK. 11. #AROUND THE FOUNDATION 100MM FLOOR SLAB SHALL BE DISMANTLED AROUND THE EXISTING FOUNDATION 12. #MEASUREMENT OF EXISTING FOUNDATION BOLTS SHALL BE TAKEN, AND SIMILAR NEW FOUNDATION BOLTS SHALL BE SUPPLIED FOR THE NEW FOUNDATION WITH DOUBLE LOCK NUT ARRANGEMENT. REFER THE ATTACHED DOCUMENT FOR BOLT QUALITY REQUIREMENTS. 13. #EXISTING REINFORCEMENT TO BE CORRECT FOR THE PROPER FORM AND Banded. IN ORDER TO ENSURE STRUCTURAL INTEGRITY AND SEAMLESS INTEGRATION OF EXISTING OLD FOUNDATION (REMAINING PART) WITH NEW CASTING,						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502901
DATE : 13.11.2025
REQ No : 1032505328
REQ TITLE : E'STATION PHASE#1
DELIVERY LOCATION
CLOSING DATE : 19.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ADDITIONALREINFORCEMENT OF AT LEAST 20% ABOVE THE EXISTING REINFORCEMENTQUALITIES-BASED ENGINEERING EVALUATION AND MUTUAL AGREEMENT WITH DEWA.NEW REINFORCEMENT SHALL BE DRILLED INTO OLD FOUNDATION AT LEAST 100MMDEEP.14.#POCKETS SHALL BE PROVID ED FOR THE FOUNDATION BOLTS AS PER THE NEWPUMP BASE BOLT LAYOUT. IN ORDER TO ENSURE THAT BOLT POCKET LAYOUT ISEXACTLY MATCHING WITH NEW PUMP BASE LAYOUT, CONTRACTOR SHALL MAKE ATEMPLATE BEFORE CASTING FOUNDATION.15.#CONSIDERING LIMITED OUTAGE DURATION, FAST CURING CONCRETE SHALL BEUSED. REFER TO ATTACHED SPECIFICATION FOR CONCRETE DETAILS.16.#AFTER COMPLETION OF THE FOUNDATION WORKS. FLOOR SLA B SHALL BERECA NTED AFTER PROVIDING VIBRO-ISOLATION PADS AROUND THE FOUNDATION.17.#SCOPE OF CONTRACTOR ALSO						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502901
DATE : 13.11.2025
REQ No : 1032505328
REQ TITLE : E'STATION PHASE#1
DELIVERY LOCATION
CLOSING DATE : 19.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INCLUDES GROUTING OF THE FOUNDATION BOLTS WITH NON-SHRINKING EPOXY GROUT AFTER PUMP POSITIONING AND LATER UP TO THE TOP OF THE BASE FRAME AFTER THE PUMP LEVELLING AND ALIGNMENT WITH PIPING. 18.# FOUNDATION SHALL BE PAINTED FOLLOWING THE PUMP ERECTION COMPLETION AS PER DEWA STANDARD.						
2		ITEM-00001	PLEASE, FIND THE SPECIFICATION BELOW IS FOR THE PARTIAL RE-BUILDING OF THE ONE OF THE CCW PUMP FOUNDATION OF GAS TURBINE AFTER REMOVING CRACKED PART OF FOUNDATION ABOVE THE FLOOR SLAB LEVEL. THE FOUNDATION IS FOR FOUNDATION FOR A NEW 75KW PUMP WEIGHING ABOUT KG. 1.# THE NEW PUMPS IS SIMILAR TO THE EXISTING PUMP IN DESIGN AND CONSTRUCTION. 2.# CONTRACTOR SHALL BE WELL EXPERIENCED CIVIL ENGINEERING COMPANY WITH PROVEN EXPERIENCE IN DESIGN CONSTRUCTION OF EQUIPMENT FOUNDATIONS. 3.# THE SPECIFIC PROVIDED HERE	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502901
DATE : 13.11.2025
REQ No : 1032505328
REQ TITLE : E'STATION PHASE#1
DELIVERY LOCATION
CLOSING DATE : 19.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AS GENERIC, IF EXPERIENCED CONTRACTOR CAN RECOMMEND ADDITIONAL MEASURES IF NECESSARY TO ENSURE INTEGRITY OF THE PUMP. 4.#GENERAL SPECIFICATION FOR CONCRETE PUMP FOUNDATION IS ATTACHED WITH THIS ENQUIRY AND SHALL BE STRICTLY FOLLOWED 5.#PREPARE AS BUILT DRAWING OF THE EXISTING CCW PUMP FOUNDING CL EARLY COORDINATES AND ELECTION. COORDINATES MAY BE MARKED WITH REFERENCE TO EXISTING COOLER SUPPORT FRAME COLUMNS. CENTRE LINES OF PUMP, MOTOR AND FOUNDATION BOLTS SHALL BE MARKED IN THE DRAWING. DRAWING TO BE COMPARED WITH NEW PUMP DIMENSIONAL DRAWINGS AND ANY CHANGES SHALL BE NOTIFIED TO DEWA. FINAL DRAWING SHALL BE SUBMITTED FOR DEWA APPROVAL PRIOR TO STARTING ANY WORKS 6.#ELECTRICAL AND MECHANICAL ISOLATION OF THE PUMP (BY DEWA). 7.#DISMANTLING OF THE OLD PUMP						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502901
DATE : 13.11.2025
REQ No : 1032505328
REQ TITLE : E'STATION PHASE#1
DELIVERY LOCATION
CLOSING DATE : 19.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WITHOUT ANY DAMAGES (BY DEWA)8.#DISMANTLE THE EXISTING PUMP FOUNDATION KEEPING THE REINFORCEMENT AS IT IS UP TO A DEPTH OF 100 BELOW THE FLOOR LEVEL. FOUNDATION BELOW THIS LEVEL WILL BE RETAINED WILL SERVE AS PART OF NEW FOUNDATION9.#REINFORCEMENT OF THE EXISTING FOUNDATION BE RETAINED FOR THE NEW FOUNDATION10.#SINCE AS BUILT DRAWING OF THE FOUNDATION DESIGN IS NOT AVAILABLE, EXPERIENCED CIVIL ENGINEERING CONTRACTOR IS EXPECTED TO MAKE HIS OWN REASONABLE JUDGMENT ON THE ACTUAL QUANTUM OF THE WORK.11.#AROUND THE FOUNDATION 100MM FLOOR SLAB SHALL BE DISMANTLED AROUND THE EXISTING FOUNDATION12.#MEASUREMENT OF EXISTING FOUNDATION BOLTS SHALL BE TAKEN, AND SIMILAR NEW FOUNDATION BOLTS SHALL BE SUPPLIED FOR THE NEW FOUNDATION WITH DOUBLE LOCK NUT ARRANGEMENT. REFER THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502901
DATE : 13.11.2025
REQ No : 1032505328
REQ TITLE : E'STATION PHASE#1
DELIVERY LOCATION
CLOSING DATE : 19.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ATTACHED DOCUMENT FOR BOLTQUALITY REQUIREMENTS.13.#EXISTING REINFORCEMENT TO BE CORRECT FOR THE PROPER FORM ANDBANDED. IN ORDER TO ENSURE STRUCTURAL INTEGRITY AND SEAMLESS INTEGRATIONOF EXISTING OLD FOUNDATION (REMAINING PART) WITH NEW CASTING, ADDITIONALREINFORCEMENT OF AT LEAST 20% ABOVE THE EXISTING REINFORCEMENTQUALITIES-BASED ENGINEERING EVALUATION AND MUTUAL AGREEMENT WITH DEWA.NEW REINFORCEMENT SHALL BE DRILLED INTO OLD FOUNDATION AT LEAST 100MMDEEP.14.#POCKETS SHALL BE PROVIDED FOR THE FOUNDATION BOLTS AS PER THE NEWPUMP BASE BOLT LAYOUT. IN ORDER TO ENSURE THAT BOLT POCKET LAYOUT ISEXACTLY MATCHING WITH NEW PUMP BASE LAYOUT, CONTRACTOR SHALL MAKE ATEMPLATE BEFORE CASTING FOUNDATION.15.#CONSIDERING LIMITED OUTAGE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502901
DATE : 13.11.2025
REQ No : 1032505328
REQ TITLE : E'STATION PHASE#1
DELIVERY LOCATION
CLOSING DATE : 19.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DURATION, FAST CURING CONCRETE SHALL BEUSED. REFER TO ATTACHED SPECIFICATION FOR CONCRETE DETAILS.16.#AFTER COMPLETION OF THE FOUNDATION WORKS. FLOOR SLA B SHALL BEREANTED AFTER PROVIDING VIBRO-ISOLATION PADS AROUND THE FOUNDATION.17.#SCOPE OF CONTRACTOR ALSO INCLUDES GROUTING OF THE FOUNDATION BOLTSWITH NON-SHRINKING EPOXY GROUT AFTER PUMP POSITIONING AND LATER UP TOTHE TOP OF THE BASE FRAME AFTER THE PUMP LEVELL ING AND ALIGNMENT WITHPIPING.18.#FOUNDATION SHALL BE PAINTED FOLLOWING THE PUMP ERECTION COMPLETIONAS PER DEWA STANDARD.						
3		ITEM-00001	PLEASE, FIND THE SPECIFICATION BELOW IS FOR THE PARTIAL RE-BUILDING OFTHE ONE OF THE CCW PUMP FOUNDATION OF GAS TURBINE AFTER REMOVI NG CRACKEDPART OF FOUNDATION ABOVE THE FLOOR SLAB LEVEL. THE FOUNDATION IS FORFOUNDATION FOR A NEW 75KW PUMP	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502901
DATE : 13.11.2025
REQ No : 1032505328
REQ TITLE : E'STATION PHASE#1
DELIVERY LOCATION
CLOSING DATE : 19.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WEIGHING ABOUT KG.1.#TH E NEW PUMPS IS SIMILAR TO THE EXISTING PUMP IN DESIGN ANDCONSTRUCTION.2.#CONTRACTOR SHALL BE WELL EXPERIENCED CIVIL ENGINEERING COMP ANY WITHPROVEN EXPERIENCE IN DESIGN CONSTRUCTION OF EQUIPMENT FOUNDATIONS.3.#THE SPECIFIC PROVIDED HERE AS GENERIC, IF EXPERIENCED C ONTRACTOR CANRECOMMEND ADDITIONAL MEASURES IF NECESSARY TO ENSURE INTEGRITY OF THEPUMP.4.#GENERAL SPECIFICATION FOR CONCRETE PUMP FO UNDATION IS ATTACHED WITHTHIS ENQUIRY AND SHALL BE STRICTLY FOLLOWED5.#PREPARE AS BUILT DRAWING OF THE EXISTING CCW PUMP FOUNDING CL EARLYCOORDINATES AND ELECTION. COORDINATES MAY BE MARKED WITH REFERENCE TOEXISTING COOLER SUPPORT FRAME COLUMNS. CENTRE LINES OF PUM P, MOTOR ANDFOUNDATION BOLTS SHALL BE MARKED IN THE DRAWING. DRAWING TO BE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502901
DATE : 13.11.2025
REQ No : 1032505328
REQ TITLE : E'STATION PHASE#1
DELIVERY LOCATION
CLOSING DATE : 19.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COMPAREDWITH NEW PUMP DIMENSIONAL DRAWINGS AND ANY CHANGE S SHALL BE NOTIFIED TODAWA. FINAL DRAWING SHALL BE SUBMITTED FOR DEWA APPROVAL PRIOR TOSTARTING ANY WORKS6.#ELECTRICAL AND MECHANICA L ISOLATION OF THE PUMP (BY DEWA).7.#DISMANTLING OF THE OLD PUMP WITHOUT ANY DAMAGES (BY DEWA)8.#DISMANTLE THE EXISTING PUMP FOUNDATION KEEPING THE REINFORCEMENT ASIT IS UP TO A DEPTH OF 100 BELOW THE FLOOR LEVEL. FOUNDATION BELOW THISLEVEL WILL BE RETAINED WILL SERVE AS PART OF NEW FOUNDATION9.#REINFORCEMENT OF THE EXISTING FOUNDATION BE RETAINED FOR THE NEWFOUNDATION10.#SINCE AS BUILT DRAWING OF THE FOUNDATION DESIGN IS NOT AVAILABLE,EXPERIENCED CIVIL ENGINEERING CONTRACTOR IS EXPECTED TO MAKE HIS OWNREASONABLE JUDGMENT ON THE ACTUAL QUANTUM OF THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502901
DATE : 13.11.2025
REQ No : 1032505328
REQ TITLE : E'STATION PHASE#1
DELIVERY LOCATION
CLOSING DATE : 19.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WORK.11.#AROUND THE FOUNDATION 100MM FLOOR SLAB SHALL BE DISMANTLED AROUND THE EXISTING FOUNDATION12.#MEASUREMENT OF EXISTING FOUNDATION BOLTS SHALL BE TAKEN, AND SIMILAR NEW FOUNDATION BOLTS SHALL BE SUPPLIED FOR THE NEW FOUNDATION WITH DOUBLE LOCK NUT ARRANGEMENT. REFER THE ATTACHED DOCUMENT FOR BOLT QUALITY REQUIREMENTS.13.#EXISTING REINFORCEMENT TO BE CORRECT FOR THE PROPER FORM AND BANDED. IN ORDER TO ENSURE STRUCTURAL INTEGRITY AND SEAMLESS INTEGRATION OF EXISTING OLD FOUNDATION (REMAINING PART) WITH NEW CASTING, ADDITIONAL REINFORCEMENT OF AT LEAST 20% ABOVE THE EXISTING REINFORCEMENT QUALITIES-BASED ENGINEERING EVALUATION AND MUTUAL AGREEMENT WITH DEWA. NEW REINFORCEMENT SHALL BE DRILLED INTO OLD FOUNDATION AT LEAST 100MM DEEP.14.#POCKETS						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502901
DATE : 13.11.2025
REQ No : 1032505328
REQ TITLE : E'STATION PHASE#1
DELIVERY LOCATION
CLOSING DATE : 19.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SHALL BE PROVIDED FOR THE FOUNDATION BOLTS AS PER THE NEWPUMP BASE BOLT LAYOUT. IN ORDER TO ENSURE THAT BOLT POCKET LAYOUT IS EXACTLY MATCHING WITH NEW PUMP BASE LAYOUT, CONTRACTOR SHALL MAKE A TEMPLATE BEFORE CASTING FOUNDATION.15.#CONSIDERING LIMITED OUTAGE DURATION, FAST CURING CONCRETE SHALL BE USED. REFER TO ATTACHED SPECIFICATION FOR CONCRETE DETAILS.16.#AFTER COMPLETION OF THE FOUNDATION WORKS. FLOOR SLAB SHALL BE RECASTED AFTER PROVIDING VIBRO-ISOLATION PADS AROUND THE FOUNDATION.17.#SCOPE OF CONTRACTOR ALSO INCLUDES GROUTING OF THE FOUNDATION BOLTS WITH NON-SHRINKING EPOXY GROUT AFTER PUMP POSITIONING AND LATER UP TO THE TOP OF THE BASE FRAME AFTER THE PUMP LEVELLING AND ALIGNMENT WITH PIPING.18.#FOUNDATION SHALL BE PAINTED FOLLOWING THE PUMP						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502901
DATE : 13.11.2025
REQ No : 1032505328
REQ TITLE : E'STATION PHASE#1
DELIVERY LOCATION
CLOSING DATE : 19.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ERECTION COMPLETIONAS PER DEWA STANDARD.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

E'STATION PHASE1 GENERATOR COOLING WATER PUMP CONCRETE FOUNDATION
INSTALLATION FOR THREE CONSECUTIVE UNITS.

FOR FURTHER DETAILS, PLEASE CONTACT ASM MYNUDDIN (0503620814)
MYNUDDIN.HOSSAIN@DEWA.GOV.AE/MARWAN AL MHEIRI (0501136322) (MARWAN.ALM
HEIRI@DEWA.GOV.AE)/AHMED ZAKARIA(0524781810)ahmed.eldaly@dewa.gov.ae

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page14 of 15

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502901
DATE : 13.11.2025
REQ No : 1032505328
REQ TITLE : E'STATION PHASE#1
DELIVERY LOCATION
CLOSING DATE : 19.11.2025
CLOSING TIME : 10:00:00

- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.
- If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
- The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP