

RFQ NUMBER : 2332502913

DATE : 12.11.2025

REQ No : 1032504992

REQ TITLE : Phase 1 Unit 5 Steam Turbine

DELIVERY LOCATION

CLOSING DATE : 24.11.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	D-STATION PHASE 1 STEAM TURBINE BYPASS TO	1	JOB				
			CONDENSER CONTROL ANDISOLATION VALVE						
			SERVICING AND SUPPLY OF SPARESDESCRIPTION						
			OF WORK:1.#						
			OVERHAUL OF ST BYPASS TO CONDENSER						
			CONTROL VALVE & ACTUATOR, QUANTITY: 1 MAKE:						
			COPES-VULCAN, MODEL 0-100-400 (B)2.#OVERHAUL						
			OF ST BYP						
			ASS TO CONDENSER ISOLATION VALVE &						
			ACTUATOR,QUANTITY: 1SCOPE OF WORK: -1.						
			MOBILIZATION OF PEOPLE, MATERIAL, TOOLS AND						
			CONSUMABLES2.						
			RISK ASSESSMENT AND WORK METHOD						
			STATEMENT TO BE SUBMITTED.3. TOOLBOX TALK						
			TO BE GIVEN TO THE CONTRACTOR PEOPLE ON						
			DAILY BASIS.4. COM						
			PLETE DISMANTLEMENT AND REASSEMBLY OF THE						
			VALVE, ACTUATOR, AND ANYOTHER PARTS						
			REQUIRED WILL BE IN THE VENDOR#S SCOPE OF						
			WORK.5. INSP						
			ECTION OF EVERY PART OF THE VALVE AND						
			ACTUATOR6. INSPECTION WITH NDT7. SUPPLY OF						
			SPARES SUCH AS O RINGS, GASKETS, PACKING,						



RFQ NUMBER : 2332502913

DATE : 12.11.2025

REQ No : 1032504992

REQ TITLE : Phase 1 Unit 5 Steam Turbine

DELIVERY LOCATION

CLOSING DATE : 24.11.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			LOCK RING						
			S, ANDREPAIR WORK SUCH AS MACHINING ARE IN						
			THE VENDOR#S SCOPE OF WORK8. REASSEMBLY						
			OF THE VALVE, ACTUATOR, AND ANY OTHER						
			PARTS DISMA						
			NTLED ISIN THE VENDOR#S SCOPE OF WORK9.						
			LEAK AND FUNCTIONAL TEST OF THE VALVE.10.						
			LIFTING SHALL BE CARRIED OUT BY THE VENDOR.						
			ALL RE						
			QUIRED TOOLS FORLIFTING SHOULD BE BROUGHT						
			BY THE VENDOR. IN ADDITION TO THAT,						
			ALLLIFTING TOOLS SHOULD HAVE VALID						
			CERTIFICATES.11. TR						
			ANSPORTATION OF THE PARTS FROM THE POWER						
			PLANT SHALL BE CARRIEDOUT BY THE VENDOR12.						
			SUBMISSION OF REPORT OF WORK DONE13.						
			PARTS TO BE						
			PAINTED WITH THE SAME COLOR.14. WORK WILL						
			BE CARRIED OUT AS PER DEWA WORK						
			SCHEDULE.15. DEWA HEALTH, SAFETY AND						
			ENVIRONMENT POLICY W						
			ILL BE FOLLOWED16. WORK TO BE COMPLETED IN						
			ALL RESPECTSCONTACT:FOR TECHNICAL						



RFQ NUMBER : 2332502913

DATE : 12.11.2025

REQ No : 1032504992

REQ TITLE : Phase 1 Unit 5 Steam Turbine

DELIVERY LOCATION

CLOSING DATE : 24.11.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CLARIFICATION, PLEASE CONTACT # HURAIZ						
			ALGAOUD #0507254						
			949 #						
			HURAIZ.ALGAOUD@DEWA.GOV.AEKARUBBAIYA						
			DURAIKKANNU # 0551584390 -						
			KARUBBAIYA.DURAIKKAN@DEWA.GOV.AESCOPE						
			OF DEWA:1. ALL I&C AND E						
			LECTRICAL INSTRUMENTS SHALL BE						
			DISCONNECTED BY DEWA2. AIR SUPPLY						
			AVAILABLE AT ONE POINT3. POWER SUPPLY IN						
			ONE POINT4. CRANE AS AVAIL						
			ABLE5. IT IS THE RESPONSIBILITY OF THE						
			CONTRACTOR TO HAVE HIS OWNARRANGEMENT						
			IN EXTENDING THE ELECTRICITY AND WATER						
			UTILITY TO HIS P						
			LACESOF WORK. FOR ANY BULK STORAGE OF						
			WATER, CONTRACTOR SHOULD MAKE HIS						
			OWNARRANGEMENT FOR STORAGE TANKS, ETC.6.						
			THE CONTRACTOR, HOW						
			EVER, IS REQUIRED TO FURNISH IN ADVANCE						
			HISREQUIREMENT OF POWER AND AIR WITH FULL						
			JUSTIFICATION. CONTRACTOR SHALLNOT WASTE						
			OR MISUSE						



RFQ NUMBER : 2332502913

DATE : 12.11.2025

REQ No : 1032504992

REQ TITLE : Phase 1 Unit 5 Steam Turbine

DELIVERY LOCATION

CLOSING DATE : 24.11.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE FACILITIES PROVIDED BY DEWA.7.						
			ISOLATIONS AND PERMIT TO WORK OF THE						
			DESIGNATED EQUIPMENT IN LINEWITH DEWA PTW						
			PROCEDURE.8. NECE						
			SSARY ENTRY PERMITS FOR CONTRACTOR						
			PERSONNEL, EQUIPMENT ANDVEHICLES AS PER						
			DEWA PROCEDURE.9. VENDOR HAS TO FOLLOW						
			ALL DEWA STIPULATE						
			D COVID GUIDELINES WHICH MAYSUPERSEDE DHA						
			COVID GUIDELINES.WARRANTY:1. THE WARRANTY						
			PERIOD FOR THE WORKS SHALL BE ONE YEAR						
			FROM THE						
			DATE OFCOMMISSIONING2. IN CASE OF ANY						
			DAMAGE/DEFECT OF THE WORK CARRIED OUT						
			UNDER THISCONTRACT WITHIN THIS WARRANTY						
			PERIOD, THE CONT						
			RACTOR SHALL ATTEND ANDCARRY OUT THE						
			NECESSARY REPAIR / REPLACEMENT WORK AND						
			MAKE GOOD THEDEFECT WITHIN SHORTEST						
			PERIOD. THE CONTRAC						
			TOR WILL PROVIDE 24-HOUREMERGENCY NUMBER						
			AND WILL ENDEAVOR TO BE ONSITE WITHIN 24						
1			HOURS OFRETURN REQUEST BY DEWA.3. ON		1				



RFQ NUMBER : 2332502913

DATE : 12.11.2025

REQ No : 1032504992

REQ TITLE : Phase 1 Unit 5 Steam Turbine

DELIVERY LOCATION

CLOSING DATE : 24.11.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BEING GIVEN A NOTICE OF DEFECT BY DEWA, THE CONTRACTOR SHALLARRANGE TO CARRY OUT THE REPAIR WORK WITHIN THE PRESCRIBED TIME LIMIT ASSET OUT BY DE WA AND ALL SUCH CONTINGENCIES SHALL BE DEEMED TO HAVE BEENCOVERED IN THE OFFER.PAYMENT:PAYMENT WILL BE DONE AS PER ACTUAL WORK						
2		ITEM-00002	D-STATION PHASE 1 STEAM TURBINE BYPASS TO CONDENSER CONTROL ANDISOLATION VALVE SERVICING AND SUPPLY OF SPARESDESCRIPTION OF WORK:1.# OVERHAUL OF ST BYPASS TO CONDENSER CONTROL VALVE & ACTUATOR,QUANTITY: 1 MAKE: COPES-VULCAN, MODEL 0-100-400 (B)2.#OVERHAUL OF ST BYP ASS TO CONDENSER ISOLATION VALVE & ACTUATOR,QUANTITY: 1SCOPE OF WORK: -1. MOBILIZATION OF PEOPLE, MATERIAL, TOOLS AND CONSUMABLES2. RISK ASSESSMENT AND WORK METHOD STATEMENT TO BE SUBMITTED.3. TOOLBOX TALK	1	JOB				



RFQ NUMBER : 2332502913

DATE : 12.11.2025

REQ No : 1032504992

REQ TITLE : Phase 1 Unit 5 Steam Turbine

DELIVERY LOCATION

CLOSING DATE : 24.11.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TO BE GIVEN TO THE CONTRACTOR PEOPLE ON						
			DAILY BASIS.4. COM						
			PLETE DISMANTLEMENT AND REASSEMBLY OF THE						
			VALVE, ACTUATOR, AND ANYOTHER PARTS						
			REQUIRED WILL BE IN THE VENDOR#S SCOPE OF						
			WORK.5. INSP						
			ECTION OF EVERY PART OF THE VALVE AND						
			ACTUATOR6. INSPECTION WITH NDT7. SUPPLY OF						
			SPARES SUCH AS O RINGS, GASKETS, PACKING,						
			LOCK RING						
			S, ANDREPAIR WORK SUCH AS MACHINING ARE IN						
			THE VENDOR#S SCOPE OF WORK8. REASSEMBLY						
			OF THE VALVE, ACTUATOR, AND ANY OTHER						
			PARTS DISMA						
			NTLED ISIN THE VENDOR#S SCOPE OF WORK9.						
			LEAK AND FUNCTIONAL TEST OF THE VALVE.10.						
			LIFTING SHALL BE CARRIED OUT BY THE VENDOR.						
			ALL RE						
			QUIRED TOOLS FORLIFTING SHOULD BE BROUGHT						
			BY THE VENDOR. IN ADDITION TO THAT,						
			ALLLIFTING TOOLS SHOULD HAVE VALID						
			CERTIFICATES.11. TR						
			ANSPORTATION OF THE PARTS FROM THE POWER						



RFQ NUMBER : 2332502913

DATE : 12.11.2025

REQ No : 1032504992

REQ TITLE : Phase 1 Unit 5 Steam Turbine

DELIVERY LOCATION

CLOSING DATE : 24.11.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PLANT SHALL BE CARRIEDOUT BY THE VENDOR12.						
			SUBMISSION OF REPORT OF WORK DONE13.						
			PARTS TO BE						
			PAINTED WITH THE SAME COLOR.14. WORK WILL						
			BE CARRIED OUT AS PER DEWA WORK						
			SCHEDULE.15. DEWA HEALTH, SAFETY AND						
			ENVIRONMENT POLICY W						
			ILL BE FOLLOWED16. WORK TO BE COMPLETED IN						
			ALL RESPECTSCONTACT:FOR TECHNICAL						
			CLARIFICATION, PLEASE CONTACT # HURAIZ						
			ALGAOUD #0507254						
			949 #						
			HURAIZ.ALGAOUD@DEWA.GOV.AEKARUBBAIYA						
			DURAIKKANNU # 0551584390 -						
			KARUBBAIYA.DURAIKKAN@DEWA.GOV.AESCOPE						
			OF DEWA:1. ALL I&C AND E						
			LECTRICAL INSTRUMENTS SHALL BE						
			DISCONNECTED BY DEWA2. AIR SUPPLY						
			AVAILABLE AT ONE POINT3. POWER SUPPLY IN						
			ONE POINT4. CRANE AS AVAIL						
			ABLE5. IT IS THE RESPONSIBILITY OF THE						
			CONTRACTOR TO HAVE HIS OWNARRANGEMENT						
			IN EXTENDING THE ELECTRICITY AND WATER						



RFQ NUMBER : 2332502913

DATE : 12.11.2025

REQ No : 1032504992

REQ TITLE : Phase 1 Unit 5 Steam Turbine

DELIVERY LOCATION

CLOSING DATE : 24.11.2025 **CLOSING TIME** : 10:00:00

ITEM CODE SERVICE ID **BRAND/ORIGIN UNIT PRICE** SL NO **DESCRIPTION** QTY **UOM** WARRANTY **TOTAL PRICE** UTILITY TO HIS P LACESOF WORK. FOR ANY BULK STORAGE OF WATER, CONTRACTOR SHOULD MAKE HIS OWNARRANGEMENT FOR STORAGE TANKS, ETC.6. THE CONTRACTOR, HOW EVER, IS REQUIRED TO FURNISH IN ADVANCE HISREQUIREMENT OF POWER AND AIR WITH FULL JUSTIFICATION, CONTRACTOR SHALLNOT WASTE OR MISUSE THE FACILITIES PROVIDED BY DEWA.7. ISOLATIONS AND PERMIT TO WORK OF THE DESIGNATED EQUIPMENT IN LINEWITH DEWA PTW PROCEDURE.8. NECE SSARY ENTRY PERMITS FOR CONTRACTOR PERSONNEL. EQUIPMENT ANDVEHICLES AS PER DEWA PROCEDURE.9. VENDOR HAS TO FOLLOW ALL DEWA STIPULATE D COVID GUIDELINES WHICH MAYSUPERSEDE DHA COVID GUIDELINES.WARRANTY: 1. THE WARRANTY PERIOD FOR THE WORKS SHALL BE ONE YEAR FROM THE DATE OF COMMISSIONING 2. IN CASE OF ANY

DAMAGE/DEFECT OF THE WORK CARRIED OUT



RFQ NUMBER : 2332502913

DATE : 12.11.2025

REQ No : 1032504992

REQ TITLE : Phase 1 Unit 5 Steam Turbine

DELIVERY LOCATION

CLOSING DATE : 24.11.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			UNDER THISCONTRACT WITHIN THIS WARRANTY						
			PERIOD, THE CONT						
			RACTOR SHALL ATTEND ANDCARRY OUT THE						
			NECESSARY REPAIR / REPLACEMENT WORK AND						
			MAKE GOOD THEDEFECT WITHIN SHORTEST						
			PERIOD. THE CONTRAC						
			TOR WILL PROVIDE 24-HOUREMERGENCY NUMBER						
			AND WILL ENDEAVOR TO BE ONSITE WITHIN 24						
			HOURS OFRETURN REQUEST BY DEWA.3. ON						
			BEING GIVEN A						
			NOTICE OF DEFECT BY DEWA, THE CONTRACTOR						
			SHALLARRANGE TO CARRY OUT THE REPAIR						
			WORK WITHIN THE PRESCRIBED TIME LIMIT ASSET						
			OUT BY DE						
			WA AND ALL SUCH CONTINGENCIES SHALL BE						
			DEEMED TO HAVE BEENCOVERED IN THE						
			OFFER.PAYMENT:PAYMENT WILL BE DONE AS PER						
			ACTUAL WORK						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Phase 1 Unit 5 Steam Turbine Bypass to Condenser control and stop valve



RFQ NUMBER : 2332502913

DATE : 12.11.2025

REQ No : 1032504992

REQ TITLE : Phase 1 Unit 5 Steam Turbine

DELIVERY LOCATION

CLOSING DATE : 24.11.2025

CLOSING TIME : 10:00:00

servicing

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6)Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.



RFQ NUMBER : 2332502913

DATE : 12.11.2025

REQ No : 1032504992

REQ TITLE : Phase 1 Unit 5 Steam Turbine

DELIVERY LOCATION

SUPPLIER'S REMARKS:

SUPPLIER'S SIGNATURE AND STAMP