

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502945
DATE : 17.11.2025
REQ No : 1032505450
REQ TITLE : CCB Chiller 1032505450
DELIVERY LOCATION
CLOSING DATE : 21.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SCOPE OF WORK THE JOB INVOLVES THE SUPPLY AND REPLACEMENT OF A TOTAL OF FIVE CONDENSER COILS IN CCB CHILLER UNITS, WITH EACH COIL MEASURING 64 INCHES IN LENGTH, 40 INCHES IN HEIGHT, 3 ROWS, AND 3/8-INCH THICKNESS. THE KEY TASKS INCLUDE: 1) REMOVAL OF THE EXISTING DETERRIORATED CONDENSER COILS FROM THE RESPECTIVE UNITS AFTER RECOVERING THE REFRIGERANT (R134A). 2) SUPPLY & INSTALLATION OF NEW COPPER-COPPER CONDENSER COILS WITH DIPTYPE ANTI-CORROSION PROTECTION COATING (PREFERABLY WITH BRONZE-GLOW HUSKY GOLD MAKE WITH DIP COATING). 3) PAINTING OF RESPECTIVE CIRCUIT OUTDOOR UNIT WITH ANTI-CORROSIVE PAINT. 4) REASSEMBLY OF THE STRUCTURES AND FRAMES ASSOCIATED WITH NEW CONDENSER COIL. 5) BRAZING OF ALL THE JOINTS AND CARRYING OUT PRESSURE TEST WITH NITROGEN (400 PSI) FOR 48 HRS. 6) VACUUMING OF COMPLETE R	5	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502945
DATE : 17.11.2025
REQ No : 1032505450
REQ TITLE : CCB Chiller 1032505450
DELIVERY LOCATION
CLOSING DATE : 21.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REFRIGERATION CIRCUIT FOR MINIMUM 12 HRS.7) RECHARGING RECOVERED REFRIGERANT (R134A) AND TOPPING UP, IF REQUIRED.PREFERABLYCHEMOURS O R HONEYWELL BRAND.8) COMMISSIONING OF THE REFURBISHED SYSTEM, CARRYING OUT PERFORMANCETEST AND SUBMISSION OF REPORTS.9) AFTER REPLAC EMENT OF COIL, THE EXISTING REFRIGERANT OIL AND FILTERDRIER CORE SHALL BE REPLACED AFTER FIRST RUN. THE SAME SHOULD BEREPLACED ONE M ORE TIME, AFTER RUNNING THE UNIT FOR ABOUT SIX MONTHS, INORDER TO ELIMINATE ANY KIND OF FOREIGN MATERIALS IN THE REFRIGERATIONCIRCUI T, BEFORE HANDING OVER.10) TOP-UP OF REFRIGERANT (R134A), DRIER CORE AND OIL SHALL BE PROVIDEDBY THE SUPPLIER.11) COIL SIZE: TOTAL 8 COILS, LENGTH 64 INCHES X HEIGHT 40 INCHES, 3ROW, 3/8 INCH.GENERAL CONDITIONS:1. THE BIDDER SHALL VISIT THE SITE AND TAKE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502945
DATE : 17.11.2025
REQ No : 1032505450
REQ TITLE : CCB Chiller 1032505450
DELIVERY LOCATION
CLOSING DATE : 21.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NECESSARY MEASUREMENTS OF THE CONDENSER COILS TO BE REPLACED. 2. VENDOR SHALL PROVIDE US THE GENERAL ARRANGEMENT, DIMENSIONAL DRAWING, MATERIALS SPECIFICATION & COATING SPECIFICATIONS TO DEWA FOR REFERENCE. 3. HOT WORK PERMIT SHALL BE TAKEN FOR WORKS LIKE DRILLING/WELDING/CUTTING. 4. COILS SHALL BE DIP TYPE ANTI-CORROSION PROTECTION COATING (PREFERABLY WITH BRONZE-GLOW HUSKY GOLD MAKE). 5. ALL SUPPORTS, NUTS AND BOLTS ETC. SHALL BE EXCELLENT CORROSION PROTECTION MATERIAL. ALL BOLTS AND NUTS SHOULD BE IN SS MATERIAL. 6. NECESSARY TOOLS, INSTRUMENTS AND OTHER CONSUMABLES REQUIRED TO CARRY OUT THE JOB SHALL BE ARRANGED BY THE CONTRACTOR. 7. ANY OTHER WORK NOT EXPLICITLY INDICATED HERE BUT REQUIRED FOR EFFICIENT AND RELIABLE OPERATION OF THE EQUIPMENT ALSO						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502945
DATE : 17.11.2025
REQ No : 1032505450
REQ TITLE : CCB Chiller 1032505450
DELIVERY LOCATION
CLOSING DATE : 21.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NEEDS TO BE CONSIDERED.8. THE CONTRACTOR SHALL OBTAIN PERMIT-TO-WORK (PTW)/LINE CLEARANCE (LC) FROM ELECTRICAL MAINTENANCE STAFF, BEFORE CARRYING OUT ANY JOB. NO JOBS SHALL BE DONE WITHOUT ANY VALID PTW/LC. WORKS LIKE DRILLING/ WELDING / CUTTING SHALL BE CARRIED OUT ONLY AFTER ENSURING THAT HOT WORK PERMIT FOR THE WORK FOR THE DAY IS AVAILABLE.9. THE CONTRACTOR SHALL ABIDE BY THE SAFETY AND SECURITY RULES AND REGULATIONS IN FORCE AT JEBEL ALI POWER STATION.10. CONTRACTOR SHALL CLEAR ALL REMOVED OLD CONDENSER COILS FROM THE SITE WITHOUT ANY DELAY.11. IT IS CONTRACTOR RESPONSIBILITY TO TAKE ACTUAL MEASUREMENTS OF COILS AS PER SITE REQUIREMENTS.12. DISCONNECTION OF CONDENSER FAN MOTOR & REFIXING & CONNECTION CONTRACTOR SCOPE.13. ALL NECESSARY ARRANGEMENT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502945
DATE : 17.11.2025
REQ No : 1032505450
REQ TITLE : CCB Chiller 1032505450
DELIVERY LOCATION
CLOSING DATE : 21.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RELATED TO HEALTH, SAFETY AND PROTECTION OF ENVIRONMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING SHALL BE MADE BY THE CONTRACTOR AT HIS OWN COST: A) PROVISION OF PROPER PPES (PERSONAL PROTECTIVE EQUIPMENT#S) TO THEIR STAFF, B) PROPER SCAFFOLDING, ACCESS AND SAFE ARRANGEMENTS (E.G. RIGID PLATFORMS, HANDRAILS ETC.) FOR WORKING AT HEIGHTS. C) USE OF CERTIFIED LIFTING AND RIGGING EQUIPMENT, ELECTRICAL PORTABLE HAND TOOLS / APPARATUS. D) THE SITE SUPERVISOR / WORKING CREW SHALL ENSURE THAT HOUSEKEEPING IS ENSURED AFTER COMPLETING THE WORK. E) THE WORK SHALL BE CARRIED OUT IN A NEAT, ORDERLY AND SAFE MANNER. THE CONTRACTOR WILL BE HELD RESPONSIBLE FOR ANY DAMAGE FOR THE EXISTING UNITS, WHICH MAY OCCUR DUE TO FAILURE TO COMPLY WITH THE ABOVE REQUIREMENT. F) THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502945
DATE : 17.11.2025
REQ No : 1032505450
REQ TITLE : CCB Chiller 1032505450
DELIVERY LOCATION
CLOSING DATE : 21.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONTRACTOR SHALL INFORM THE ENGINEER/FOREMAN PRIOR TO START OF THE WORK AND SHALL COMPLIANCE WITH PERMIT TO WORK PROCEDURE OF DEWA, REGARDING THE JOB TO BE CARRIED OUT ON THAT DAY AND INFORM THE WORK DONE AT THE END OF THE DAY. D. WARRANTY: A) 1 YEAR OF WARRANTY FOR THE COMPLETE COIL AND WORKMANSHIP AFTER SUCCESSFUL REFURBISHMENT. B) 7 YEARS OF WARRANTY FOR THE COATING ON THE COIL. IF ANY WORKMANSHIP DEFECTS ARE NOTICED, THE SAME SHALL BE RECTIFIED WITHIN 3 WORKING DAYS WITH ALL THE MATERIALS REQUIRED TO RESTORE THE UNIT. CCB CHILLER # TOTAL COILS # 5 NOS. CHILLER 2, S3 A -1 COIL CHILLER 4, S5-A & D 2 COILS CHILLER 4, S6-A & B 2 COILS FOR ANY TECHNICAL CLARIFICATION PLEASE CONTACT MR. KHALID 04-8024552 MOB. 0553972853 E MAIL: KHALID.HUSSAIN@DEWA.GOV.AE , #. MOHANAKRISHNAN#04-8024558 MOB 0503667						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502945
DATE : 17.11.2025
REQ No : 1032505450
REQ TITLE : CCB Chiller 1032505450
DELIVERY LOCATION
CLOSING DATE : 21.11.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			795 #GANAPAGHY.KRISHNAN@DEWA.GOV.AE#, MR. ERNANNUQUI SANTOS MOB. 0588893724 E MAIL: ERNAN.SANTOS@DEWA.GOV.AE ,MR. #MANIKANDAN# #MANI KANDAN.MURUGESAN@DEWA.GOV.AE , 0551925955,04-3226281.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

CCB Chiller

For EMD-L1

CCB Chiller 2 <(><)> 4 condenser coil replacement job.

Note: Bidders may be asked to have a site survey to clearly understand the requirement, before giving their offer.

For any technical clarification please contact Mr. Khalid 04-8024552

Mob. 0553972853 E Mail: khalid.hussain@dewa.gov.ae , . Mohanakrishnan

04-8024558 Mob: 0503667795 Ganapaghy.Krishnan@dewa.gov.ae, Mr. Ernan

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502945
DATE : 17.11.2025
REQ No : 1032505450
REQ TITLE : CCB Chiller 1032505450
DELIVERY LOCATION
CLOSING DATE : 21.11.2025
CLOSING TIME : 10:00:00

Nuqui Santos Mob. 0588893724 E mail: ernan.santos@dewa.gov.ae , Mr.
Manikandan manikandan.murugesan@dewa.gov.ae , 0551925955, 04-3226281.

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
 - 2) Quotation to be submitted only in local currency U.A.E Dirhams
 - 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
 - 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
 - 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
 - 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.
- If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
- The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332502945
DATE : 17.11.2025
REQ No : 1032505450
REQ TITLE : CCB Chiller 1032505450
DELIVERY LOCATION
CLOSING DATE : 21.11.2025
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP