

RFQ NUMBER : 2332503025

DATE : 20.11.2025

REQ No : 1032505683

REQ TITLE: FOR EMD L1 STATION.

DELIVERY LOCATION

CLOSING DATE : 26.11.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SUPPLY, INSTALLATION, TESTING AND	1	EA				
			COMMISSIONING SERVICES FOR ABB						
			MAKEREF542PLUS RELAY WITH MAINTENANCE						
			EXCHANGE BASIS IN GT71 AUTOMI						
			ZING AMOTOR FEEDER.MOTOR RELAY DETAILS:						
			REF542PLUS WITH BASE UNIT WITH HMI; ANALOG						
			INPUTS:4CTS, 2VT; 28 DI AND 16 DO; POWER						
			SUPPLY:						
			110VDC.SCOPE OF WORKS:1) DISCONNECT THE						
			CABLES AND REMOVE THE EXISTING RELAY FROM						
			THE PANEL.2) INSTALL THE BASE UNIT OF THE						
			NEW RELA						
			Y.3) REQUIRED CUTOUT ON THE PANEL TO BE						
			MADE AND INSTALL THE HMI UNIT.4)						
			CONNECTIONS FOR THE NEWLY INSTALLED						
			RELAY.5) CONFIGURE THE						
			RELAY AND DO RELAY SETTING, TESTING AND						
			COMMISSIONING.6) CHECK THE FUNCTIONAL OPERATION OF ALL BINARY INPUTS AND						
			OUTPUTS.7) SUBMIT T						
1			HE SITE TEST REPORT AND COMMISSIONING						
1			REPORT.8) BEFORE SUBMITTING THE QUOTE,						
			PARTY SHOULD VISIT THE SITE TOUNDERSTAND						



RFQ NUMBER : 2332503025

DATE : 20.11.2025

REQ No : 1032505683

REQ TITLE: FOR EMD L1 STATION.

DELIVERY LOCATION

CLOSING DATE : 26.11.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE ACTUAL REQ UIREMENT.9) PARTY SHOULD QUOTE THE PRICE IN AED ONLY WITH DETAILED SPLIT UP FORTHE COST.10) WARRANTY SHALL BE PROVIDED FOR BOTH RELA YS AND WORKMANSHIP FOR1-YEAR AFTER TESTING AND COMMISSIONING OF RELAY UNIT.						
2		ITEM-00001	SUPPLY, INSTALLATION, TESTING AND COMMISSIONING SERVICES FOR ABB MAKEREF542PLUS RELAY WITH MAINTENANCE EXCHANGE BASIS IN GT71 EXCITA TIONTRANSFORMER FEEDER.TRANSFORMER RELAY DETAILS: REF542PLUS WITH BASE UNIT WITH HMI; ANALOGINPUTS: 3CTS; 2VTS; 28 DI AND 16 DO; POW ER SUPPLY: 110VDC.SCOPE OF WORKS:1) DISCONNECT THE CABLES AND REMOVE THE EXISTING RELAY FROM THE PANEL.2) INSTALL THE BASE UNIT OF T HE NEW RELAY.3) REQUIRED CUTOUT ON THE PANEL TO BE MADE AND INSTALL THE HMI UNIT.4) CONNECTIONS FOR THE NEWLY INSTALLED RELAY.5) CON	1	EA				



RFQ NUMBER : 2332503025

DATE : 20.11.2025

REQ No : 1032505683

REQ TITLE: FOR EMD L1 STATION.

DELIVERY LOCATION

CLOSING DATE : 26.11.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FIGURE THE RELAY AND DO RELAY SETTING, TESTING AND COMMISSIONING.6) CHECK THE FUNCTIONAL OPERATION OF ALL BINARY INPUTS AND OUTPUTS. 7) SUBMIT THE SITE TEST REPORT AND COMMISSIONING REPORT.8) BEFORE SUBMITTING THE QUOTE, PARTY SHOULD VISIT THE SITE TOUNDERSTAND THE ACTUAL REQUIREMENT.9) PARTY SHOULD QUOTE THE PRICE IN AED ONLY WITH DETAILED SPLIT UP FORTHE COST.10) WARRANTY SHALL BE PROVIDED FO R BOTH RELAYS AND WORKMANSHIP FOR1-YEAR AFTER TESTING AND COMMISSIONING OF RELAY UNIT.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

FOR EMD L1 STATION.





RFQ NUMBER : 2332503025

DATE : 20.11.2025

REQ No : 1032505683

REQ TITLE: FOR EMD L1 STATION.

DELIVERY LOCATION

CLOSING DATE : 26.11.2025

CLOSING TIME : 10:00:00

SUPPLY, INSTALLATION, TESTING AND COMMISSIONING SERVICES FOR 2NOS OF ABB MAKE REF542PLUS RELAY IN GT71 AUTOMIZING A MOTOR FEEDER <(>&<)> GT71 EXCITATION TRANSFORMER FEEDER.

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6)Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.



RFQ NUMBER : 2332503025

DATE : 20.11.2025

REQ No : 1032505683

REQ TITLE : FOR EMD L1 STATION.

DELIVERY LOCATION

SUPPLIER'S REMARKS:

SUPPLIER'S SIGNATURE AND STAMP