

RFQ NUMBER : 2332503030

DATE : 21.11.2025

REQ No : 1032505521

REQ TITLE : REFURBISHMENT AND

DELIVERY LOCATION

CLOSING DATE : 27.11.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF	2	EA				
			OUTSOURCING WORKL-2 STATION, JEBEL ALI						
			POWER STATIONTITLE:#REFURBISHMENT AND						
			TESTING OF HP/L						
			PHYDRAULIC ACTUATOR QTY						
			2NOS.REFURBISHMENT AND TESTING OF HP-LP						
			STOP VALVE HYDRAULIC ACTUATORPISTON						
			LENGTH110 & DIA 80 MM2.REFURBISH						
			MENT AND TESTING ALL MEASUREMENTSARE						
			APPROXIMATELY, AND FINAL MEASUREMENT TO						
			BE COLLECTED AND CHECKED BYVENDOR						
			BEFORE QUOTEPERIOD OF						
			WORK:###REFURBISHMENT & TESTING: 10						
			DAYSSCOPE OF WORK FOR HYDRAULIC						
			ACTUATOR REFURBISHMENT:###THE						
			CONTRACTOR SHALL VISIT THE SITE A						
			ND MAKE HIMSELF FULLY FAMILIARWITH THE						
			WORK SCOPE.###SUBMIT DETAILED SCHEDULE						
			AND RISK ASSESSMENT / METHOD STATEMENT						
			OFTHE WORK IN A						
			DVANCE TO DEWA.###OBTAIN GATE PASS FOR THE						
			STAFFS AND PERMIT TO WORK (FOR						
			THISCONTRACTOR HAS TO SUBMIT THE						



RFQ NUMBER : 2332503030

DATE : 21.11.2025

REQ No : 1032505521

REQ TITLE : REFURBISHMENT AND

DELIVERY LOCATION

CLOSING DATE : 27.11.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NECESSARY GATE ENTRY PASS						
			DOCUMENTS, TODEWA ENGINEER WELL IN						
			ADVANCE)###SITE MOBILIZATION / WORK						
			PREPARATION ONE DAY IN ADVANCE###TBT TO BE						
			SIGN DAILY###DEWA						
			SAFETY RULES TO BE FOLLOW STRICTLY###ALL						
			TOOLS / LIFTING EQUIPMENT (CHAIN BLOCK , BELT						
			,) SHALL BEUNDER CONTRACT SCOPE AND TEST						
			CERTIFICATE TO BE PROVIDE IN						
			ADVANCE###WORK WILL CARRY OUT WITH						
			SPECIALIZED TECHNICIANS WITH						
			CLOSESUPERVISION SITE ENGINEER.###COLLE						
			CTION AND TRANSPORTATION OF THE CYLINDERS						
			FROM DEWA L-2 STATIONTO CONTRACTOR						
			WORKSHOP.NOTE: HYDRAULIC HOSES						
			CONNECTED TO CYLINDERS T						
			OBE COVERED PROPERLY DURING						
			TRANSPORTATION OFTHE CYLINDER AFTER						
			REMOVALOF CYLINDERS.###DISMANTLING,						
			CLEANING, INSPECTION OF HYDRAULI						
			C CYLINDER COMPONENTS.###INFORM DEWA FOR						
			ANY DAMAGE NOTICED.###POLISHING/HONING OF						
			CYLINDER PISTON.###CHROMING OF PISTON						



RFQ NUMBER : 2332503030

DATE : 21.11.2025

REQ No : 1032505521

REQ TITLE : REFURBISHMENT AND

DELIVERY LOCATION

CLOSING DATE : 27.11.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ROD/TUBE.##						
			#SEALS REPLACEMENT. (CONSUMABLE SUPPLIED						
			BY DEWA)###ASSEMBLING OF CYLINDER USING						
			SEAL KIT SUPPLIED BY DEWA###TESTING OF						
			CYLINDER IN						
			PRESENCE OF DEWA REPRESENTATIVE.###TEST						
			SHALL BE DONE AT 250 BAR. THE ACCEPTANCE						
			CRITERIA FOR THEPRESSURE DROP SHOULD BE						
			LESSTHAN 2						
			BAR WITHIN 10 MINUTES. DIGITAL						
			GRAPHRECORDER TO BE USED DURING THE						
			TEST###PUNCHING THE UNIQUE NUMBER ON THE						
			CYLINDER AND MENTION THE						
			SAMEUNIQUE NUMBER IN						
			THEREPORT.###PROVIDING TEST CERTIFICATE						
			WITH ONE-YEAR WARRANTY.###DELIVERY BACK						
			TO DEWA L-2 STORE WITHIN 5 DAY						
			SDEWA SCOPE:###CONSUMABLE SPARE###FORK						
			LIFT###CRANEWARRANTY :###THE WARRANTY						
			PERIOD FOR THE WORKS/REPAIR SHALL BE ONE						
			YEAR FROM THED						
			ATE OF COMPLETION OFWORKS CERTIFIED BY						
			DEWA.### IN CASE OF ANY DAMAGE/DEFECT OF						



RFQ NUMBER : 2332503030

DATE : 21.11.2025

REQ No : 1032505521

REQ TITLE : REFURBISHMENT AND

DELIVERY LOCATION

CLOSING DATE : 27.11.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE WORK CARRIED OUT UNDER THISCONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND ANDCARRY OUT THE NECESSARY REPAIR WORK AND MAKE GOOD THE DEFECT WITHINSHORT PERIOD WITH OUT AFFECTING THE PRODUCTION OF ELECTRICITY AND WATER						
2		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORKL-2 STATION, JEBEL ALI POWER STATIONTITLE:#REFURBISHMENT AND TESTING OF HP/L P & HP-IP HYDRAULIC ACTUATOR QTY 5NOS1.REFURBISHMENT AND TESTING OF HP-LP STOP VALVE HYDRAULIC ACTUATORPISTON LENGTH110 & DIA 80 MM2 .REFURBISHMENT AND TESTING OF HP-IP TCVHYDRAULIC ACTUATOR PISTON LENGTH 80 & DIA 30 MMNOTE: ALL MEASUREMENTSARE APPROXIMATELY, AND F INAL MEASUREMENT TO BE COLLECTED AND CHECKED BYVENDOR BEFORE QUOTEPERIOD OF WORK:###REFURBISHMENT & TESTING: 10	3	EA				



RFQ NUMBER : 2332503030

DATE : 21.11.2025

REQ No : 1032505521

REQ TITLE : REFURBISHMENT AND

DELIVERY LOCATION

CLOSING DATE : 27.11.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DAYSSCOPE OF WORK FO						
			R HYDRAULIC ACTUATOR REFURBISHMENT:###THE						
			CONTRACTOR SHALL VISIT THE SITE AND MAKE						
			HIMSELF FULLY FAMILIARWITH THE WORK						
			SCOPE.###SUBM						
			IT DETAILED SCHEDULE AND RISK ASSESSMENT /						
			METHOD STATEMENT OFTHE WORK IN ADVANCE						
			TODEWA.###OBTAIN GATE PASS FOR THE STAFFS						
			AND PERM						
			IT TO WORK (FOR THISCONTRACTOR HAS TO						
			SUBMIT THENECESSARY GATE ENTRY PASS						
			DOCUMENTS, TO DEWAENGINEER WELL IN						
			ADVANCE)###SITE MOBILIZ						
			ATION / WORK PREPARATION ONE DAY IN						
			ADVANCE###TBT TO BE SIGN DAILY###DEWA						
			SAFETY RULES TO BE FOLLOW STRICTLY###ALL						
			TOOLS / LIFTING E						
			QUIPMENT (CHAIN BLOCK , BELT ,) SHALL						
			BEUNDER CONTRACT SCOPE AND						
			TESTCERTIFICATE TO BE PROVIDE IN						
			ADVANCE###WORK WILL CARRY OUT W						
			ITH SPECIALIZED TECHNICIANS WITH						
			CLOSESUPERVISION SITE						



RFQ NUMBER : 2332503030

DATE : 21.11.2025

REQ No : 1032505521

REQ TITLE : REFURBISHMENT AND

DELIVERY LOCATION

CLOSING DATE : 27.11.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ENGINEER.###COLLECTION AND						
			TRANSPORTATION OF THE CYLINDERS FROM						
			DEWA L-2 STAT						
			IONTO CONTRACTOR WORKSHOP.NOTE:						
			HYDRAULIC HOSES CONNECTED TO CYLINDERS						
			TOBE COVERED PROPERLY DURING						
			TRANSPORTATION OFTHE CYLINDER AF						
			TER REMOVALOF CYLINDERS.###DISMANTLING,						
			CLEANING, INSPECTION OF HYDRAULIC CYLINDER						
			COMPONENTS.###INFORM DEWA FOR ANY						
			DAMAGE NOTICED.						
			###POLISHING/HONING OF CYLINDER						
			PISTON.###CHROMING OF PISTON						
			ROD/TUBE.###SEALS REPLACEMENT.						
			(CONSUMABLE SUPPLIED BY DEWA)###ASSEMBLI						
			NG OF CYLINDER USING SEAL KIT SUPPLIED BY						
			DEWA###TESTING OF CYLINDER IN PRESENCE OF						
			DEWA REPRESENTATIVE.###TEST SHALL BE DONE						
			AT 250						
			BAR. THE ACCEPTANCE CRITERIA FOR						
			THEPRESSURE DROP SHOULD BE LESSTHAN 2						
			BAR WITHIN 10 MINUTES. DIGITAL						
			GRAPHRECORDER TO BE USED DURI						



RFQ NUMBER : 2332503030

DATE : 21.11.2025

REQ No : 1032505521

REQ TITLE : REFURBISHMENT AND

DELIVERY LOCATION

CLOSING DATE : 27.11.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NG THE TEST###PUNCHING THE UNIQUE NUMBER						
			ON THE CYLINDER AND MENTION THE						
			SAMEUNIQUE NUMBER IN						
			THEREPORT.###PROVIDING TEST CERTIFICAT						
			E WITH ONE-YEAR WARRANTY.###DELIVERY BACK						
			TO DEWA L-2 STORE WITHIN 5 DAYSDEWA						
			SCOPE:###CONSUMABLE SPARE###FORK						
			LIFT###CRANEWARRANTY						
			:###THE WARRANTY PERIOD FOR THE						
			WORKS/REPAIR SHALL BE ONE YEAR FROM						
			THEDATE OF COMPLETION OFWORKS CERTIFIED						
			BY DEWA.### IN CASE OF A						
			NY DAMAGE/DEFECT OF THE WORK CARRIED OUT						
			UNDER THISCONTRACT WITHIN THIS WARRANTY						
			PERIOD, THE CONTRACTOR SHALL ATTEND						
			ANDCARRY OUT TH						
			E NECESSARY REPAIR WORK AND MAKE GOOD						
			THE DEFECT WITHINSHORT PERIOD WITHOUT						
			AFFECTING THE PRODUCTION OF ELECTRICITY						
			AND WATER.						

TOTAL AMOUNT IN WORDS: TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:





RFQ NUMBER : 2332503030

DATE : 21.11.2025

REQ No : 1032505521

REQ TITLE : REFURBISHMENT AND

DELIVERY LOCATION

CLOSING DATE : 27.11.2025

CLOSING TIME : 10:00:00

REFURBISHMENT AND TESTING OF HP/LP <(>&<)> HP-IP HYDRAULIC ACTUATOR QTY5 NOSAT L-2 STATION For more information Please Coordinate with Mr. Arunkumar Sethuraman Regarding arunkumar.sethuraman@dewa.gov.ae 04-322-6104 any support & update.

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6)Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.



RFQ NUMBER : 2332503030

DATE : 21.11.2025

REQ No : 1032505521

REQ TITLE : REFURBISHMENT AND

DELIVERY LOCATION

SUPPLIER'S REMARKS:

SUPPLIER'S SIGNATURE AND STAMP