

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503086
DATE : 28.11.2025
REQ No : 1032505794
REQ TITLE : JAPS L1-STATION, Servicing, R
DELIVERY LOCATION
CLOSING DATE : 04.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	REPAIR OF GE FRAME-9FA, ACTUATOR FOR AUX GAS STOP VALVE ACTUATOR FOR AUXGAS STOP VALVE, GE PART # 371A6421P011,RCO-280-FC087-ST-N-RA -0-Q-P-F16-46-C, MAX PRESSURE: 0,8MPA/8BAR/116PSI,MAX VOLUME: 15,6l, OPRATE MEDIA: PED NON-DANGEROUS, FLUID GROUP 2,DIRECTIVE 2014/6 8/EU, ART. NO: 184099, MANUFACTURER: ROTORK FLUID SYSTEMSCOPE OF WORK FOR SERVICING, REPAIRING, AND TESTING OF ACTUATOR FORAUXILIARY GAS VALVE:SCOPE OVERVIEW:THE SCOPE INCLUDES SERVICING, REPAIRING, AND TESTING THE ACTUATOR OF THEAUXILIARY GAS VALVE TO ENSURE PROP ER FUNCTIONALITY AND SAFETY. THE WORKWILL BE CARRIED OUT BY QUALIFIED PERSONNEL IN ACCORDANCE WITH INDUSTRYSTANDARDS AND MANUFACTURE R GUIDELINES.SCOPE OF WORK:1.#COLLECTION: COLLECT THE ACTUATOR FROM DEWA.2.#INITIAL INSPECTION: VISUAL INSPECTION OF THE	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503086
DATE : 28.11.2025
REQ No : 1032505794
REQ TITLE : JAPS L1-STATION, Servicing, R
DELIVERY LOCATION
CLOSING DATE : 04.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ACTUATOR FOR ANY SIGNS OF DAMAGE OR WEAR. CHECK FOR PROPER ALIGNMENT AND MOUNTING OF THE ACTUATOR. VERIFY ELECTRICAL CONNECTIONS AND WIRING INTEGRITY.3.#SERVICING: CLEAN AND LUBRICATE THE ACTUATOR AS PER MANUFACTURER RECOMMENDATIONS. REPLACE ANY DAMAGED OR WORN PARTS, SUCH AS SEALS OR GASKETS. ENSURE ALL COMPONENTS ARE FUNCTIONING CORRECTLY.4.#REPAIR: ADDRESS ANY IDENTIFIED ISSUES, SUCH AS LEAKS OR MECHANICAL FAILURES. REPLACE FAULTY COMPONENTS WITH NEW (PROVIDED BY CONTRACTOR), MANUFACTURER-APPROVED PARTS. CONDUCT NECESSARY ADJUSTMENTS TO ENSURE PROPER OPERATION.5.#TESTING: PERFORM FUNCTIONAL TESTING OF THE ACTUATOR TO ENSURE IT OPERATES AS INTENDED. CONDUCT PERFORMANCE TESTS UNDER SIMULATED CONDITIONS. VERIFY THAT THE ACTUATOR RESPONDS CORRECTLY TO						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503086
DATE : 28.11.2025
REQ No : 1032505794
REQ TITLE : JAPS L1-STATION, Servicing, R
DELIVERY LOCATION
CLOSING DATE : 04.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONTROLSIGNALS.6.#DOCUMENTATION: PROVIDE A DETAILED REPORT OF THE WORK PERFORMED,INCLUDING BEFORE-AND-AFTER PHOTOS (IF APPLICABLE). RECORD ALLMAINTENANCE AND REPAIR ACTIVITIES, INCLUD ING PARTS REPLACED AND TESTINGRESULTS.7.#SAFETY: ADHERE TO ALL SAFETY PROTOCOLS AND GUIDELINES DURING THESERVICING, REPAIR, AND TEST ING PROCESSES. ENSURE PROPER LOCKOUT/TAGOUTPROCEDURES ARE FOLLOWED WHEN WORKING ON THE ACTUATOR.8.#COMPLETION: UPON COMPLETION OF TH E WORK, ENSURE SAFE DELIVERY OF THEMATERIAL TO DEWA. PROVIDE A FINAL REPORT DETAILING THE WORK PERFORMED,INCLUDING ANY RECOMMENDATIO NS FOR FUTURE MAINTENANCE OR REPAIRS.NOTE:THIS SCOPE OF WORK IS INTENDED TO OUTLINE THE GENERAL TASKS ANDREQUIREMENTS FOR SERVICING,						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503086
DATE : 28.11.2025
REQ No : 1032505794
REQ TITLE : JAPS L1-STATION, Servicing, R
DELIVERY LOCATION
CLOSING DATE : 04.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REPAIRING, AND TESTING THE ACTUATOR OF THEAUXILIARY GAS VALVE. SPECIFIC DETAILS MAY VARY BASED ON THE EQUIPMENTAND MANUFACTURER SPECIFICATIONS.CONTACT PERSON FROM DEWA 1. SYED SHOWKAT ALI - SYEDS.ALI@DEWA.GOV.AE /048140513 OR 2. MUHAMMAD SHAMIM KHAN-MUHAMMAD.KHAN@DEWA.GOV.AE /043226023 / 050-2806027						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

JAPS L1-STATION, Servicing, Repairing, and Testing of Actuator for Auxiliary Gas Stop Valve

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503086
DATE : 28.11.2025
REQ No : 1032505794
REQ TITLE : JAPS L1-STATION, Servicing, R
DELIVERY LOCATION
CLOSING DATE : 04.12.2025
CLOSING TIME : 10:00:00

4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP