

RFQ NUMBER : 2332503105

DATE : 03.12.2025

REQ No : 1032505631

REQ TITLE : SHIPPMENT: Refub: of WMS

DELIVERY LOCATION

CLOSING DATE : 09.12.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	#SHIPMENT: REFUBRISHMENT OF DANFOSS 1.5	1	AU				
			"DSVTHE SCOPE OF WORK FOR REFURBISHMENT						
			OF EUROSAFE MAKE WATER MIST						
			SYSTEMMOTORIZED DRY SECT						
			IONAL VALVES [SIZES 1.5 INCH] SHALL INCLUDE,						
			NOTLIMITED TO THE FOLLOWING, INSPECTION,						
			PREPARATIONS AND REPLACEMENT OFPARTS AS						
			APPLIC						
			ABLE AS FOLLOWS:-INSPECTION AND						
			PREPARATION##THE CONTRACTOR MUST HAVE						
			EXPERIENCE IN REPAIR AND RECTIFICATION						
			OFEUROSAFE MAKE HP WATE						
			R MIST SYSTEM.##CLEAN INTERNAL COMPONENTS						
			USING SUITABLE SOLVENTS.##REMOVE SCALE,						
			RUST, OR DEBRIS USING BRUSHES##DRY ALL						
			PARTS THORO						
			UGHLY WITH LINT-FREE CLOTHS OR COMPRESSED						
			AIR.##CHECK BALL SURFACE FOR SCORING,						
			PITTING, OR CORROSION.##EXAMINE SEATS AND						
			SEALS FOR						
			WEAR, DEFORMATION, OR CRACKS.##INSPECT						
			STEM AND TEFLON PAD AND O RINGS OF THE BALL						
			VALVE.##CHECK ACTUATOR FOR SMOOTH						



RFQ NUMBER : 2332503105

DATE : 03.12.2025

REQ No : 1032505631

REQ TITLE : SHIPPMENT: Refub: of WMS

DELIVERY LOCATION

CLOSING DATE : 09.12.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OPERATION, AND						
			SIGNAL RESPONSE.##THE REPLACEMENT OF						
			COMPONENTS IF INVOLVED SHALL BE OF SAME						
			MAKE &MODEL OF THAT OF OEM.##ALL THE						
			TESTING SHALL BE C						
			ARRIED OUT IN THE VENDOR TEST FACILITY						
			ORANY APPROVED TESTING LABORATORY.##A						
			PROPER INSPECTION REPORT WITH						
			PHOTOGRAPHS SHALL BE SUBM						
			ITTED TODEWACASE: -1 ACTUATOR IS WORKING						
			PERFECTLY, AND VALVE NEED TO BE						
			RECTIFIEDRECTIFICATION OF DSV##REPLACE						
			DAMAGED TEFLON PAD O						
			N THE BALL VALVE.##LAP THE BALL AND SEATS IF						
			MINOR DAMAGE EXISTS.##LUBRICATE MOVING						
			PARTS WITH APPROPRIATE VALVE						
			GREASE.##REASSEMBLE						
			VALVE IN CORRECT ORIENTATION AND TORQUE						
			FASTENERS TOSPECIFICATION.##DO THE						
			HYDRAULIC STATIC PRESSURE TEST WITH						
			PRESSURE OF 210 BARS						
			FOR15 MIN.##IF THE PRESSURE TEST IS PASSED						
			MOUNT ACTUATOR, ALIGN TO PREVIOUSPOSITION,						



RFQ NUMBER : 2332503105

DATE : 03.12.2025

REQ No : 1032505631

REQ TITLE : SHIPPMENT: Refub: of WMS

DELIVERY LOCATION

CLOSING DATE : 09.12.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AND TIGHTEN PROPERLY.##CONNECT ELECTRICAL						
			LIN						
			ES AS PER SPECIFICATIONS.##CALIBRATE						
			ACTUATOR STROKE USING MANUAL						
			TUNING.##ENSURE SMOOTH OPERATION OF VALVE						
			AND ACTUATOR ASSEMBLY.##						
			IF THE PRESSURE TEST FAILS DISPOSE THE						
			VALVE##PROPOSE AND ASSEMBLE NEW VALVE TO						
			THE ACTUATOR AND TEST AGAIN.##GENERATE						
			VALVE REFURBI						
			SHMENT/REPLACEMENT REPORT WITH BEFORE						
			AND AFTERPHOTOGRAPHS##WARRANTY FOR THE						
			NEW VALVE SUPPLIED: 1 YEAR CASE: -2 VALVE IS						
			FUNCTIONIN						
			G PERFECTLY, AND ACTUATOR IS NOT						
			WORKING##CHECK ACTUATOR FOR SMOOTH						
			OPERATION, AND SIGNAL RESPONSE.##CLEAN THE						
			MOVING PARTS AND LUBR						
			ICATE##CONNECT ELECTRICAL LINES AS PER						
			SPECIFICATIONS AND TEST##IF THE VALVE IS NOT						
			WORKING, REPLACE THE ACTUATOR [ULLI 10						
			SERIES]AN						
1			D ASSEMBLE TO THE VALVE AND DO THE						



RFQ NUMBER : 2332503105

DATE : 03.12.2025

REQ No : 1032505631

REQ TITLE : SHIPPMENT: Refub: of WMS

DELIVERY LOCATION

CLOSING DATE : 09.12.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TESTING.##CONNECT ELECTRICAL LINES AS PER						
			SPECIFICATIONS.##CALIBRATE ACTUATOR						
			STROKE USING MANUAL						
			TUNING.##ENSURE SMOOTH OPERATION OF						
			VALVE AND ACTUATOR ASSEMBLY.##DO THE						
			HYDRAULIC STATIC PRESSURE TEST WITH						
			PRESSURE OF 210 BARS F						
			OR15 MIN.##GENERATE VALVE						
			REFURBISHMENT/REPLACEMENT REPORT WITH						
			BEFORE AND AFTERPHOTOGRAPHS##WARRANTY						
			FOR THE NEW ACTUATOR SUPPLIED:						
			1 YEARTHE WORK SHALL BE COMPLETED WITHIN						
			4 WEEKS FROM DATE OF ISSUANCE OF PO.FOR						
			ANY RELATED QUERIES AND FURTHER						
			INFORMATION, CONTA						
			CT MR. VISHNUVIJAY [EMAIL :						
			VISHNU.VIJAY@DEWA.GOV.AE , MOB: 0509463644]						
			OR MR. ANEEZHUSSAIN [EMAIL :						
			ANEEZ.ABDULRAZAK@DEWA.GOV.AE ,						
			MOB:0559660850]						

TOTAL AMOUNT IN WORDS: TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:





RFQ NUMBER : 2332503105

DATE : 03.12.2025

REQ No : 1032505631

REQ TITLE : SHIPPMENT: Refub: of WMS

DELIVERY LOCATION

CLOSING DATE : 09.12.2025

CLOSING TIME : 10:00:00

SHIPPMENT: Refub: of WMS DSV in IDT 2

For any related queries and further information, contact Mr. Vishnu

Vijay [Email: vishnu.vijay@dewa.gov.ae, Mob: 0509463644] or Mr. Aneez

Hussain [Email: aneez.abdulrazak@dewa.gov.ae, Mob:0559660850]

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6)Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider





RFQ NUMBER : 2332503105

DATE : 03.12.2025

REQ No : 1032505631

REQ TITLE : SHIPPMENT: Refub: of WMS

DELIVERY LOCATION

CLOSING DATE : 09.12.2025 **CLOSING TIME** : 10:00:00

shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS:

SUPPLIER'S SIGNATURE AND STAMP