

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503117
DATE : 04.12.2025
REQ No : 1032505708
REQ TITLE : Repairing and Replacement of
DELIVERY LOCATION
CLOSING DATE : 10.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	JOB SPECIFICATION # REPAIRING AND REPLACEMENT OF DAMAGED PUMPS AT DEWAVARIOUS LOCATIONS1. GENERALTHIS SCOPE OF WORK DEFINES THE REQUIREMENTS FOR THE INSPECTION,REPAIRING, REPLACEMENT, TESTING, AND COMMISSIONING OF DEFECTIVE ANDGROUNDED PUMPS INSTALLED AT VARIOUS DEWA FACILITIES. THE OBJECTIVE IS TORESTORE THE NORMAL OPERATION OF ALL PUMPING SYSTEMS TO ENSUREUNINTERRUPTED WATER SUPPLY AND SYSTEM RELIABILITY IN COMPLIANCE WITHDEWA MAINTENANCE STANDARDS.2. INTRODUCTIONTHE LISTED PUMPS HAVE BEEN FOUND DEFECTIVE DUE TO ELECTRIC,MECHANICAL, OR CONTROL PANEL FAULTS. THE IDENTIFIED ISSUES INCLUDE MOTORGROUNDING, IMPELLER/SEAL DAMAGE, PRESSURE NOT BUILT, AND CONTROL PANELMALFUNCTION. THE SCOPE COVERS ALL NECESSARY WORKS TO RECTIFY, REPLACE,TEST, AND COMMISSION THE PUMPS AT	1	NO				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503117
DATE : 04.12.2025
REQ No : 1032505708
REQ TITLE : Repairing and Replacement of
DELIVERY LOCATION
CLOSING DATE : 10.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE MENTIONED SITES.3. SCOPE OF WORK3.1 HUDAIBA BUILDING # BOOSTER PUMP (GOULDS)# QUANTITY: 1 NO# FAULT: GROUNDED, NEEDS REPAIR SCOPE:# DISMANTLE THE GROUNDED PUMP AND MOTOR ASSEMBLY.# CARRY OUT MOTOR REWINDING OR REPLACEMENT AS REQUIRED.# REPLACE BEARINGS, SEALS, AND GASKETS A S NECESSARY.# TEST INSULATION RESISTANCE AND VERIFY MOTOR PERFORMANCE AFTER REPAIR.# REINSTALL, ALIGN, AND TEST PUMP OPERATION.3.2 A L QOUZ STORE 2 # BOOSTER PUMP (GRUNDFOS)DEWA-CONFIDENTIAL# QUANTITY: 1 NO# FAULT: PRESSURE NOT BUILT, NEEDS REPAIRING SCOPE:# INSPEC T IMPELLER, SEAL, AND COUPLING.# REPLACE DAMAGED IMPELLER OR MECHANICAL SEAL IF REQUIRED.# CHECK MOTOR WINDING AND INSULATION.# COND UCT PRESSURE AND FLOW TEST TO VERIFY PROPER OPERATION.3.3 AL QOUZ</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503117
DATE : 04.12.2025
REQ No : 1032505708
REQ TITLE : Repairing and Replacement of
DELIVERY LOCATION
CLOSING DATE : 10.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ACCOMMODATION # BOOSTER PUMP (GRUNDFOS)# QUANTITY: 1 NO# FAULT: GROUNDED, NEEDS REPLACEMENT SCOPE:# REMOVE THE DAMAGED PUMP AND MOTOR ASSEMBLY.# SUPPLY AND INSTALL A NEW GRUNDFOS PUMP OF EQUIVALENT MODEL ANDCAPACITY (TYPE-CM10-3A-R-A-E-AVBEF-A-A-N).# RECONNECT PIPING, POWER, AND CONTROL WIRING.# PERFORM ALIGNMENT, INSULATION RESISTANCE, AND OPERATIONAL TESTING.3.4 FILING STATION # BOOSTER PUMP (GRUNDFOS)# QUANTITY: 1 NO# FAULT: PRESSURE NOT BUILT, NEEDS REPAIRING SCOPE:# INSPECT PUMP IMPELLER, VOLUTE, AND SEAL CONDITION.# REPAIR OR REPLACE DEFECTIVE COMPONENTS.# PERFORM PRESSURE AND FUNCTIONAL TESTING AFTER REASSEMBLY.3.5 JABEL ALI CABLE STORE # TRANSFER PUMP (GRUNDFOS)# QUANTITY: 2 NOS# FAULT: GROUNDED, NEEDS REPLACEMENT SCOPE:DEWA-CONFIDENTIAL# DISMANTLE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503117
DATE : 04.12.2025
REQ No : 1032505708
REQ TITLE : Repairing and Replacement of
DELIVERY LOCATION
CLOSING DATE : 10.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AND REMOVE DEFECTIVE PUMPS.# SUPPLY AND INSTALL TWO (2) NEW GRUNDFOS TRANSFER PUMPS OF EQUIVALENT CAPACITY.# RECONNECT PIPING AND POWER CABLES.# PERFORM ALIGNMENT, LEAKAGE TEST, AND COMMISSIONING.3.6 AL QOUZ SUSTAINABLE BUILDING # SUBMERSIBLE PUMPS# QUANTITY: 2 NOS# FAULT: GROUNDED, NEEDS REPLACEMENT SCOPE:# REMOVE DEFECTIVE SUBMERSIBLE PUMPS.# SUPPLY AND INSTALL NEW SUBMERSIBLE PUMPS WITH EQUIVALENT SPECIFICATIONS.# PROVIDE NEW CABLING AND WATERPROOF JOINTS IF REQUIRED.# CONDUCT INSULATION TEST, OPERATION TEST, AND VERIFY DISCHARGE PRESSURE.3.7 JAPS SERVICE BLOCK B # VFD (SIEMENS)# QUANTITY: 1 NO# FAULT: CONTROL PANEL AND VFD FAULT RECTIFICATION SCOPE:# INSPECT AND DIAGNOSE THE EXISTING SIEMENS VFD PANEL.# REPLACE DAMAGED COMPONENTS (VFD MODULE)</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503117
DATE : 04.12.2025
REQ No : 1032505708
REQ TITLE : Repairing and Replacement of
DELIVERY LOCATION
CLOSING DATE : 10.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>E, CONTROL CARDS, FUSES, ETC.).# TEST INPUT/OUTPUT VOLTAGE, PROGRAMMING PARAMETERS, AND CONTROLSIGNALS.# VERIFY AUTOMATIC AND MANUAL PUMP OPERATION MODES.3.8 JAPS PUMP ROOM # TRANSFER PUMP (GRUNDFOS)# QUANTITY: 1 NO# FAULT: BEARING SOUND, NEEDS REPAIRING SCOPE:# D ISMANTLE THE PUMP, REPLACE BEARINGS, SEALS, AND GASKETS.# BALANCE ROTATING PARTS AND REASSEMBLE.# TEST FOR VIBRATION, NOISE, AND SMO OTH OPERATION.DEWA-CONFIDENTIAL3.9 WARSAN TP ADMIN BUILDING # BOOSTER PUMP (KSB)# QUANTITY: 1 NO# FAULT: IMPELLER AND SEAL DAMAGE, M OTOR GROUNDED, NEEDS REPLACEMENTSCOPE:# REMOVE THE DEFECTIVE UNIT.# SUPPLY AND INSTALL NEW KSB PUMP OR EQUIVALENT MODEL.# REALIGN, R ECONNECT PIPING AND ELECTRICAL SUPPLY.# TEST OPERATION, PERFORMANCE, AND PRESSURE DELIVERY.3.10 WARSAN CENTRAL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503117
DATE : 04.12.2025
REQ No : 1032505708
REQ TITLE : Repairing and Replacement of
DELIVERY LOCATION
CLOSING DATE : 10.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>STORE # BOOSTER PUMP (GRUNDFOS)# QUANTITY: 1 NO# FAULT: GROUNDED, NEEDS REPLACEMENT SCOPE:# REPLACE EXISTING PUMP WITH EQUIVALENT GRUNDFOS MODEL.# CONNEC T PIPING, ELECTRICAL WIRING, AND CONTROL SIGNALS.# TEST AND COMMISSION.3.11 RUWAYAH DP COMPLEX # SUBMERSIBLE PUMP# QUANTITY: 1 NO# F AULT: GROUNDED, NEEDS REPLACEMENT SCOPE:# REMOVE THE DEFECTIVE SUBMERSIBLE PUMP.# SUPPLY AND INSTALL NEW SUBMERSIBLE PUMP WITH SUITA BLE HEAD AND FLOWCAPACITY.# VERIFY CONTROL PANEL OPERATION AND CABLE TERMINATIONS.# CONDUCT INSULATION RESISTANCE, OPERATIONAL, AND PRESSURE TESTS.3.12 RUWAYAH GARAGE # BOOSTER PUMPS (GRUNDFOS)# QUANTITY: 2 NOSDEWA-CONFIDENTIAL# FAULT: GROUNDED, NEEDS REPLACEMENT SCOPE:# REMOVE TWO (2) DEFECTIVE PUMPS.# SUPPLY AND INSTALL NEW GRUNDFOS PUMPS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503117
DATE : 04.12.2025
REQ No : 1032505708
REQ TITLE : Repairing and Replacement of
DELIVERY LOCATION
CLOSING DATE : 10.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			(MODEL A-96935503-P9-2133 OREQUIVALENT).# ALIGN PUMPS , CHECK ROTATION, AND VERIFY OPERATION UNDER FULL LOAD.# SUBMIT PERFORMANCE AND TEST REPORTS.4. TECHNICAL SPECIFICATIONS ITEM #SPECI FICATION #PUMP BRAND #GRUNDFOS, KSB, GOULDS, OR APPROVED EQUIVALENT #MOTOR RATING #AS PER EXISTING INSTALLATION (MATCH EXISTING DUTY ANDHEAD) #ENCLOSURE RATING #IP55 OR HIGHER FOR MOTORS, IP65 FOR CONTROL PANELS #CONTROL PANEL #EXISTING PANEL TO BE RETAINED OR REP AIRED UNLESS FAULTY#CABLE #XLPE INSULATED, FLAME-RETARDANT, AS PER LOAD REQUIREMENT #PROTECTION DEVICES #OVERLOAD, PHASE FAILURE, DR Y RUN, AND SHORT-CIRCUITPROTECTION #TESTING #INSULATION RESISTANCE, NO-LOAD CURRENT, VIBRATION, PRESSURE,AND FLOW TEST #SL. NO. #LOC ATION / BUILDING #PUMP TYPE #QTY (NOS.)						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503117
DATE : 04.12.2025
REQ No : 1032505708
REQ TITLE : Repairing and Replacement of
DELIVERY LOCATION
CLOSING DATE : 10.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			#ACTIVITYDESCRIPTION #BRAND / MODEL #WORK CATEGORY #REMARKS #6 #AL QOUZ SUSTAINABLE BUILDING #SUBMERSIBLE PUMP #2 #REPLACEMENT OFDEFECTIVE SUBMERSIBLE PUMPS WITH NEW EQUIVALENT MODELS, CABLING &COMMISSIONING ## #REPLACEMENT #GROUNDED #7 #JAPS SERVICE BLOCK B #VFD CONTROL PANEL #1 #INSPECTION & REPAIR OF SIEMENS VFD, REPLACEMENT OF FAULTY COMPONENTS, PROGR AMMING & TESTING#SIEMENS # SZVH0YFK035722/SCN-A5E03-262700 #REPAIR #CONTROL PANELFAULT #8 #JAPS PUMP ROOM #TRANSFER PUMP #1 #BEARING & SEAL REPLACEMENT,BALANCING & FUNCTIONAL TESTING #GRUNDFOS # A-96806946-P3-1738 #REPAIR#BEARING SOUND #9 #WARSAN TP ADMIN BUILDING #BOOSTER PUMP #1 #REMOVAL OF DAMAGEDPUMP, SUPPLY & INSTALLATION OF NEW KSB EQUIVALENT, REALIGNMENT &COMMISSIONING #KSB # WEA10012 #						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503117
DATE : 04.12.2025
REQ No : 1032505708
REQ TITLE : Repairing and Replacement of
DELIVERY LOCATION
CLOSING DATE : 10.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REPLACEMENT #IMPELLER, SEAL, & MOTORDAMAGED #10 #WARSAN CENTRAL STORE #BOOSTER PUMP #1 #DISMANTLING &INSTALLATION OF NEW EQUIVALENT GRUNDFOS BOOSTER PUMP, TESTING &COMMISSIONING #GRUNDFOS # D-AR508030 #REPLACEMENT #GROUNDED #11 #RUWAYAH DP COMPLEX #SUBMERSIBLE PUM P #1 #REMOVAL OF DAMAGEDSUBMERSIBLE PUMP, INSTALLATION OF NEW EQUIVALENT, CABLE TERMINATION &TESTING ## #REPLACEMENT #GROUNDED #12 # RUWAYAH GARAGE #BOOSTER PUMP #2 #REMOVAL OF DAMAGED PUMPS,INSTALLATION OF NEW GRUNDFOS BOOSTER PUMPS, ALIGNMENT & FULL TESTING #GRUN DFOS # A-96935503-P9-2133 #REPLACEMENT #GROUNDED #NOTES:1. ALL REPLACED PUMPS SHALL BE GRUNDFOS, KSB, OR GOULDS, OR APPROVEDEQUIVALE NT MEETING THE SAME DUTY POINT AND PERFORMANCE.2. CONTRACTOR SHALL VISIT EACH SITE PRIOR TO EXECUTION TO CONFIRM						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503117
DATE : 04.12.2025
REQ No : 1032505708
REQ TITLE : Repairing and Replacement of
DELIVERY LOCATION
CLOSING DATE : 10.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SITE CONDITIONS AND PUMP DETAILS.3. ALL ALIGNMENT, INSULATION RESISTANCE, AND PERFORMANCE TEST REPORTS MUST BE SUBMITTED AFTER COMPLETION.4. RATES SHALL INCLUDE TRANSPORTATION, DISMANTLING, REINSTALLATION, CONSUMABLES, TOOLS, AND TESTING MATERIALS.5. WARRANTY: 1 YEAR FROM COMMISSIONING DATE FOR REPLACED PARTS AND WORKMANSHIP. GENERAL CONDITIONS# THE CONTRACTOR AT DEWA WORK PREMISES SHALL FOLLOW DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATIONS DURING THE CONTRACT PERIOD.# THE CONTRACTOR SHALL CARRY OUT A RISK ASSESSMENT FOR ALL HIS WORKS. THIS RISK ASSESSMENT SHALL BE FROM SAFETY AS WELL AS OCCUPATIONAL HEALTH CONSIDERATIONS. (DEWA FORMAT TO BE USED).# TOOLBOX TALKS SHOULD BE GIVEN TO THE WORKERS BY THEIR SUPERVISOR, A COPY OF WHICH SHALL BE GIVEN</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503117
DATE : 04.12.2025
REQ No : 1032505708
REQ TITLE : Repairing and Replacement of
DELIVERY LOCATION
CLOSING DATE : 10.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TO DEWA.# NO WELDING, FLAME HEATING OR CUTTING, GRINDING , PNEUMATIC CHIPPING,ETC. SHALL BE CARRIED OUT WITHOUT SPECIFIC CLEARANCE FROM DEWA THROUGH"HOT WORK PERMITS". THE HOT WORK PERMIT I F REQUIRED SHALL BE OBTAINED ONA DAILY BASIS.# THE CONTRACTOR SHALL AT NO TIM						
2		ITEM-00001	OVERHAULING OF PUMP, REPLACEMENT OF IMPELLER/SEAL, FUNCTIONAL TESTING ASPER ATTACHED SPECIFICATION AT AL QOUZ STORE 02	1	NO				
3		ITEM-00001	DISMANTLING & REPLACEMENT WITH NEW EQUIVALENT GRUNDFOS PUMP,INSTALLATION, ALIGNMENT & COMMISSIONING AS PER ATTACHED SPECIFICATION AT AL QOUZ ACCOMMODATION	1	NO				
4		ITEM-00001	PUMP DISMANTLING, IMPELLER/ SEAL CHECK, REASSEMBLY & PRESSURE TEST ASPER SPECIFICATION AT FILING STATION	1	NO				
5		ITEM-00001	REMOVAL OF DAMAGED PUMPS, SUPPLY & INSTALLATION OF NEW GRUNDFOS TRANSFERPUMPS, TESTING & COMMISSIONING AS	2	NO				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503117
DATE : 04.12.2025
REQ No : 1032505708
REQ TITLE : Repairing and Replacement of
DELIVERY LOCATION
CLOSING DATE : 10.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PER SPECIFICATION @JEBEL A LI CABLESTORE						
6		ITEM-00001	REPLACEMENT OF DEFECTIVE SUBMERSIBLE PUMPS WITH NEW EQUIVALENT MODELS,CABLING & COMMISSIONING AS PER SPECIFICATION @ SUSTAINABLE BUI LDING	2	NO				
7		ITEM-00001	INSPECTION & REPAIR OF SIEMENS VFD, REPLACEMENT OF FAULTY COMPONENTS,PROGRAMMING & TESTING AT JAPS BACHELOR ACCOMMODATION	1	NO				
8		ITEM-00001	BEARING & SEAL REPLACEMENT, BALANCING & FUNCTIONAL TESTING AS PERSPECIFICATION @JAPS FAMILY	1	NO				
9		ITEM-00001	REMOVAL OF DAMAGED PUMP, SUPPLY & INSTALLATION OF NEW KSB EQUIVALENT,REALIGNMENT & COMMISSIONING AS PER SPECIFICATION @ WARSAN TP AD MINBUILDING	1	NO				
10		ITEM-00001	DISMANTLING & INSTALLATION OF NEW EQUIVALENT GRUNDFOS BOOSTER PUMP,TESTING & COMMISSIONING AS PER SPECIFICATION @	1	NO				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503117
DATE : 04.12.2025
REQ No : 1032505708
REQ TITLE : Repairing and Replacement of
DELIVERY LOCATION
CLOSING DATE : 10.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WARSAN CENTRAL STORE						
11		ITEM-00001	REMOVAL OF DAMAGED SUBMERSIBLE PUMP, INSTALLATION OF NEW EQUIVALENT, CABLE TERMINATION & TESTING AS PER SPECIFICATION @ RUWAYAH DP COMPLEX	1	NO				
12		ITEM-00001	REMOVAL OF DAMAGED PUMPS, INSTALLATION OF NEW GRUNDFOS BOOSTER PUMPS, ALIGNMENT & FULL TESTING AS PER SPECIFICATION AT RUWAYAH GARAGE	2	NO				

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Repairing and Replacement of Damaged Pumps at DEWA Various Locations.

Contact: Mr.M.Arif Mushtaq / 055-2239059

Payment Terms: 100% on completion.

Site Visit Date: 03.12.2025

STANDARD TERMS & CONDITIONS

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503117
DATE : 04.12.2025
REQ No : 1032505708
REQ TITLE : Repairing and Replacement of
DELIVERY LOCATION
CLOSING DATE : 10.12.2025
CLOSING TIME : 10:00:00

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
 - 2) Quotation to be submitted only in local currency U.A.E Dirhams
 - 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
 - 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
 - 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
 - 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.
- If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
- The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503117
DATE : 04.12.2025
REQ No : 1032505708
REQ TITLE : Repairing and Replacement of
DELIVERY LOCATION
CLOSING DATE : 10.12.2025
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP