

RFQ NUMBER : 2332503140

DATE : 05.12.2025

REQ No : 1032505859

REQ TITLE : AMC FIRE ALARM, FIRE

DELIVERY LOCATION

CLOSING DATE : 12.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SPECIFICATION OF ANNUAL MAINTENANCE OF	4	JOB				
			FIRE ALARM, FIRE FIGHTINGSYSTEM, PA SYSTEMS						
			AND EMERGENCY/ EXIT LIGHT @ JABEL ALI CSO						
			2025-2						
			6#DEWA-CONFIDENTIALSPECIFICATION OF						
			ANNUAL MAINTENANCE OF FIRE ALARM, FIRE						
			FIGHTING SYSTEM,PA SYSTEMS AND EMERGENCY/						
			EXIT LIGHT @ JA						
			BEL ALI CSO 2025-26SCOPE OF WORK1. THE						
			PARTIES SHOULD VISIT THE SITE, AND CHECK THE						
			SYSTEMS, ASSESS THEREQUIREMENTS (HIGH						
			LEVEL ACCE						
			SS, CONSUMABLES, ACCESSORIES, DIESEL						
			TOP-UPAND CABLES ETC) AND QUOTE THE LUMP						
			SUM ACCORDINGLY.2. THE CONTRACTOR SHALL						
			HAVE APPROV						
			AL FROM DCD FOR THE MAINTENANCE OFFIRE						
			PROTECTION SYSTEMS.3. ALL EMERGENCY						
			MAINTENANCE CALLS ARE TO BE ATTENDED 24X7						
			ROUND THECLOCK						
			365 DAYS.4. MINIMUM 4 SERVICES (PREVENTIVE						
			MAINTENANCE) TO BE CARRIED OUTQUARTERLY.5.						
			ALL DEVICES HAVE TO BE CLEANED AND TESTED						



RFQ NUMBER : 2332503140

DATE : 05.12.2025

REQ No : 1032505859

REQ TITLE : AMC FIRE ALARM, FIRE

DELIVERY LOCATION

CLOSING DATE : 12.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			EACH						
			QUARTER.6. THE SYSTEMS SHOULD BE						
			MAINTAINED AS PER CIVIL DEFENSE						
			REGULATIONS.7. IN CASE OF UNSATISFACTORY						
			PERFORMANCE, THE LPO WILL						
			BE CANCELLEDGIVING 15 DAYS# NOTICE.8. THE						
			DIESEL ENGINE MAJOR SERVICE SHALL BE						
			CARRIED OUT ONCE IN A YEARINCLUDING SPARES						
			(FILTERS,						
			OIL, COOLANT, ETC.) AND TO PERFORM						
			PUMPPERFORMANCE TESTDEWA-CONFIDENTIAL9.						
			IF ANY LEAK FOUND IN PUMPS GLAND PACKING,						
			WATER SEALS AN						
			D MECHANICALSEALS SHOULD BE REPLACED/						
			REPAIRED FREE OF COAST BY THE						
			CONTRACTOR10. THE DIESEL TO BE FILLED IN						
			DIESEL TANK TO MAINTAIN						
			THE DIESEL LEVELLIMIT THROUGHOUT ONE YEAR						
			MAINTENANCE CONTRACT PERIOD11. THE WORK						
			SHALL INCLUDE SUPPLY, INSTALLATION,						
			PROGRAMMING,						
			ANDTESTING OF THE DEVICES BELOW IN CASE OF						
			FAULT AND NOT WORKING CONDITION.# ALL						



RFQ NUMBER : 2332503140

DATE : 05.12.2025

REQ No : 1032505859

REQ TITLE : AMC FIRE ALARM, FIRE

DELIVERY LOCATION

CLOSING DATE : 12.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BATTERIES FOR FIRE ALARM SYSTEMS AND						
			EMERGENCY/ EXI						
			T LIGHTINGSYSTEMS# ALL BATTERIES FOR FM200/						
			INERGEN SYSTEMS AND FOAM SYSTEMS# ALL FIRE						
			ALARM SYSTEMS, FM200/ INRGEN SYSTEMS AND						
			FOAM						
			SYSTEMS DEVICES# ALL EMERGENCY/ EXIT						
			LIGHTING SYSTEMS DEVICES# (MAJOR PART OF						
			CONTROL PANEL LIKE MOTHER BOARD, POWER						
			SUPPLY, DISPLA						
			YBOARD, LOOP CARD AND REFILLING OF FM200/						
			INERGEN GAS AND FOAM NOTINCLUDED)12. THE						
			WORK SHALL INCLUDE REFILLING/ REPAIRING OF						
			FIRE E						
			XTINGUISHER ANDHYDRO TESTING.13.						
			CONTRACTOR TO SUPPORT ANY RENOVATION OR						
			REPLACEMENT OF DAMAGEDCEILING TILES FOR						
			THE EXISTING SYSTEM						
			S WITHOUT ANY ADDITIONAL						
			COST.DEWA-CONFIDENTIAL14. CONTRACTORS TO						
			PARTICIPATE WITH THE INTERNAL DEPARTMENT						
			OR EXTERNALEMERGENCY AUTH						
1			ORITIES MOCK DRILL ALONG WITH DUBAI CIVIL						



RFQ NUMBER : 2332503140

DATE : 05.12.2025

REQ No : 1032505859

REQ TITLE : AMC FIRE ALARM, FIRE

DELIVERY LOCATION

CLOSING DATE : 12.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DEFENSE. HEALTHAND SAFETY DEPARTMENT						
			OBSERVATIONS NEED TO BE RECTIFIED WITHIN						
			THECONTRACT.						
			15. CONTRACTOR TO SUBMIT SNAG LIST ONCE						
			CONTRACT IS AWARDED.16. A MINIMUM OF ONE						
			SUPERVISOR/ ENGINEER AND TECHNICIAN WITH						
			DCDAPPROVE						
			D CARDHOLDER SHOULD BE AVAILABLE FOR ALL						
			PPM ACTIVITIES ANDCORRECTIVE						
			MAINTENANCE.17. SERVICE TO BE CARRIED OUT IN						
			THE PRESENCE OF D						
			EWA STAFF ONLY.18. THE CONTRACT PERIOD WILL						
			START FROM THE DATE OF THE FIRST						
			SERVICE/VISIT.19. ONE-YEAR REPLACEMENT						
			WARRANTY IS APPL						
			ICABLE FOR ALL PARTS REPLACEDBY THE						
			CONTRACTOR.20. THE QUOTATION SHALL BE						
			SUBMITTED AS PER DEWA SPECIFICATION ONLY.						
			NOCHANGES WERE A						
			CCEPTED. PO WILL BE ISSUED AS PER DEWA						
			SPECIFICATION ONLY.21. CONTRACTOR TO OBTAIN						
			MAINTENANCE CONTRACT AGREEMENT AND						
			SAFETYCERTIFIC						



RFQ NUMBER : 2332503140

DATE : 05.12.2025

REQ No : 1032505859

REQ TITLE : AMC FIRE ALARM, FIRE

DELIVERY LOCATION

CLOSING DATE : 12.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ATE FROM DUBAI CIVIL DEFENSE WITHOUT ANY						
			ADDITIONAL PAYMENT.22. SYSTEMS COVERED						
			UNDER CONTRACTA. FIRE ALARM SYSTEMB. HOSE						
			REEL SYSTE						
			MSC. FIRE PUMPS (JOCKEY, ELECTRICAL MAIN AND						
			DIESEL)DEWA-CONFIDENTIALD. PORTABLE FIRE						
			EXTINGUISHERSE. EMERGENCY/EXIT LIGHTING						
			SYSTEM						
			SF. LANDING VALVE/ HYDRANT VALVEG.						
			SPRINKLER SYSTEMH. BREECHING INLETI. WET						
			RISER/ DRY RISERJ. FM200/ INERGEN SYSTEMSK.						
			VOICE EVACUA						
			TION/ PA SYSTEMPAYMENT TERMS1. PAYMENT						
			WILL BE MADE AFTER CARRYING OUT PREVENTIVE						
			MAINTENANCESERVICE AND COMPLETION OF 3						
			MONTHS.2. Q						
			UARTERLY IN ARREARS.PENALTY CLAUSE*IN CASE						
			CONTRACTOR, DUE TO HIS FAULT TO COMPLETE THE JOB IN TIME AS PERGIVEN AND AGREED						
			SCHEDULE,						
			THEN CONTRACTOR IS LIABLE TO PAY 1.25% OF						
			THE OUNTRACTOR IS LIABLE TO PAY 1.25% OF THE JOB VALUE AS PENALTY FOR EVERY WEEK OF						
			DELAY WITH MAXIMUM CEILING OF						



RFQ NUMBER : 2332503140

DATE : 05.12.2025

REQ No : 1032505859

REQ TITLE : AMC FIRE ALARM, FIRE

DELIVERY LOCATION

CLOSING DATE : 12.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			10%DEWA-CONFIDENT						
			IAL*IN CASE THE CONTRACTOR FAILS TO KEEP						
			THE ACTIVITY SCHEDULE IN PROGRESS,THEN						
			DEWA WILL TAKE OVER THE WORK AND EXECUTE						
			IT THE WAY						
			THAT MAY FEELRIGHT TO MEET THE SCHEDULE.						
			THE EXPENDITURE INCURRED WILL BE CHARGED						
			TOTHE CONTRACTORHSE REQUIREMENTTHE						
			SERVICE PROVIDE						
			R/ CONTRACTOR MUST BE AN ISO CERTIFIED						
			COMPANY. THEYMUST COMPLY WITH DEWA						
			INTEGRATED MANAGEMENT SYSTEM (QUALITY,						
			HSE ANDENVIRONMENTA						
			L REQUIREMENTS). NECESSARY TBT & RISK						
			ASSESSMENTS AS WELL ASPPE SHALL BE						
			ARRANGED BY THE SERVICE PROVIDER/						
			CONTRACTOR TO ENSUREEMPLO						
			YEE AND EQUIPMENT SAFETYGENERAL1. ALL THE						
			MATERIALS IN GENERAL WILL CONFIRM AS PER						
			LATEST STANDARDS ANDSHALL BE SUBMITTED TO						
			DEWA FO						
			R ENGINEER#S APPROVAL.2. THE CONTRACTOR IS						
			REQUIRED TO TAKE ALL PRECAUTIONS, SO AS NOT						



RFQ NUMBER : 2332503140

DATE : 05.12.2025

REQ No : 1032505859

REQ TITLE : AMC FIRE ALARM, FIRE

DELIVERY LOCATION

CLOSING DATE : 12.12.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TODAMAGE ANY OF THE EXISTING						
			EQUIPMENT/STRUCT						
			URE, ETC.3. CONTRACTOR STAFF ARE REQUIRED						
			TO ALWAYS WEAR PROPER						
			PERSONALPROTECTIVE EQUIPMENT ON THE						
			SITE.4. THE CONTRACTOR SHALL VIS						
			IT THE SITE, ASSESS THE WORK REQUIRED,						
			ANDQUOTE A LUMP SUM ACCORDINGLY.CONTACT						
			TO MR. THOMASKUTTY 050-3014789 AND MR.						
			AHMED 055-5888						
			827 FORSITE VISIT						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

AMC FIRE ALARM, FIRE FIGHTING SYSTEMS, PA SYSTEMS AND EMERGENCY/ EXIT LIGHT @ JABEL ALI CSO 2025-26

FOR MORE INFORMATION CONTACT THOMASKUTTY - PHONE: 503528909

Site Visit Date <(>&<)> Time: 09-12-25





RFQ NUMBER : 2332503140

DATE : 05.12.2025

REQ No : 1032505859

REQ TITLE : AMC FIRE ALARM, FIRE

DELIVERY LOCATION

CLOSING DATE : 12.12.2025

CLOSING TIME : 10:00:00

Payment Terms: Payment will be made after carrying out preventive maintenance service and completion of 3 months.

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6)Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.



RFQ NUMBER : 2332503140

DATE : 05.12.2025

REQ No : 1032505859

REQ TITLE : AMC FIRE ALARM, FIRE

DELIVERY LOCATION

CLOSING DATE : 12.12.2025

CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS:

SUPPLIER'S SIGNATURE AND STAMP