

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503200
DATE : 11.12.2025
REQ No : 1032506095
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 17.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	REMOVAL/RETRIEVAL OF FAULTY/DETECTIVE SUBMERSIBLE PUMP-MOTOR SETS WITH GI RAISER PIPES, DIPPING TUBE AND ITS FITTINGS FROM THE WELLS AND INSTALLATION OF THE SAME ON THE SAME WELL FOR HATTA WELLFIELD. PLEASE CONTACT MR. REHMAN (04-3229435/050-5340018) FOR FURTHER CLARIFICATIONS. 1.0#SCOPE OF WORK THE SCOPES OF WORKS FOR THE PREVENTIVE & CORRECTIVE MAINTENANCE OF THE WELLS ARE FOLLOWS. #SUBMERSIBLE PUMP -MOTOR SPECIFICATIONS #MAKE: ###WELL PUMP, MAKE- BELGIUM #MODEL: ##WSP/64 #CAPACITY: ##7.5 # 8 M3/HR, MOTOR-10HP #HEAD: ###288 # 147 M #RPM: ###3500 #DETAILS OF WELLS #THE TOTAL NO OF WELLS - 50 #NO#S #THE AVERAGE DEPTH OF WELLS- 900FT. #GI PIPE DIAMETER 2# (EACH 20FT LENGTH). SCOPE OF WORKS (MECHANICAL) A.#REMOVAL/RETRIEVAL OF FAULTY/DETECTIVE SUBMERSIBLE PUMP-MOTOR SETS WITH GI RAISER PIPES, DIPPING	20	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503200
DATE : 11.12.2025
REQ No : 1032506095
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 17.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TUBE AND ITS FITTINGS FROM THE WELLS ANDSHIFTING THE PUMP-MOTOR SETS ALONG WITH PIPES TO WORKSHOP FOR REPAIRING/ MAINTENANCE PURPOSE</p> <p>IF REQUIRED, AS DIRECTED BY THE DEWA ENGINEERS.B.#INSTALLATION OF SUBMERSIBLE PUMP-MOTOR SET IN THE BORE WELL ALONGWITH REPLACEMENT</p> <p>OF GI RAISER PIPES, DIPPING TUBES AND PIPE FITTINGS.C.#REPLACEMENT OF PUMP OUTLET CONNECTION ALONG WITH ENTIRE FITTINGSLIKE- GATE V</p> <p>ALVES, UNION. SOCKET, FLOW METER, NRV, AIR RELEASE VALVESETC. IF REQUIRES DEWA WILL PROVIDE ALL KINDS OF REPLACEMENTS FITTINGS TOCON</p> <p>TRACTOR.D.#EXISTING DIPPING TUBE & LEVEL RELAY SHALL BE REPLACED (WILL BEPROVIDED BY DEWA) IF FOUND DAMAGE OTHERWISE SAME WILL BE I</p> <p>NSTALLED INTHE RESPECTIVE WELL.E.#THE WELL NOT HAVING DIPPING TUBE SHALL BE INSTALLED AND WFO (WELLFIELD OPERATION, DEWA) WILL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503200
DATE : 11.12.2025
REQ No : 1032506095
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 17.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TEST THE DYNAMIC & STATIC LEVEL. ONCE WFO SATISFIED, THE PUMP WILL BE RETRIEVED AGAIN, ADD THE LEVEL RELAY AND REINSTALL THE PUMP.F.#INSTALLATION OF METAL / PVC PIPES FOR WELL CONNECTION AND CONSUMER CONNECTION, IF REQUIRES (ALL THE CONNECTION FITTINGS WILL BE PROVIDED BY DEWA).G.#MODIFICATION OF THE EXISTING SYSTEM AS PER SITE REQUIREMENT IF REQUIRES.H.#WELL FLUSHING AND INSTALLATION OF CASING INSIDE THE EXISTING WELLS,IF REQUIRES.I.#PERFORMANCE TESTING OF THE WELL.SCOPE OF WORKS (ELECTRICAL)DETAILS OF ELECTRICAL SCOPE OF WORKS ON S SUBMERSIBLE PUMP RETRIEVAL &RE-INSTALLATIONØ#UPON RECEIVING THE MOTOR AND CABLES THE CONTRACTOR ELECTRICIAN HAS TO CHECK FOR ANY PHYSICAL DAMAGE, IF ANY REPORT THE SAME IMMEDIATELY TO DEWA						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503200
DATE : 11.12.2025
REQ No : 1032506095
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 17.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REPRESENTATIVES.Ø#INSULATION RESISTANCE TEST SHALL BE CARRIED OUT ON MOTORS AND CABLES BEFORE AND AFTER INSTALLING THE PUMP USING AN INSULATION MEASURING UNIT (500 VDC) AND ENSURE THAT THE BELOW MINIMUM INSULATION RESISTANCE (500VDC;1 MIN;20 DEGREE C) WITH EXTENSION CABLE -#FOR A NEW MOTOR > 4 MEGA OHM -#FOR A USED MOTOR > 1 MEGA OHMAFTER INSTALLATION OF THE PUMP AND BEFORE CONNECTING THE MOTOR LEADS TO THE STARTERS THE FOLLOWING POINTS HAS TO BE CHECKED AND VERIFIED.Ø#STARTER HAS TO BE CHECKED FOR PROPER VOLTAGE LEVEL (380 # 400 VAC & THE VOLTAGE TOLERANCE -10% TO +6% FOR 50 HZ) AT INCOMER MCCB AND MOTOR LEAD CONNECTION TERMINALS.Ø#PROPER OPERATION OF THE LEVEL RELAY, ELCB, AND OLR HAS TO BE SIMULATED AND CHECKED.Ø#OVERLOAD RELAY SETTING HAS TO BE ADJUSTED ACCORDING THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503200
DATE : 11.12.2025
REQ No : 1032506095
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 17.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MOTORCURRENT.Ø#MOTOR LEADS TO BE CONNECTED TO THE DOL STARTER AND TEST RUN TO BECONDUCTED.Ø#VERIFY DIRECTION OF MOTOR ROTATION AND CORRECT THE SAME IF REQUIRED.Ø#PUMP INSTALLATION / RETRIEVAL REPO</p> <p>RT HAS TO BE FILLED PROPERLY ANDHAS TO BE RETURNED TO THE DEWA REPRESENTATIVES.Ø#IF ANY DIFFICULTY ARISES DURING THE INSTALLATION / RETRIEVAL, THESAME MUST BE REPORT TO DEWA REPRESENTATIVE IMMEDIATELY.Ø#IN PUMP RETRIEVAL CASE THE PUMP- MOTOR SET, PUMP DROP CABLE A</p> <p>ND LEVELWIRES HAS TO BE COILED IN PROPER WAY AND HANDED OVER TO DEWAREPRESENTATIVES FOR INSPECTION, TESTING AND REPAIR.Ø#ALL ELECTRI CAL WORKS CARRIED OUT MUST BE COMPLIED WITH DEWA STANDARD& TERMS AND CONDITIONS.2.0#PRIOR TO SUBMISSION OF QUOTATION, THE FOLLOWING SHALL BE DETERMINEDCAREFULLY:A.#THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503200
DATE : 11.12.2025
REQ No : 1032506095
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 17.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPES, COMPLEXITIES, ETC., BEFORE SUBMITTING THE QUOTATION. B.# DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES / PRICES DURING AND AFTER THE EXECUTION OF WORK ORDERED. C.# THE CONTRACTOR SHOULD SUBMIT THE TIME SCHEDULE / BAR CHART INDICATING EACH ACTIVITY. D.# ON COMPLETION OF THE WORK, THE INSPECTION CHECKLIST OF QUALITY PROCEDURES, WHEREVER APPLICABLE SHOULD BE FILLED IN AND SUBMITTED. 4.0# TAKE OVER ON COMPLETION OF ALL WORK WITHIN THE SCOPE OF THE CONTRACT, FOR ACCEPTANCE OF THE MAINTENANCE WORK, CONTRACTOR SHALL NOTIFY DEWA IN WRITING. A CERTIFICATE OF COMPLETION WILL BE ISSUED BY DEWA ON FINAL INSPECTION ONLY WHEN THE CONTRACT WORK IS DEEMED TO HAVE BEEN TAKEN OVER.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503200
DATE : 11.12.2025
REQ No : 1032506095
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 17.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>VERBY DEWA AFTER NECESSARY CONDITION MONITORING CHECKS WHEREVER & WHENEVER REQUIRED. WARRANTY A.#ALL THE WORK CARRIED OUT SHALL CARRY A WARRANTY FOR 8000 HOURS OF OPERATION OR 1 YEAR WHICHEVER IS EARLIER. B.#THE GUARANTEE WILL TAKE EFFECT FROM THE DATE OF TAKEOVER BY D</p> <p>EWA OF THE JOB CARRIED OUT BY THE CONTRACTOR. C.#WHEN A DEFECT IS NOTICED DURING THE PERIOD OF WARRANTY, THE CONTRACTOR MUST RECTIFY THE DEFECT WITHIN A REASONABLE AMOUNT OF TIME FIXED BY DEWA WITH NO CLAIM OR COMPENSATION. 6.0#DOCUMENTS:#ON SATISFACTORY COMPLETION OF THE WORK & HANDING OVER, THE CONTRACTOR SHOULD SUBMIT THE FOLLOWING TO DEWA. ##A.#INSPECTION REPORT. B.#REPAIR ACTION REPORT. C.#METHOD STATEMENT OF THE REPAIRING WORKS. D.#PHOTOS OF WELLS AFTER RETRIEVAL & BEFORE INSTALLATION. E.#ALL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503200
DATE : 11.12.2025
REQ No : 1032506095
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 17.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TEST REPO RTS.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Removal/Retrieval of faulty/detective submersible pump-motor sets with
 GI raiser pipes, dipping tube and its fittings from the wells and
 installation of the same on the same well for HATTA WELLFIELD.

Please contact Mr. Rehman (04-3229435/050-5340018) for further
 clarifications.

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503200
DATE : 11.12.2025
REQ No : 1032506095
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 17.12.2025
CLOSING TIME : 10:00:00

6)Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by theSupplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP