

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503232  
**DATE** : 12.12.2025  
**REQ No** : 1032505799  
**REQ TITLE** : Supply & instalation 1032505799  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SUPPLY INSTALLATION TESTING COMMISSIONINGOF INSULATED GRP TANK WITH DIMENSIONS WX L X H =2.5 X 2.5 X1.5DEWA-CONFIDENTIALSUPPLY, INST ALLATION, TESTING, AND COMMISSIONING OF WATER TANK DEWA HEADOFFICE MASJIDGENERAL:THIS SCOPE OF WORK OUTLINES THE REQUIREMENTS FOR PROVIDING ALLENGINEERING, MATERIALS, AND LABOR NECESSARY TO DESIGN, CONSTRUCT,SUPPLY, INSTALL, AND COMMISSION A DOMESTIC DRINKING WATE R STORAGE TANKWITH FOUNDATION, AND A PUMP SYSTEM WITH NECESSARY PLUMBING FITTINGS. THECONTRACTOR SHALL VISIT THE SITE TO THOROUGHLY ASSESS LOCAL CONDITIONS,NATURE, AND REQUIREMENTS OF THE WORK, INCLUDING PRESENT CONDITIONS ANDNEW INSTALLATIONS, TO ACCURATELY DETERMINE LABOUR AND MATERIAL NEEDSBEORE SUBMITTING PRICING.ALL MATERIALS SHALL CONFORM TO THE LATEST STANDARDS AND	1	NO				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503232  
**DATE** : 12.12.2025  
**REQ No** : 1032505799  
**REQ TITLE** : Supply & instalation 1032505799  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHALL BE SUBMITTED TO DEWA FOR ENGINEER APPROVAL. THE PROPOSAL SHALL ALIGN WITH DEWA'S ENERGY MANAGEMENT POLICY AND ENMS MANUAL. SCOPE OF WORK: DESIGN AND ENGINEERING: DESIGN A WATER STORAGE TANK WITH A CAPACITY OF 1000 GALLONS, TAILORED TO SPECIFIC SITE REQUIREMENTS. THE TANK SHALL BE CONSTRUCTED FROM GLASS REINFORCED PLASTIC MODULAR PANEL OR AN EQUIVALENT MATERIAL, ENSURING DURABILITY AND COMPLIANCE WITH DEWA REGULATIONS. DEVELOP DETAILED DESIGN DRAWINGS FOR THE TANK, FOUNDATION, AND ASSOCIATED SYSTEMS, TO BE SUBMITTED FOR DEWA ENGINEER APPROVAL. PROPOSAL SUBMITTALS (PRIOR TO IMPLEMENTATION):</p> <p>1. SUBMIT FINAL WATER STORAGE TANK DESIGN DRAWINGS</p> <p>2. PUMP DETAILS INCLUDING CONTROL PANEL</p> <p>3. SINGLE-LINE PIPING LAYOUTS WITH PIPE SIZES</p> <p>4. SINGLE-LINE ELECTRICAL SCHEMATIC WITH WIRE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503232  
**DATE** : 12.12.2025  
**REQ No** : 1032505799  
**REQ TITLE** : Supply & instalation 1032505799  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SIZES AND EXPECTED LOADS,5. FINAL GENERAL LAYOUT6. FINAL WORK PLAN7. PRODUCT TECHNICAL SPECIFICATIONS OR EQUIPMENT BROCHURES.8. PRODUCT SPECIFICATIONS.9. SYSTEM OPERATION DIA GRAM.10. INSTALLATION OPERATIONAL MANUAL.11. THE SUBMITTAL PACKAGE SHALL BE COMPLETE IN ALL ASPECTS AND SHALL INCLUDE EQUIPMENT DETAILS AND A COMPLETE MATERIALS LIST.DEWA-CONFIDENTIALSITE PREPARATION AND FOUNDATION CONSTRUCTION: CONSTRUCT A REINFORCED CONCRETE FOUNDATION CAPABLE OF SUPPORTING THE OPERATING WEIGHT OF THE WATER STORAGE TANK. THE FOUNDATION DESIGN SHALL ADHERE TO RELEVANT STRUCTURAL STANDARDS AND BE APPROVED BY DEWA ENGINEERS.ARRANGE ALL NOC IF NECESSARY TO PERFORM ALL NECESSARY CIVIL EXCAVATION WORK, ENSURING MINIMAL DISRUPTION TO THE EXISTING SITE AND ADHERENCE TO SAFETY PROTOCOLS.TANK						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503232  
**DATE** : 12.12.2025  
**REQ No** : 1032505799  
**REQ TITLE** : Supply & instalation 1032505799  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INSTALLATION: INSTALL THE GRP PANEL DRINKING WATER STORAGE TANK ON THE PREPARED FOUNDATION, ENSURING PROPER ALIGNMENT AND STABILITY. DISINFECT THE WATER STORAGE TANK BEFORE COMMISSIONING, FOLLOWING INDUSTRY BEST PRACTICES AND DEWA GUIDELINES TO ENSURE WATER QUALITY AND SAFETY. PLUMBING AND FITTINGS: PROVIDE AND INSTALL FLOAT SWITCHES AND FLOW VALVES TO CONTROL WATER LEVELS, ENSURING EFFICIENT OPERATION OF THE TANK SYSTEM. INSTALL UNIONS OR FLANGE CONNECTIONS BETWEEN LINES AND THE TANK TO FACILITATE EASY REMOVAL AND MAINTENANCE. CONNECT MECHANICAL AND ELECTRICAL SERVICES TO THE WATER STORAGE TANK, INCLUDING UTILITY WATER SUPPLY CONNECTIONS. SUPPLY AND INSTALL NEW WATER PIPING CONSTRUCTED FROM POLYPROPYLENE RANDOM COPOLYMER, ENSURING DURABILITY AND COMPLIANCE WITH</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503232  
**DATE** : 12.12.2025  
**REQ No** : 1032505799  
**REQ TITLE** : Supply & installation 1032505799  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DEWASTANDARDS.ENSURE ALL HANGERS AND PIPE SUPPORTS ARE GALVANIZED OR EPOXY-COATED TOPREVENT CORROSION AND EXTEND SERVICE LIFE.PUMP SYSTEM INSTALLATION:DESIGN AND INSTALL A DOMESTIC WATER PUMP SYSTEM FEATURING A CONSTANTPRESSURE BOOSTER WITH A CONTROL PANEL. THE SYSTEM SHALL INCLUDE ALLPACKAGED PUMP COMPONENTS, FIELD PIPING, AND WIRING CONNECTIONS.PREPARE A CONCRETE PAD TO SECURELY ANCHOR THE PUMP SYSTEM, ENSURINGSTABILITY AND COMPLIANCE WITH STRUCTURAL STANDARDS.INSTALL A SHADE STRUCTURE TO SHIELD THE PUMP SYSTEM FROM DIRECTSUNLIGHT.PROVIDE ISOLATION VALVES AND FLEXIBLE JOINT CONNECTIONS AT COMMONSUCTION AND DISCHARGE PIPING TO FACILITATE MAINTENANCE, ACCOMMODATEMINOR MISALIGNMENTS, AND DAMPEN EXCESSIVE VIBRATIONS.DEWA-CONFIDENTIALSUPPLY A</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503232  
**DATE** : 12.12.2025  
**REQ No** : 1032505799  
**REQ TITLE** : Supply & instalation 1032505799  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONTROL PANEL WITH AN IP66 RATING, EQUIPPED WITH COMPONENTS(MCBS, RELAYS, CONTACTORS) FROM REPUTABLE MANUFACTURERS SUCH AS ABB,SCHNEIDER, GE, OR SIEMENS. THE PANEL SHALL INCLUDE AUTO/MANUAL SELECTORSWITCHES AND BE PROTECTED WITH A SUNSHADE.ENSURE THE SYSTEM OPERATES SATISFACTORILY IN ENVIRONMENTS WITHTEMPERATURES UP TO 50 DEGREES CELSIUS AND 80% HUMIDITY.USE MATERIALS IN CONTACT WITH WATER THAT ARE NON-TOXIC,NON-CONTAMINATING, BIOLOGICALLY INERT, AND RESISTANT TO INTERNAL ANDEXTERNAL CORROSION OR PROTECTED BY SUITABLE SURFACE TREATMENTS.PUMP DESIGN AND CONSTRUCTION: PROVIDE A DUTY AND STANDBY BOOSTER PUMPSET FOR MAXIMUM RELIABILITY AND EFFICIENCY. THE PUMPS SHALL BE 1.5 KWGRUNDFOS VERTICAL IN-LINE MULTI-STAGE CENTRIFUGAL PUMPS, DESIGNED WITHMOTORS MOUNTED DIRECTLY ON						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503232  
**DATE** : 12.12.2025  
**REQ No** : 1032505799  
**REQ TITLE** : Supply & instalation 1032505799  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TOP FOR EASY            INSTALLATION WITH THE CONTROL PANEL. ENSURE            THE MOTOR AND PUMP ARE FROM THE SAME            MANUFACTURER TO GUARANTEE OPTIMAL            PERFORMANCE. THE PUMP            S SHALL HAVE AN ENCLOSURE CLASS OF IP55,            CLASS F INSULATION, AND A MAXIMUM SPEED OF            2900 RPM. DESIGN THE BOOSTER SYSTEM TO            ALLOW REMOV            AL OF THE IMPELLER SHAFT AND BEARING            WITHOUT DISTURBING SUCTION AND DISCHARGE            CONNECTIONS. ALL WETTED PARTS SHALL BE            STAINLESS STEEL. E            LECTRICAL WORKS: ARRANGE POWER            CONNECTIONS FROM THE NEAREST SUB            MAIN DISTRIBUTION BOARD INCLUDING CABLE            LAYING AND ALL ASSOCIATED CIV            IL WORK. PROVIDE AND INSTALL THE REQUIRED            PANEL BOARD BREAKERS TO MATCH THE EXISTING            PANEL MANUFACTURER AND MODEL TYPE,            ENSURING SEAML            ESS INTEGRATION. DEWA WATER SUPPLY            CONNECTION: MANAGE ALL ASSOCIATED WORK</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503232  
**DATE** : 12.12.2025  
**REQ No** : 1032505799  
**REQ TITLE** : Supply & instalation 1032505799  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AND COORDINATION WITH DEWA FOR WATER SUPPLYCONNECTION APPROVALS. THIS INCLUDES HANDLING APPLICATIONS, ONLINE FORMS,AND ENSURING THE CONTRACTOR IS REGISTERED AND APPROVED BY DEWA.SYSTEM OPERATIO</p> <p>NS: CONFIGURE THE SYSTEM TO ACTIVATE THE DUTY PUMP WHENSYSTEM PRESSURE DROPS TO A PREDETERMINED VALUE. THE PUMP SHALL REGULATE SPEED ACCORDING TO DEMAND AND DEACTIVATE WHEN NO FLOW IS DETECTED.ACTIVATE THE STANDBY PUMP UPON DETECTION OF HIGH FLOW/DEMAND BY THECONTR</p> <p>OLLER. BOTH PUMPS SHALL DEACTIVATE WHEN NO FLOW IS DETECTED OR WHENFLOW FALLS WITHIN THE DUTY PUMP CURVE.PROVIDE START AND STOP INDICATIONS FOR EACH PUMP ON THE DISPLAY.DEWA-CONFIDENTIALENSURE THE STANDBY PUMP ACTIVATES AUTOMATICALLY IF THE DUTY PUMP FAILS,WITH FAULT INDICATIONS TRIGGERED UPON OVERLOAD</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503232  
**DATE** : 12.12.2025  
**REQ No** : 1032505799  
**REQ TITLE** : Supply & instalation 1032505799  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TRIPS.ALLOW MANUAL OPERATION, ENABLING ANY PUMP TO BE STARTED AND STOPPED BYTHE CONTROLLER, WITH USER-DEFINED PRESSURE SETTINGS DURING MANUAL MODE.TESTING AND COMMISSIONING: CONDUCT COMPREHENSIVE TESTING OF THE ENTIRESYSTEM, INCLUDING PRESSURE TESTS, FLOW TESTS, AND FUNCTIONAL TESTS OFALL COMPONENTS.ENSURE THE SYSTEM OPERATES AS DESIGNED AND MEETS ALL SP ECIFIEDPERFORMANCE CRITERIA BEFORE HANDOVER.DOCUMENTATION AND HANDOVER: PROVIDE AS-BUILT DRAWINGS, EQUIPMENTSPECIFICATIONS, OPERATIO N AND MAINTENANCE MANUALS, AND WARRANTYDOCUMENTS. TESTING AND COMMISSIONING REPORTS: COMPREHENSIVE REPORTS OFALL CONDUCTED TESTS, IN CLUDING PRESSURE TESTS, FLOW TESTS, ANDFUNCTIONAL TESTSTIMELINE: ALL TASKS, FROM PROCUREMENT TO FINAL SIGN-OFF, MUST BECOMPLETED WIT</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503232  
**DATE** : 12.12.2025  
**REQ No** : 1032505799  
**REQ TITLE** : Supply & instalation 1032505799  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>HIN 40 DAYS FROM THE START DATE OF THE DEWA PURCHASE ORDER.WARRANTY:# THE INSTALLING CONTRACTOR SHALL PROVIDE A ONE-YEAR INSTALLATIO</p> <p>NWARRANTY THAT INCLUDES ALL MATERIALS, LABOR, AND MISCELLANEOUS COSTS.#</p> <p>STANDARD MANUFACTURER WARRANTY FOR GRP WATER TANKS SHALL BE INCLUDED,COVERING DEFECTS IN MATERIALS AND WORKMANSHIP UNDER NORMAL USE ANDSERVICE CONDITIONS# ANY ISSUES ARISING DURING THE WARRANT</p> <p>Y PERIOD MUST BE RESOLVED WITHIN72 HOURS OF NOTIFICATION.GENERAL CONDITIONS:# THE CONTRACTOR AT DEWA WORK PREMISES SHALL FOLLOW DEWA</p> <p>SAFETY &amp;ENVIRONMENT POLICY, RULES AND REGULATIONS DURING THE CONTRACT PERIOD.#</p> <p>THE CONTRACTOR SHALL CARRY OUT A RISK ASSESSMENT FOR</p> <p>ALL HIS WORKS.THIS RISK ASSESSMENT SHALL BE FROM SAFETY AS WELL AS OCCUPATIONAL HEALTHCONSIDERATIONS. (DEWA FORMAT TO BE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503232  
**DATE** : 12.12.2025  
**REQ No** : 1032505799  
**REQ TITLE** : Supply & instalation 1032505799  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			USED).# TO OLBOX TALKS SHOULD BE GIVEN TO THE WORKERS BY THEIR SUPERVISOR, A COPY OF WHICH SHALL BE GIVEN TO DEWA.# NO WELDING, FLAME HEATING OR CUTTING, GRINDING, PNEUMATIC CHIPPING,ETC. SHALL BE CONDUCTED WITHOUT SPECIFIC CLEARANCE FROM DEWA THROUGH"HOT WORK PERMITS". THE H OT WORK						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### SPECIAL NOTES / INSTRUCTIONS:

Supply <(>&<)> instalation  
for the Insulated GRP tank @Dewa  
head office Masjid

for more information contact Muhammad Tahir Iqbal - Phone : 0566357045

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503232  
**DATE** : 12.12.2025  
**REQ No** : 1032505799  
**REQ TITLE** : Supply & instalation 1032505799  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

Site Visit Date <(>&<)> Time: 15/12/2025

Payment Terms : 100% ON STATIFACTORY COMPLDTION

### **STANDARD TERMS & CONDITIONS**

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
  - 2) Quotation to be submitted only in local currency U.A.E Dirhams
  - 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
  - 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
  - 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
  - 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.
- If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
- The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503232  
**DATE** : 12.12.2025  
**REQ No** : 1032505799  
**REQ TITLE** : Supply & instalation 1032505799  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**