

RFQ NUMBER : 2332503244

DATE : 15.12.2025

REQ No : 1032506232

REQ TITLE : INSULATION REMOVAL AND

DELIVERY LOCATION: 0017 - L1 STORES, JAPS

CLOSING DATE : 19.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	INSULATION REMOVAL AND REFIXING IN STEAM &	400	M2				
			WATER SYSTEM. L-1 STATION,MMD-MBR. WO						
			511275876PERIOD OF WORK04 DAYS DURING EACH						
			SHUTDOWN						
			OF L1 STATION FROM DEC 2025 TO MAY						
			2026.QUANTITY400M2 (INSULATION THICKNESS						
			FROM 150MM TO 350MM)SCOPE OF WORK-#THE						
			CONTRACTOR SHALL						
			VISIT THE SITE AND MAKE HIMSELF FULLY						
			FAMILIARWITH THE WORK SCOPE, PLANT ACCESS,						
			FACILITIES, COMPLEXITIES, SAFETYMEASURES						
			ETC., BEF						
			ORE HE SUBMITS HIS BID. #CONTRACTOR SHALL						
			CONSIDER MINIMUM THREE MOBILIZATIONS TO						
			COMPLETE THESCOPE. #DEWA WILL NOT ACCEPT THE BID W						
			1 =						
			ITHOUT VISITING THE SITE, AS THIS WORKTO BE CARRIED OUT DURING TOTAL SHUT DOWN OF L1						
			STATION AND DELAY MAYAFFECT THE PLANT						
			AVAILABIL						
			ITY. #TO GET A PTW CONTRACTOR MUST SUBMIT						
			RISK ASSESSMENT AND METHOD OFSTATEMENT						
			PRIOR TO START THE WORK#CHECK CONDITION						



RFQ NUMBER : 2332503244

DATE : 15.12.2025

REQ No : 1032506232

REQ TITLE : INSULATION REMOVAL AND

DELIVERY LOCATION: 0017 - L1 STORES, JAPS

CLOSING DATE : 19.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SUITABLE						
			TO CARRY OUT WORK. CONDUCT SITE SURVEY						
			ANDSAFETY INSPECTION TO ASSESS THE						
			WORKING ENVIRONMENT.:#A SAFETY MEETING						
			WILL BE HELD TO EVA						
			LUATE THE RISK INVOLVED INMETHODS TO BE						
			USED, RISK ASSESSMENT AND, TOOLBOX TALK TO						
			BE GIVEN TO THEEMPLOYEES. HMOBILIZE THE						
			LABOR, EQ						
			UIPMENT, TOOLS, ETC. ON 12 HRS. NOTICE						
			PERIOD. #THE CONTRACTOR SHALL WORK ON 24						
			HRS. BASIS TO COMPLETE THE JOB ONTIME,						
			BASED ON DEWA						
			REQUIREMENT#COVER THE COMPLETE GRATING						
			UNDER THE HEADER TO AVOID THE						
			INSULATIONFALLING ON GROUND FLOOR/ ON						
			OTHER EQUIPMENT#INSU						
			LATION REMOVAL WILL BE REQUIRED DURING						
			TOTAL PLANT SHUT DOWN, DURING INTEGRITY						
			INSPECTION OF HRSG71 AND FOR INSPECTION OF						
			PIPESUPPORT						
			S. #MARK/NAME CLADDING SHEETS AND REMOVE						
			THE CLADDING SHEET, INSULATIONCLAMPS AND						



RFQ NUMBER : 2332503244

DATE : 15.12.2025

REQ No : 1032506232

REQ TITLE : INSULATION REMOVAL AND

DELIVERY LOCATION: 0017 - L1 STORES, JAPS

CLOSING DATE : 19.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INSULATION AS PER DEWA REQUIREMENT.:#KEEP						
			THE REMO						
			VED INSULATION AND CLADDING SHEETS IN SAFE						
			LOCATIONS ANDDO NOT ALLOW THE INSULATION						
			FIBERS TO FLY IN THE AIR-#CLEAN THE SURFACE						
			OF T						
			HE PIPE AFTER REMOVAL OF THE						
			INSULATION. #ANY CLADDING SHEET BOX (VALVES						
			OR EQUIPMENT) REMOVAL REQUIRED TOACCESS						
			THE REQUIRED AREA S						
			HALL BE DONE BY THE CONTRACTOR. CLADDING						
			SHEETALONE REMOVED CANNOT BE CONSIDERED						
			IN TOTAL INSULATION						
			REMOVALMEASUREMENT#INTIMATE D						
			EWA PERSONNEL IN CASE OF ANY ABNORMALITIES						
			/ DAMAGES FOUNDIN THE CLADDING SHEETS/						
			INSULATION SUPPORT CLAMPS ETC#INSULATION						
			SUPPORT						
			CLAMPS TO BE REMOVED WHEREVER REQUIRED						
			TO ASSISTTHE INSPECTION#INSULATION						
			SUPPORT CLAMPS TO BE REPAIRED BASED ON						
			THE REQUIREMENT.						
1			-#AFTER COMPLETION OF THE REPAIR WORK,						



RFQ NUMBER : 2332503244

DATE : 15.12.2025

REQ No : 1032506232

REQ TITLE : INSULATION REMOVAL AND

DELIVERY LOCATION: 0017 - L1 STORES, JAPS

CLOSING DATE : 19.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DEWA ENGINEER WILL GIVECLEARANCE FOR						
			INSULATION REFIXING. #INSTALL THE INSULATION						
			SUPPORT CLA						
			MPS AT SAME DISTANCE FROM WHERETHESE						
			CLAMPS WERE REMOVED#INSTALL THE						
			INSULATION (NEW INSULATION TO BE USED IF OLD						
			INSULATIONFOUND						
			DAMAGE)#ENSURE THAT THERE ARE NO WASTE /						
			CLOTH / COMBUSTIBLE MATERIALS INSIDETHE						
			INSULATION / OVER THE PIPE SURFACE WHICH						
			MAY CATC						
			H FIRE DURING HOTOPERATING						
			CONDITIONS#MAINTAIN THE SAME THICKNESS OF						
			INSULATION AS IT WAS EXISTING PRIOR						
			TOREMOVE THE INSULATION.						
			#FIX THE CERAMIC TAPE ON THE INSULATION						
			SUPPORT CLAMPS AND IN BETWEENTHE VALVE						
			BODY AND CLADDING BOX#CONTRACTOR SHALL						
			RECTIFY ANY						
			ABNORMALITIES / DEFORMATION FOUND IN						
			THECLADDING SHEETS/ VALVE BOXES. #IN CASE						
			OF COMPLETE DAMAGE OF THE CLADDING						
			SHEETS, DEWA WILL						



RFQ NUMBER : 2332503244

DATE : 15.12.2025

REQ No : 1032506232

REQ TITLE : INSULATION REMOVAL AND

DELIVERY LOCATION: 0017 - L1 STORES, JAPS

CLOSING DATE : 19.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SUPPLYNEW CLADDING SHEETS AND						
			CONTRACTOR SHALL FABRICATE AND FIX THE						
			CLADDINGSHEETS/ BOXES ACCORDING TO SITE						
			CONDITIONS#FIX THE CL						
			ADDING SHEETS/ VALVE BOXES AND ENSURE THAT						
			ALL THE FIXINGSCREWS ARE PROPERLY						
			INSTALLED. #MAKE THE GROOVE AT THE END OF						
			THE CLADDING						
			SHEET/ BOXES PRIOR TO FIX. #USE THE SEALANT						
			FOR CLADDING SHEET FIXING. #KEEP THE GOOD						
			INSULATION AT SITE IN PROPER WAY TO REUSE						
			IT.∙						
			#IF INSULATION FOUND DAMAGED, IT SHALL BE						
			PACKED IN RED POLYETHENEBAGS PROPERLY						
			AND SHALL SHIFT TO THE DESIGNATED AREA						
			(GROUND FLOOR						
			WHEREVEHICLE ACCESS IS						
			AVAILABLE). HOUSEKEEP THE AREA ON REGULAR						
			BASIS AS OTHER CONTRACTOR HAS TO WORKIN						
			THE SAME AREA.:#JOB COMPL						
			ETION ACCEPTANCE IS SUBJECTED TO DEWA						
			PERSONNEL INSPECTIONAND VERIFICATION.						
			DEWA WILL ARRANGE TO PERFORM THE						



RFQ NUMBER : 2332503244

DATE : 15.12.2025

REQ No : 1032506232

REQ TITLE : INSULATION REMOVAL AND

DELIVERY LOCATION: 0017 - L1 STORES, JAPS

CLOSING DATE : 19.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THERMOGRAPHY AFTERCOMPL						
			ETION OF INSULATION FIXING ACTIVITIES AND IF						
			THE TEMPERATURE FOUNDMORE THAN 70°C IN						
			ANY PLACE, IT WILL NOT BE ACCEPTABLE, AND						
			CONTRA						
			CTORSHALL IMMEDIATELY RECTIFY THE SAME						
			ONLINE. #SUBMIT WORK COMPLETION REPORT						
			WITH CLEAR PHOTOS. #WORK NEEDS TO BE DONE						
			IN DAY AND N						
			IGHT SHIFTS DUE TO TOTAL SHUT DOWNOF L1						
			STATION. ANY KIND OF DELAY IS NOT ACCEPTABLE						
			AT ALL.:#CONTRACTOR SHALL PROVIDE ALL						
			NECESSARY						
			AND SUFFICIENT PPES TO THEIRSTAFFS AND						
			SHALL ENSURE THAT ALL STAFF ARE ALWAYS						
			WEARING THE SAME, SINCE INSULATION WILL BE						
			REMOVING FR						
			OM HOT PIPE SURFACE WHICH CAN						
			CAUSEBLISTERS OR SEVERE SKIN BURNING. #THE						
			CONTRACTOR WILL HAVE TO START INSULATION						
			REMOVAL FROM HOT P						
			IPESURFACE AFTER PLANT SHUTDOWN WITH						
			NECESSARY ARRANGEMENTS						



RFQ NUMBER : 2332503244

DATE : 15.12.2025

REQ No : 1032506232

REQ TITLE : INSULATION REMOVAL AND

DELIVERY LOCATION: 0017 - L1 STORES, JAPS

CLOSING DATE : 19.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ACCORDINGLY#AWARDING THE PO DOES NOT						
			GUARANTEE THAT THE WHOLE JOB SCOP						
			E WILL BECONSUMED AND CAN BE						
			CLAIMED.CLAIMING SHALL BE AS PER ACTUAL						
			QUANTITY OF SCOPE CARRIED OUT.DEWA						
			SCOPE1.#SCAFFOLDING2.#ELECTR						
			ICITY3.#WATER4.#CERAMIC TAPE, INSULATION (50,						
			80 & 100 MM THICK ROCKWOOL BLANKETS),AND						
			CLADDING SHEETS IF REQUIRED IN CASE OF OLD						
			IN						
			SULATION/ CLADDINGSHEET FOUND						
			DAMAGED.5.#FLAT BAR FOR INSULATION CLAMP IF						
			FOUND DAMAGED (FABRICATION/FIXINGSHALL BE						
			UNDER CONTRACTOR						
			SCOPE)6.#BINDING WIRE7.#SILICONE						
			SEALANT8.#CLADDING SHEET						
			SCREWCONTRACTOR SCOPE OF SUPPLY:#TOOLS,						
			TACKLES, AND EQUIPMENT TO CARRY O						
			UT THE JOB. #MANPOWER. #BATTERY OPERATED						
			LIGHT IN CASE OF REQUIREMENT FOR NIGHT						
			WORK.WARRANTY.#THE MINIMUM WARRANTY						
			PERIOD FOR THE WO						
			RK SHALL BE OF ONE YEAR FROMTHE DATE OF						



RFQ NUMBER : 2332503244

DATE : 15.12.2025

REQ No : 1032506232

REQ TITLE : INSULATION REMOVAL AND

DELIVERY LOCATION: 0017 - L1 STORES, JAPS

CLOSING DATE : 19.12.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COMPLETION OF WORK ACCEPTED BY DEWA#IN						
			CASE OF ANY DAMAGE/DEFECT OF THE WORK						
			CARRIED OUT U						
			NDER THISCONTRACT WITHIN THIS WARRANTY						
			PERIOD, THE CONTRACTOR SHALL ATTEND						
			ANDCARRY OUT THE NECESSARY REPAIR WORK						
			AND RECTIFY THE DE						
			FECT WITHIN SHORTPERIOD WITHOUT AFFECTING						
			THE PRODUCTION OF ELECTRICITY AND WATER.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

INSULATION REMOVAL AND REFIXING AT L1 STATION.

for any clarification please contact Nadeem.Ahmad@dewa.gov.ae,

055-1338462

SWO attached

STANDARD TERMS & CONDITIONS



RFQ NUMBER : 2332503244

DATE : 15.12.2025

REQ No : 1032506232

REQ TITLE : INSULATION REMOVAL AND

DELIVERY LOCATION: 0017 - L1 STORES, JAPS

CLOSING DATE : 19.12.2025

CLOSING TIME : 10:00:00

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6)Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS:

SUPPLIER'S SIGNATURE AND STAMP