

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	TECHNICAL SPECIFICATION # MANUAL GATE VALVE SERVICING (CCW SYSTEM- GTE3)-#SYSTEM DETAILSO#CLOSED COOLING WATER (CCW) SUPPLIES COOLIN G WATER FOR GAS TURBINESAND GENERATORS.O#MAXIMUM OPERATING PRESSURE: 10 BAR.O#MANUAL GATE VALVES USED FOR ISOLATION: 6#, 8#, 10#.O#I NSTALLED VALVES (CONFIRM QUANTITIES IN THE BOQ):\$#6# CS, 150 LBS, GATE VALVE # [10NOS]\$#8# CS, 150 LBS, GATE VALVE # [03NOS]\$#10# CS , 150 LBS, GATE VALVE # [07NOS]\$#2" CS, 150 LBS, GATE VALVE # [02NOS]\$#-#APPLICABLE TYPICAL INTERNATIONAL STANDARDS (TESTING & INSTA LLATION).BIDDER TO SPECIFY APPLICABLE STANDARD CONSIDERED IN HIS SCOPE.O#TESTING & INSPECTION\$#API 598 # VALVE INSPECTION AND TEST (SHELL, SEAT LEAKAGE, BACKSEAT,CLOSURE INTEGRITY).\$#ISO 5208 # INDUSTRIAL VALVES#PRESSURE TESTING (ALTERNATIVE ACCEPTANCECRITERIA WHE RE AGREED).\$#MSS SP-61 # PRESSURE TESTING	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OF STEEL VALVES (SUPPLEMENTARY WHEREAPPLICABLE).\$#ASME SECTION V # NDT METHODS (FOR ANY AG REED NDT SUCH AS PT/MT ONSEATING/BONNET SURFACES).O#SURFACE PREP & COATING (POST-SERVICE)\$#ISO 8501 / ISO 8503 / ISO 8502 # SURFACE CLEANLINESS, PROFILE, ANDCONTAMINATION CHECKS.\$#ISO 12944 # CORROSION PROTECTION OF STEEL STRUCTURES BY PROTECTIVEPAINT SYSTEMS (SELECT SYSTEM PER SITE CLASS).\$#SSPC STANDARDS # AS EQUIVALENT REFERENCES FOR BLAST CLEANING ANDCOATING WORKMANSHIP.#SCOPE OF WORKO#SERVICE ALL LISTED VALVES STRICTLY PER OEM PROCEDURES AND ABOVESTANDARDS.O#SUPPLY ALL REQUIRED SPARES AND CONSUMABLES FOR SERVICING.# SPARE PARTS & CONSUMABLES (COMMERCIAL SUBMISSION)O#PROVIDE A DETAILED LIST OF RECOMMENDED SPARES/CONSUMABLES WITH PARTNO., DESCRIPTI</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ON, QUANTITY, AND UNIT PRICE.O#DEWA MAY PLACE SEPARATE ORDERS FOR SPARES AND SERVICES AT ITS DISCRETION.#SERVICING ACTIVITIESO#REMOV</p> <p>AL: ISOLATE, UNBOLT, AND REMOVE VALVES FROM THE CCW SYSTEM WITH PIPELINE PROTECTION (PLASTIC BLINDS/CAPS).O#DISASSEMBLY & INSPECTION:</p> <p>OPEN VALVE; INSPECT BODY/BONNET, STEM,WEDGE/DISC, GUIDES, SEATS, PACKING, STUDS/NUTS. CARRY OUT NDT TESTS FOR BODY AND INTERNAL CRAC</p> <p>KS.O#SERVICING: CLEAN, DE-SCALE, LAP/POLISH SEATING SURFACES; REPLACE WORN PARTS (STEM PACKING, GASKETS, FASTENERS, BUSHINGS, SEALS)</p> <p>AS PER OEM.O#LUBRICATION: APPLY OEM-APPROVED STEM & YOKE NUT LUBRICANTS; VERIFY SMOOTH HANDWHEEL/GEAR OPERATION.O#REASSEMBLY: ASSEMBLE PER OEM TORQUE VALUES, MSS SP-25 MARKINGS VERIFIED/UPDATED.O#PRESSURE & LEAK TESTING: PERFORM API 598 (OR ISO 5208)</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHELL AND SEATT ESTS AT SPECIFIED TEST PRESSURES FOR CLASS 150 VALVES; RECORDACCEPTANCE CRITERIA AND RESULTS.O#PAINTING/COATING: PREPARE SURFACES AN D COAT PER ISO 12944 SYSTEMSUITABLE FOR CCW ENVIRONMENT.O#REINSTALLATION: FIT VALVES USING STANDARD BOLTING PRACTICES; ALIGN,BOLT-UP WITH CORRECT GASKET CLASS PER ASME B16.5; VERIFY FACE-TO-FACEPER ASME B16.10.O#TESTING & COMMISSIONING: FUNCTIONAL STROKE CHECKS, C LOSUREVERIFICATION, AND FINAL TIGHTNESS UNDER 10 BAR SYSTEM CONDITIONS.#QUALITY ASSURANCE & DOCUMENTATIONO#INITIAL INSPECTION REPOR T UPON RECEIPT/REMOVAL (CONDITION, SERIALS,MARKINGS, DIMENSIONAL CHECKS).O#FINAL INSPECTION & TEST REPORTS POST-SERVICE (TEST CERTIF ICATES, NDTREPORTS IF PERFORMED).O#MATERIAL TEST CERTIFICATES</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FOR REPLACED PARTS (WHERE APPLICABLE), COATING DFT READINGS, TORQUE REC ORDS, AND SIGN-OFFS. O# MAINTAIN TRACEABILITY TO STANDARDS/OEM AND UNIQUE VALVE TAGS IN ALL RECORDS. O# ENSURE ALIGNMENT WITH DEWA TENDER /ITP DOCUMENTATION PRACTICES PREVIOUSLY USED FOR VALVES SERVICING. # ADDITIONAL REQUIREMENTS O# SCAFFOLDING TO BE PROVIDED BY DEWA AT NO COST. O# ANY OEM-RECOMMENDED TASKS NOT EXPLICITLY LISTED SHALL BE DEEMED INCLUDED IN CONTRACTOR'S SCOPE. O# MAXIMUM DURATION FROM DISMAN TLING TO RE-ERECTION PER BATCH OF VALVES: # 10 DAYS. # COMMERCIAL & SCHEDULING O# SUBMIT SEPARATE PRICE SCHEDULES FOR SERVICES AND SPARE S. O# PROVIDE A WORK PROGRAM INDICATING SEQUENCE (REMOVAL # SERVICE # TEST # REINSTALL) TO MEET THE # 10 DAYS TURNAROUND.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
2		ITEM-00001	TECHNICAL SPECIFICATION # MANUAL GATE VALVE SERVICING (CCW SYSTEM- GTE3)-#SYSTEM DETAILSO#CLOSED COOLING WATER (CCW) SUPPLIES COOLIN G WATER FOR GAS TURBINESAND GENERATORS.O#MAXIMUM OPERATING PRESSURE: 10 BAR.O#MANUAL GATE VALVES USED FOR ISOLATION: 6#, 8#, 10#.O#I NSTALLED VALVES (CONFIRM QUANTITIES IN THE BOQ):\$#6# CS, 150 LBS, GATE VALVE # [10NOS]\$#8# CS, 150 LBS, GATE VALVE # [03NOS]\$#10# CS , 150 LBS, GATE VALVE # [07NOS]\$#2" CS, 150 LBS, GATE VALVE # [02NOS]\$#-#APPLICABLE TYPICAL INTERNATIONAL STANDARDS (TESTING & INSTA LLATION).BIDDER TO SPECIFY APPLICABLE STANDARD CONSIDERED IN HIS SCOPE.O#TESTING & INSPECTION\$#API 598 # VALVE INSPECTION AND TEST (SHELL, SEAT LEAKAGE, BACKSEAT,CLOSURE INTEGRITY).\$#ISO 5208 # INDUSTRIAL VALVES#PRESSURE TESTING (ALTERNATIVE ACCEPTANCECRITERIA WHE RE AGREED).\$#MSS SP-61 # PRESSURE TESTING	10	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OF STEEL VALVES (SUPPLEMENTARY WHEREAPPLICABLE).\$#ASME SECTION V # NDT METHODS (FOR ANY AG REED NDT SUCH AS PT/MT ONSEATING/BONNET SURFACES).O#SURFACE PREP & COATING (POST-SERVICE)\$#ISO 8501 / ISO 8503 / ISO 8502 # SURFACE CLEANLINESS, PROFILE, ANDCONTAMINATION CHECKS.\$#ISO 12944 # CORROSION PROTECTION OF STEEL STRUCTURES BY PROTECTIVEPAINT SYSTEMS (SELECT SYSTEM PER SITE CLASS).\$#SSPC STANDARDS # AS EQUIVALENT REFERENCES FOR BLAST CLEANING ANDCOATING WORKMANSHIP.#SCOPE OF WORKO#SERVICE ALL LISTED VALVES STRICTLY PER OEM PROCEDURES AND ABOVESTANDARDS.O#SUPPLY ALL REQUIRED SPARES AND CONSUMABLES FOR SERVICING.# SPARE PARTS & CONSUMABLES (COMMERCIAL SUBMISSION)O#PROVIDE A DETAILED LIST OF RECOMMENDED SPARES/CONSUMABLES WITH PARTNO., DESCRIPTI</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ON, QUANTITY, AND UNIT PRICE.O#DEWA MAY PLACE SEPARATE ORDERS FOR SPARES AND SERVICES AT ITS DISCRETION.#SERVICING ACTIVITIESO#REMOV</p> <p>AL: ISOLATE, UNBOLT, AND REMOVE VALVES FROM THE CCW SYSTEM WITH PIPELINE PROTECTION (PLASTIC BLINDS/CAPS).O#DISASSEMBLY & INSPECTION:</p> <p>OPEN VALVE; INSPECT BODY/BONNET, STEM,WEDGE/DISC, GUIDES, SEATS, PACKING, STUDS/NUTS. CARRY OUT NDT TESTS FOR BODY AND INTERNAL CRAC</p> <p>KS.O#SERVICING: CLEAN, DE-SCALE, LAP/POLISH SEATING SURFACES; REPLACE WORN PARTS (STEM PACKING, GASKETS, FASTENERS, BUSHINGS, SEALS)</p> <p>AS PER OEM.O#LUBRICATION: APPLY OEM-APPROVED STEM & YOKE NUT LUBRICANTS; VERIFY SMOOTH HANDWHEEL/GEAR OPERATION.O#REASSEMBLY: ASSEMBLE PER OEM TORQUE VALUES, MSS SP-25 MARKINGS VERIFIED/UPDATED.O#PRESSURE & LEAK TESTING: PERFORM API 598 (OR ISO 5208)</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHELL AND SEATT ESTS AT SPECIFIED TEST PRESSURES FOR CLASS 150 VALVES; RECORDACCEPTANCE CRITERIA AND RESULTS.O#PAINTING/COATING: PREPARE SURFACES AN D COAT PER ISO 12944 SYSTEMSUITABLE FOR CCW ENVIRONMENT.O#REINSTALLATION: FIT VALVES USING STANDARD BOLTING PRACTICES; ALIGN,BOLT-UP WITH CORRECT GASKET CLASS PER ASME B16.5; VERIFY FACE-TO-FACEPER ASME B16.10.O#TESTING & COMMISSIONING: FUNCTIONAL STROKE CHECKS, C LOSUREVERIFICATION, AND FINAL TIGHTNESS UNDER 10 BAR SYSTEM CONDITIONS.#QUALITY ASSURANCE & DOCUMENTATIONO#INITIAL INSPECTION REPOR T UPON RECEIPT/REMOVAL (CONDITION, SERIALS,MARKINGS, DIMENSIONAL CHECKS).O#FINAL INSPECTION & TEST REPORTS POST-SERVICE (TEST CERTIF ICATES, NDTREPORTS IF PERFORMED).O#MATERIAL TEST CERTIFICATES</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FOR REPLACED PARTS (WHERE APPLICABLE), COATING DFT READINGS, TORQUE REC ORDS, AND SIGN-OFFS. O# MAINTAIN TRACEABILITY TO STANDARDS/OEM AND UNIQUE VALVE TAGS IN ALL RECORDS. O# ENSURE ALIGNMENT WITH DEWA TENDER /ITP DOCUMENTATION PRACTICES PREVIOUSLY USED FOR VALVES SERVICING. # ADDITIONAL REQUIREMENTS O# SCAFFOLDING TO BE PROVIDED BY DEWA AT NO COST. O# ANY OEM-RECOMMENDED TASKS NOT EXPLICITLY LISTED SHALL BE DEEMED INCLUDED IN CONTRACTOR'S SCOPE. O# MAXIMUM DURATION FROM DISMAN TLING TO RE-ERECTION PER BATCH OF VALVES: # 10 DAYS. # COMMERCIAL & SCHEDULING O# SUBMIT SEPARATE PRICE SCHEDULES FOR SERVICES AND SPARE S. O# PROVIDE A WORK PROGRAM INDICATING SEQUENCE (REMOVAL # SERVICE # TEST # REINSTALL) TO MEET THE # 10 DAYS TURNAROUND.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
3		ITEM-00001	TECHNICAL SPECIFICATION # MANUAL GATE VALVE SERVICING (CCW SYSTEM- GTE3)-#SYSTEM DETAILSO#CLOSED COOLING WATER (CCW) SUPPLIES COOLIN G WATER FOR GAS TURBINESAND GENERATORS.O#MAXIMUM OPERATING PRESSURE: 10 BAR.O#MANUAL GATE VALVES USED FOR ISOLATION: 6#, 8#, 10#.O#I NSTALLED VALVES (CONFIRM QUANTITIES IN THE BOQ):\$#6# CS, 150 LBS, GATE VALVE # [10NOS]\$#8# CS, 150 LBS, GATE VALVE # [03NOS]\$#10# CS , 150 LBS, GATE VALVE # [07NOS]\$#2" CS, 150 LBS, GATE VALVE # [02NOS]\$#-#APPLICABLE TYPICAL INTERNATIONAL STANDARDS (TESTING & INSTA LLATION).BIDDER TO SPECIFY APPLICABLE STANDARD CONSIDERED IN HIS SCOPE.O#TESTING & INSPECTION\$#API 598 # VALVE INSPECTION AND TEST (SHELL, SEAT LEAKAGE, BACKSEAT,CLOSURE INTEGRITY).\$#ISO 5208 # INDUSTRIAL VALVES#PRESSURE TESTING (ALTERNATIVE ACCEPTANCECRITERIA WHE RE AGREED).\$#MSS SP-61 # PRESSURE TESTING	3	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OF STEEL VALVES (SUPPLEMENTARY WHEREAPPLICABLE).\$#ASME SECTION V # NDT METHODS (FOR ANY AG REED NDT SUCH AS PT/MT ONSEATING/BONNET SURFACES).O#SURFACE PREP & COATING (POST-SERVICE)\$#ISO 8501 / ISO 8503 / ISO 8502 # SURFACE CLEANLINESS, PROFILE, ANDCONTAMINATION CHECKS.\$#ISO 12944 # CORROSION PROTECTION OF STEEL STRUCTURES BY PROTECTIVEPAINT SYSTEMS (SELECT SYSTEM PER SITE CLASS).\$#SSPC STANDARDS # AS EQUIVALENT REFERENCES FOR BLAST CLEANING ANDCOATING WORKMANSHIP.#SCOPE OF WORKO#SERVICE ALL LISTED VALVES STRICTLY PER OEM PROCEDURES AND ABOVESTANDARDS.O#SUPPLY ALL REQUIRED SPARES AND CONSUMABLES FOR SERVICING.# SPARE PARTS & CONSUMABLES (COMMERCIAL SUBMISSION)O#PROVIDE A DETAILED LIST OF RECOMMENDED SPARES/CONSUMABLES WITH PARTNO., DESCRIPTI</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ON, QUANTITY, AND UNIT PRICE.O#DEWA MAY PLACE SEPARATE ORDERS FOR SPARES AND SERVICES AT ITS DISCRETION.#SERVICING ACTIVITIESO#REMOV</p> <p>AL: ISOLATE, UNBOLT, AND REMOVE VALVES FROM THE CCW SYSTEM WITH PIPELINE PROTECTION (PLASTIC BLINDS/CAPS).O#DISASSEMBLY & INSPECTION:</p> <p>OPEN VALVE; INSPECT BODY/BONNET, STEM,WEDGE/DISC, GUIDES, SEATS, PACKING, STUDS/NUTS. CARRY OUT NDT TESTS FOR BODY AND INTERNAL CRAC</p> <p>KS.O#SERVICING: CLEAN, DE-SCALE, LAP/POLISH SEATING SURFACES; REPLACE WORN PARTS (STEM PACKING, GASKETS, FASTENERS, BUSHINGS, SEALS)</p> <p>AS PER OEM.O#LUBRICATION: APPLY OEM-APPROVED STEM & YOKE NUT LUBRICANTS; VERIFY SMOOTH HANDWHEEL/GEAR OPERATION.O#REASSEMBLY: ASSEMBLE PER OEM TORQUE VALUES, MSS SP-25 MARKINGS VERIFIED/UPDATED.O#PRESSURE & LEAK TESTING: PERFORM API 598 (OR ISO 5208)</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHELL AND SEATT ESTS AT SPECIFIED TEST PRESSURES FOR CLASS 150 VALVES; RECORDACCEPTANCE CRITERIA AND RESULTS.O#PAINTING/COATING: PREPARE SURFACES AN D COAT PER ISO 12944 SYSTEMSUITABLE FOR CCW ENVIRONMENT.O#REINSTALLATION: FIT VALVES USING STANDARD BOLTING PRACTICES; ALIGN,BOLT-UP WITH CORRECT GASKET CLASS PER ASME B16.5; VERIFY FACE-TO-FACEPER ASME B16.10.O#TESTING & COMMISSIONING: FUNCTIONAL STROKE CHECKS, C LOSUREVERIFICATION, AND FINAL TIGHTNESS UNDER 10 BAR SYSTEM CONDITIONS.#QUALITY ASSURANCE & DOCUMENTATIONO#INITIAL INSPECTION REPOR T UPON RECEIPT/REMOVAL (CONDITION, SERIALS,MARKINGS, DIMENSIONAL CHECKS).O#FINAL INSPECTION & TEST REPORTS POST-SERVICE (TEST CERTIF ICATES, NDTREPORTS IF PERFORMED).O#MATERIAL TEST CERTIFICATES</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FOR REPLACED PARTS (WHERE APPLICABLE), COATING DFT READINGS, TORQUE REC</p> <p>ORDS, AND SIGN-OFFS.O#MAINTAIN TRACEABILITY TO STANDARDS/OEM AND UNIQUE VALVE TAGS IN ALL RECORDS.O#ENSURE ALIGNMENT WITH DEWA TENDER</p> <p>/ITP DOCUMENTATION PRACTICES PREVIOUSLY USED FOR VALVES SERVICING.#ADDITIONAL REQUIREMENTS O#SCAFFOLDING TO BE PROVIDED BY DEWA AT NO</p> <p>COST.O#ANY OEM-RECOMMENDED TASKS NOT EXPLICITLY LISTED SHALL BE DEEMED INCLUDED IN CONTRACTOR'S SCOPE.O#MAXIMUM DURATION FROM DISMAN</p> <p>TLING TO RE-ERECTION PER BATCH OF VALVES:# 10 DAYS.#COMMERCIAL & SCHEDULING O#SUBMIT SEPARATE PRICE SCHEDULES FOR SERVICES AND SPARE</p> <p>S.O#PROVIDE A WORK PROGRAM INDICATING SEQUENCE (REMOVAL # SERVICE # TEST# REINSTALL) TO MEET THE # 10 DAYS TURNAROUND.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
4		ITEM-00001	TECHNICAL SPECIFICATION # MANUAL GATE VALVE SERVICING (CCW SYSTEM- GTE3)-#SYSTEM DETAILSO#CLOSED COOLING WATER (CCW) SUPPLIES COOLIN G WATER FOR GAS TURBINESAND GENERATORS.O#MAXIMUM OPERATING PRESSURE: 10 BAR.O#MANUAL GATE VALVES USED FOR ISOLATION: 6#, 8#, 10#.O#I NSTALLED VALVES (CONFIRM QUANTITIES IN THE BOQ):\$#6# CS, 150 LBS, GATE VALVE # [10NOS]\$#8# CS, 150 LBS, GATE VALVE # [03NOS]\$#10# CS , 150 LBS, GATE VALVE # [07NOS]\$#2" CS, 150 LBS, GATE VALVE # [02NOS]\$#-#APPLICABLE TYPICAL INTERNATIONAL STANDARDS (TESTING & INSTA LLATION).BIDDER TO SPECIFY APPLICABLE STANDARD CONSIDERED IN HIS SCOPE.O#TESTING & INSPECTION\$#API 598 # VALVE INSPECTION AND TEST (SHELL, SEAT LEAKAGE, BACKSEAT,CLOSURE INTEGRITY).\$#ISO 5208 # INDUSTRIAL VALVES#PRESSURE TESTING (ALTERNATIVE ACCEPTANCECRITERIA WHE RE AGREED).\$#MSS SP-61 # PRESSURE TESTING	7	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OF STEEL VALVES (SUPPLEMENTARY WHEREAPPLICABLE).\$#ASME SECTION V # NDT METHODS (FOR ANY AG REED NDT SUCH AS PT/MT ONSEATING/BONNET SURFACES).O#SURFACE PREP & COATING (POST-SERVICE)\$#ISO 8501 / ISO 8503 / ISO 8502 # SURFACE CLEANLINESS, PROFILE, ANDCONTAMINATION CHECKS.\$#ISO 12944 # CORROSION PROTECTION OF STEEL STRUCTURES BY PROTECTIVEPAINT SYSTEMS (SELECT SYSTEM PER SITE CLASS).\$#SSPC STANDARDS # AS EQUIVALENT REFERENCES FOR BLAST CLEANING ANDCOATING WORKMANSHIP.#SCOPE OF WORKO#SERVICE ALL LISTED VALVES STRICTLY PER OEM PROCEDURES AND ABOVESTANDARDS.O#SUPPLY ALL REQUIRED SPARES AND CONSUMABLES FOR SERVICING.# SPARE PARTS & CONSUMABLES (COMMERCIAL SUBMISSION)O#PROVIDE A DETAILED LIST OF RECOMMENDED SPARES/CONSUMABLES WITH PARTNO., DESCRIPTI</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ON, QUANTITY, AND UNIT PRICE.O#DEWA MAY PLACE SEPARATE ORDERS FOR SPARES AND SERVICES AT ITS DISCRETION.#SERVICING ACTIVITIESO#REMOV</p> <p>AL: ISOLATE, UNBOLT, AND REMOVE VALVES FROM THE CCW SYSTEM WITH PIPELINE PROTECTION (PLASTIC BLINDS/CAPS).O#DISASSEMBLY & INSPECTION:</p> <p>OPEN VALVE; INSPECT BODY/BONNET, STEM,WEDGE/DISC, GUIDES, SEATS, PACKING, STUDS/NUTS. CARRY OUT NDT TESTS FOR BODY AND INTERNAL CRAC</p> <p>KS.O#SERVICING: CLEAN, DE-SCALE, LAP/POLISH SEATING SURFACES; REPLACE WORN PARTS (STEM PACKING, GASKETS, FASTENERS, BUSHINGS, SEALS)</p> <p>AS PER OEM.O#LUBRICATION: APPLY OEM-APPROVED STEM & YOKE NUT LUBRICANTS; VERIFY SMOOTH HANDWHEEL/GEAR OPERATION.O#REASSEMBLY: ASSEMBLE PER OEM TORQUE VALUES, MSS SP-25 MARKINGS VERIFIED/UPDATED.O#PRESSURE & LEAK TESTING: PERFORM API 598 (OR ISO 5208)</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHELL AND SEATT ESTS AT SPECIFIED TEST PRESSURES FOR CLASS 150 VALVES; RECORDACCEPTANCE CRITERIA AND RESULTS.O#PAINTING/COATING: PREPARE SURFACES AN D COAT PER ISO 12944 SYSTEMSUITABLE FOR CCW ENVIRONMENT.O#REINSTALLATION: FIT VALVES USING STANDARD BOLTING PRACTICES; ALIGN,BOLT-UP WITH CORRECT GASKET CLASS PER ASME B16.5; VERIFY FACE-TO-FACEPER ASME B16.10.O#TESTING & COMMISSIONING: FUNCTIONAL STROKE CHECKS, C LOSUREVERIFICATION, AND FINAL TIGHTNESS UNDER 10 BAR SYSTEM CONDITIONS.#QUALITY ASSURANCE & DOCUMENTATIONO#INITIAL INSPECTION REPOR T UPON RECEIPT/REMOVAL (CONDITION, SERIALS,MARKINGS, DIMENSIONAL CHECKS).O#FINAL INSPECTION & TEST REPORTS POST-SERVICE (TEST CERTIF ICATES, NDTREPORTS IF PERFORMED).O#MATERIAL TEST CERTIFICATES</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FOR REPLACED PARTS (WHERE APPLICABLE), COATING DFT READINGS, TORQUE REC ORDS, AND SIGN-OFFS. O# MAINTAIN TRACEABILITY TO STANDARDS/OEM AND UNIQUE VALVE TAGS IN ALL RECORDS. O# ENSURE ALIGNMENT WITH DEWA TENDER /ITP DOCUMENTATION PRACTICES PREVIOUSLY USED FOR VALVES SERVICING. # ADDITIONAL REQUIREMENTS O# SCAFFOLDING TO BE PROVIDED BY DEWA AT NO COST. O# ANY OEM-RECOMMENDED TASKS NOT EXPLICITLY LISTED SHALL BE DEEMED INCLUDED IN CONTRACTOR'S SCOPE. O# MAXIMUM DURATION FROM DISMAN TLING TO RE-ERECTION PER BATCH OF VALVES: # 10 DAYS. # COMMERCIAL & SCHEDULING O# SUBMIT SEPARATE PRICE SCHEDULES FOR SERVICES AND SPARE S. O# PROVIDE A WORK PROGRAM INDICATING SEQUENCE (REMOVAL # SERVICE # TEST # REINSTALL) TO MEET THE # 10 DAYS TURNAROUND.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503259
DATE : 16.12.2025
REQ No : 1032506038
REQ TITLE : E'STATION GTE#3 OFF BASE
DELIVERY LOCATION
CLOSING DATE : 22.12.2025
CLOSING TIME : 10:00:00

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

E'STATION GTE3 OFF BASE COOLER GATE VALVE SERVICING

1. 6# CS, 150 lbs, gate valve [10 NOS]
2. 8# CS, 150 lbs, gate valve [03 NOS]
3. 10# CS, 150 lbs, gate valve [07 NOS]
4. 2" CS, 150 lbs, gate valve [02 NOS]

FOR FURTHER DETAILS, PLEASE CONTACT ASM MYNUDDIN (0503620814)
MYNUDDIN.HOSSAIN@DEWA.GOV.AE/MARWAN AL MHEIRI (0501136322) (MARWAN.ALM
HEIRI@DEWA.GOV.AE)/AHMED ZAKARIA(0524781810)ahmed.eldaly@dewa.gov.ae

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332503259
DATE	: 16.12.2025
REQ No	: 1032506038
REQ TITLE	: E'STATION GTE#3 OFF BASE
DELIVERY LOCATION	
CLOSING DATE	: 22.12.2025
CLOSING TIME	: 10:00:00

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

6)Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by theSupplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP