

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503267  
**DATE** : 16.12.2025  
**REQ No** : 1032506272  
**REQ TITLE** : Replacement of Fire Alarm Pan  
**DELIVERY LOCATION**  
**CLOSING DATE** : 22.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SCOPE OF WORK:# SUPPLY AND INSTALLATION OF FIRE ALARM PANEL WITH NEW SHEILD P-A300ADDRESSABLE WITH COMPLETE DEVICES.# SINGLE LOOP A DDRESSABLE FIRE CONTROL PANEL,FLASHER, SMOKE DETECTORS,HEAT DETECTOR WITH WP SOUNDER FLASHERS.# FACP PANEL IN CONTROL ROOM: 1 UNIT.# REPEATER PANEL IN SECURITY ROOM: 1 UNIT.PANEL REPLACEMENT WILL BE DONE IN THE FOLLOWING LOCATIONS:# OPERATION CONTROL ROOM# SECURIT Y ROOM REPEATER PANELTHE TOTAL NUMBER OF DEVICES CONNECTED IS AS FOLLOWS:# SOUNDERS W/P AS PER REQUIREMENTS: 6 UNITS# HEAT DETECTORS : 3 UNITS.# SMOKE DETECTORS: 6 UNITS.# BREAK GLASS UNITS: 6 UNITS.ADDITIONAL SPECIFICATIONS:# INTERFACING WITH DCD 24X7 MONITORI NG PANEL.# THE WORK INCLUDES SUPPLY, INSTALLATION, AND COMMISSIONING OF FIREALARM PANELS AND REPEATER PANELS WITH	1	LS				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503267  
**DATE** : 16.12.2025  
**REQ No** : 1032506272  
**REQ TITLE** : Replacement of Fire Alarm Pan  
**DELIVERY LOCATION**  
**CLOSING DATE** : 22.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COMPLETE DEVICES.# ALL DEVICES ARE INSTALLED IN ACCORDANCE WITH DCD RULES AND REGULATIONS.# THE SYSTEM SHOULD BE SYNCHRONIZED STATUS AND CONNECTED WITH EXISTING SCADA SYSTEM.# QUANTITY OF DEVICES TO BE REMOVED AND REPLACED AS PER EXISTING INSTALLATION.# ALL WIRING ACCESSORIES, WIRE AND DUCTS/PIPES REPLACE AS PER REQUIREMENTS AND STANDARD.# INCLUDING ANY TYPE OF CIVIL WORK (INTERLOCK EXCAVATION AND REINSTATEMENT, SAND EXCAVATION AND BACK FILLING, WALL HOLES) WILL BE THE RESPONSIBILITY OF THE CONTRACTOR.# IF EXCAVATION REQUIRED, THE CONTRACTOR WILL PROVIDE THE STANDARD DUCT PIPE WITH WARNING TAPE AS PER DEWA STANDARD.						
2		ITEM-00001	REPLACEMENT OF FAULTY FIRE ALARM PANEL AND REPEATER PANEL AT MUSHRIF RESERVOIR; -SCOPE OF WORK:# SUPPLY AND INSTALLATION OF FIRE ALAR	1	LS				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503267  
**DATE** : 16.12.2025  
**REQ No** : 1032506272  
**REQ TITLE** : Replacement of Fire Alarm Pan  
**DELIVERY LOCATION**  
**CLOSING DATE** : 22.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>M PANEL WITH NEW SHEILD P-A300MADE BY UK WITH COMPLETE DEVICES AND REQUIREMENTS.# ADDRESSABLE FIRE CONTROL PANEL, XENON FLASHER, ION IZATION SMOKEDETECTORS, HEAT DETECTOR WITH WP GASKET FOR SOUNDER.# FACP PANEL IN CONTROL ROOM: 4 UNITS.# REPEATER PANEL IN SE CURITY ROOM: 1 UNIT.FACP REPLACEMENT WILL BE DONE IN THE FOLLOWING LOCATIONS:# OPERATION CONTROL ROOM# OLD LV ROOM# OLD ACCOMMODATIO N# GUARD ROOM FACP PANEL AND REPEATER PANEL.# CHLORINATION BUILDING (CONVENTIONAL PANEL GENT 3260)THE TOTAL NUMBER OF DEVICES CONNEC TED IS AS FOLLOWS:# SMOKE DETECTOR : 27UNITS# HEAT DETECTOR 17UNITS# MCP 13UNITS# SOUN DER (INSIDE) WITH STROBE 13UNITS# SOUNDER OUTSIDE WP 4 UNITS# FLASHER OUT SIDE WP 3 UNITSADDITIONAL SPECIFICATIONS:# INTERFACING WIT</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503267  
**DATE** : 16.12.2025  
**REQ No** : 1032506272  
**REQ TITLE** : Replacement of Fire Alarm Pan  
**DELIVERY LOCATION**  
**CLOSING DATE** : 22.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>H DCD 24X7 MONITORING PANEL.# THE WORK INCLUDES SUPPLY, INSTALLATION, AND COMMISSIONING OF FIREALARM PANELS AND REPEATER PANELS WITH COMPLETE DEVICES.# ALL DEVICES ARE INSTALLED IN ACCORDANCE WITH DCD RULES ANDREGULATIONS.# THE SYSTEM SHOULD BE SYNCHRONIZED STATUS AND CONNECTED WITH EXISTINGSCADA SYSTEM.# QUANTITY OF DEVICES TO BE REMOVED AND REPLACED AS PER EXISTINGINSTALLATION.# ALL WIRING ACCESSORIES, WIRE AND DUCTS/PIPES REPLACE AS PERREQUIREMENTS AND STANDARD.# INCLUDING ANY TYPE OF CIVIL WORK (INTERLOCK EXCAVATION AND DREINSTATEMENT, SAND EXCAVATION AND BACK FILLING, WALL HOLES) WILL BE THERESPONSIBILITY OF THE CONTRACTOR.IF EXCAVATION IS REQUIRED, THE CONTRACTOR WILL PROVIDE THE STANDARD DUCTPIPE WITH WARNING TAPE AS PER DEWASTANDARD.</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503267  
**DATE** : 16.12.2025  
**REQ No** : 1032506272  
**REQ TITLE** : Replacement of Fire Alarm Pan  
**DELIVERY LOCATION**  
**CLOSING DATE** : 22.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
3		ITEM-00001	REPLACEMENT OF FAULTY FIRE ALARM PANEL AND REPEATER PANEL AT LUSAILY NEWPUMPING STATION; -SCOPE OF WORK:# SUPPLY AND INSTALLATION OF FIRE ALARM PANEL WITH NEW SHEILD P-A300WITH COMPLETE DEVICES AND REQUIREMENTS.# SINGLE LOOP ADDRESSABLE FIRE CONTROL PANEL, XENON F LASHER, IONIZATIONS MOKE DETECTORS, HEAT DETECTOR WITH WP GASKET FOR SOUNDER.# FACP PANEL IN CONTROL ROOM: 1 UNITS.# REPEATER PANEL I N SECURITY ROOM: 1 UNIT.PANEL REPLACEMENT WILL BE DONE IN THE FOLLOWING LOCATIONS:# CONTROL ROOM.# SECURITY PORTA CABIN FACP PANEL A ND REPEATER PANEL.THE TOTAL NUMBER OF DEVICES CONNECTED IS AS FOLLOWS:# SOUNDERS: 6 UNITS# HEAT DETECTORS: 5 UNIT S# SMOKE DETECTORS: 6 UNITS# BREAK GLASS UNITS: 5 UNITSADDITIONAL SPECIFICATIONS:# INTERFACING WITH DCD 24X7 MONITORING	1	LS				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503267  
**DATE** : 16.12.2025  
**REQ No** : 1032506272  
**REQ TITLE** : Replacement of Fire Alarm Pan  
**DELIVERY LOCATION**  
**CLOSING DATE** : 22.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PANEL.# THE WORK INCLUDES SUPPLY, INSTALLATION, AND COMMISSIONING OF FIREALARM PANELS AND REPEATER PANELS WITH COMPLETE DEVICES.# ALL DEVICE S ARE INSTALLED IN ACCORDANCE WITH DCD RULES ANDREGULATIONS.# THE SYSTEM SHOULD BE SYNCHRONIZED STATUS AND CONNECTED WITH YOUEXISTI NG SCADS SYSTEM.# QUANTITY OF DEVICES TO BE REMOVED AND REPLACED AS PER EXISTINGINSTALLATION.# ALL WIRING ACCESSORIES, WIRE AND DUCT S/PIPES REPLACE AS PERREQUIREMENTS AND STANDARD.# INCLUDING ANY TYPE OF CIVIL WORK (INTERLOCK EXCAVATION ANDREINSTATEMENT, SAND EXCA VATION AND BACK FILLING, WALL HOLES) WILL BE THERESPONSIBILITY OF THE CONTRACTOR.# 1 NO FIRE HOSE REEL RELOCATED AS PER DEWA ENGINEE R DIRECTION.IF EXCAVATION IS REQUIRED, THE CONTRACTOR WILL PROVIDE THE STANDARD</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503267  
**DATE** : 16.12.2025  
**REQ No** : 1032506272  
**REQ TITLE** : Replacement of Fire Alarm Pan  
**DELIVERY LOCATION**  
**CLOSING DATE** : 22.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DUCTPIPE WITH WARNING TAPE AS PER DEWA STANDARD.						
4		ITEM-00001	REPLACEMENT OF FAULTY FIRE ALARM PANEL AND REPEATER PANEL AT AL YASSATISLAND RO PLANT; -SCOPE OF WORK:# SUPPLY AND INSTALLATION OF FIRE ALARM PANEL WITH NEW SHEILD PA300 WITHCOMPLETE DEVICES AND REQUIREMENTS.# SINGLE LOOP ADDRESSABLE FIRE CONTROL PANEL, FLASHER, SMOKE DETECTORS,HEAT DETECTOR WITH WP GASKET FOR SOUNDER.# FACP PANEL IN CONTROL ROOM: 1 UNIT.# REPEATER PANEL IN SECURITY ROOM: 1 UNIT.PANEL REPLACEMENT WILL BE DONE IN THE FOLLOWING LOCATIONS:# CONTROL ROOM.# SECURITY PORTA CABIN FACP PANEL AND REPEATER PANEL.THE TOTAL NUMBER OF DEVICES CONNECTED IS AS FOLLOWS:# SOUNDERS AND FLASHER: 16 UNITS.# HEAT DETECTORS: 12 UNITS.# SMOKE DETECTORS: 20 UNITS.# BREAK GLASS UNITS: 12	1	LS				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503267  
**DATE** : 16.12.2025  
**REQ No** : 1032506272  
**REQ TITLE** : Replacement of Fire Alarm Pan  
**DELIVERY LOCATION**  
**CLOSING DATE** : 22.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>UNITS.A DDITIONAL SPECIFICATIONS:# INTERFACING WITH DCD 24X7 MONITORING PANEL.# THE WORK INCLUDES SUPPLY, INSTALLATION, AND COMMISSIONING OF FIREALARM PANELS AND REPEATER PANELS WITH COMPLETE DEVICES.# ALL DEVICES ARE INSTALLED IN ACCORDANCE WITH DCD RULES ANDREGULATIONS. # THE SYSTEM SHOULD BE SYNCHRONIZED STATUS AND CONNECTED WITH EXISTINGSCADA SYSTEM.# QUANTITY OF DEVICES TO BE REMOVED AND REPLACED AS PER EXISTINGINSTALLATION.# ALL WIRING ACCESSORIES, WIRE AND DUCTS/PIPES REPLACE AS PERREQUIREMENTS AND STANDARD.# INCLUDING ANY T YPE OF CIVIL WORK (INTERLOCK EXCAVATION ANDREINSTATEMENT, SAND EXCAVATION AND BACK FILLING, WALL HOLES) WILL BE THERESPONSIBILITY OF THE CONTRACTOR.IF EXCAVATION IS REQUIRED, THE CONTRACTOR WILL PROVIDE THE STANDARD</p>						



## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503267  
**DATE** : 16.12.2025  
**REQ No** : 1032506272  
**REQ TITLE** : Replacement of Fire Alarm Pan  
**DELIVERY LOCATION**  
**CLOSING DATE** : 22.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DUCTPIPE WITH WARNING TAPE AS PER DEWA STANDARD.						
5		ITEM-00001	REFILLING OF GAS FM-200 CYLINDER AT LUSAILY RESERVOIR.CHLORINE DOSSING ROOM# REFILLING OF GAS FM-200 CYLINDER FOR FIRE SUPPRESSION S YSTEM.# TARE WEIGHT 35.22 KG# GROSS NET WEIGHT 75.22K KG# HEPTAFLUOROPROPANE GAS WEIGH HCF-277EA 40KG HYDROSTATICS PRESSURETEST REQUIRED FOR CYLINDER.# MAKE FIKE USA.	1	LS				

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### SPECIAL NOTES / INSTRUCTIONS:

Replacement of Fire Alarm Panel and Associated works at various pumping station and reservoirs

Contact : Adnan Haider / 509634981

Site Visit Date <(>&<)> Time : 18/12/2025

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503267  
**DATE** : 16.12.2025  
**REQ No** : 1032506272  
**REQ TITLE** : Replacement of Fire Alarm Pan  
**DELIVERY LOCATION**  
**CLOSING DATE** : 22.12.2025  
**CLOSING TIME** : 10:00:00

Payment Terms : 100 % upon Job Completion / Retention Condition : 5 %  
will be retained for one year DLP

### **STANDARD TERMS & CONDITIONS**

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
  - 2) Quotation to be submitted only in local currency U.A.E Dirhams
  - 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
  - 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
  - 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
  - 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.
- If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503267  
**DATE** : 16.12.2025  
**REQ No** : 1032506272  
**REQ TITLE** : Replacement of Fire Alarm Pan  
**DELIVERY LOCATION**  
**CLOSING DATE** : 22.12.2025  
**CLOSING TIME** : 10:00:00

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**