

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503287

DATE : 18.12.2025

REQ No : 1032506342

REQ TITLE : JAPS L1-STATION

DELIVERY LOCATION

CLOSING DATE : 24.12.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	FABRICATION AND INSTALLATION OF END CONNECTION FITTINGS FOR CO# STORAGETANK FILLING AND EQUALIZING LINE SCOPE OVERVIEW:THIS SCOPE OF WORK IS TO FABRICATE AND INSTALL NEW END CONNECTIONFITTINGS FOR THE 1½-INCH FILLING LINE AND 1-INCH EQUALIZING LINE OF THECO# STORA GE TANK. THE NEW FITTINGS SHALL MATCH THE EXISTING INSTALLEDCONNECTIONS AT SITE ON ONE END AND INTERFACE WITH STANDARD CO# FILLINGEQ UIPMENT AVAILABLE IN THE MARKET ON THE OTHER. WORK INCLUDES MATERIALSUPPLY, FABRICATION, INSTALLATION, TESTING, AND HANDOVER UP TO R EADINESSFOR THIRD-PARTY CO# TOP-UP.SCOPE OF WORK:SITE VERIFICATION:1.#CONTRACTOR SHALL VISIT THE SITE PRIOR TO FABRICATION TO CONFIR M:2.#ACTUAL DIMENSIONS, CONFIGURATION, AND ORIENTATION OF EXISTINGFITTINGS.3.#MATERIAL SPECIFICATIONS AND	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503287

DATE : 18.12.2025

REQ No : 1032506342

REQ TITLE : JAPS L1-STATION

DELIVERY LOCATION

CLOSING DATE : 24.12.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THICKNESS.4.#ACCESSIBILITY FOR INSTALLATION.5.#NO WORK MAY BEGIN WITHOUT ON-SITE CONFIRMATION.FABRICATION OF FITTINGS:THE CONTRACTOR SHALL FABRICATE THE FOLLO WING:1.#FILLING LINE END CONNECTION FITTING # 1½ INCH (1 EACH)FABRICATE AN END CONNECTION FITTING IDENTICAL TO THE EXISTING FITTINGI NSTALLED AT SITE.2.#EQUALIZING LINE END CONNECTION FITTING # 1 INCH (1 EACH)FABRICATE AN END CONNECTION FITTING IDENTICAL TO THE EXI STING FITTINGINSTALLED AT SITE.3.#NEW FILLING LINE ADAPTER FITTING # 1½ INCH (1 EACH)ONE END COMPATIBLE WITH THE EXISTING FILLING LI NE CONNECTION INSTALLEDAT SITE.OTHER END COMPATIBLE WITH STANDARD CO# FILLING FACILITIES AVAILABLE INTHE MARKET.4.#NEW EQUALIZING LI NE ADAPTER FITTING # 1 INCH (1 EACH)ONE END IS COMPATIBLE WITH THE EXISTING EQUALIZING LINE CONNECTIONINSTALLED AT SITE.OTHER END CO MPATIBLE WITH STANDARD CO# FILLING						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503287
DATE : 18.12.2025
REQ No : 1032506342
REQ TITLE : JAPS L1-STATION
DELIVERY LOCATION
CLOSING DATE : 24.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FACILITIES AVAILABLE IN THE MARKET. ALL FABRICATED FITTINGS SHALL MEET THE MATERIAL GRADE REQUIREMENTS SUITABLE FOR CO# SERVICE AND FOLLOW RELEVANT PRESSURE RATING AND SAFETY STANDARDS. INSTALLATION WORK: CONTRACTOR SHALL INSTALL THE FABRICATED FITTINGS ON THE FILLING AND EQUALIZING LINES. ALL INSTALLATION WORK SHALL BE PERFORMED DOWNSTREAM OF THE ISOLATION VALVE ONLY, AS THE CO# STORAGE TANK IS IN A CHARGED CONDITION. TESTING AND VERIFICATION: CONTRACTOR MUST ENSURE PROPER FIT-UP AND ALIGNMENT OF INSTALLED FITTINGS. LEAK CHECKS AND INTEGRITY VERIFICATION AFTER INSTALLATION. READINESS OF CONNECTION POINTS FOR THIRD-PARTY CO# TOP-UP. DELIVERABLES: FABRICATED AND INSTALLED FITTINGS (AS LISTED ABOVE). INSPECTION REPORTS AND MATERIAL CERTIFICATES. INSTALLATION COMPLETE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503287

DATE : 18.12.2025

REQ No : 1032506342

REQ TITLE : JAPS L1-STATION

DELIVERY LOCATION

CLOSING DATE : 24.12.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TION REPORT.EXCLUSIONS:CO# TOP-UP ACTIVITIES ARE NOT PART OF THE CONTRACTOR#S SCOPE.NOTE:THIS SCOPE OF WORK IS INTENDED TO OUTLINE THE GENERAL TASKS ANDREQUIREMENTS FOR FABRICATION AND INSTALLATION OF END CONNECTIONFITTINGS.CONTACT PERSON FROM DEWA1. SYED SHOWKAT ALI - SYEDS.ALI@DEWA.GOV.AE / 048140513 OR2. MUHAMMAD SHAMIM KHAN- MUHAMMAD.KHAN@DEWA.GOV.AE / 043226023						
2		ITEM-00001	FABRICATION AND INSTALLATION OF END CONNECTION FITTINGS FOR CO# STORAGETANK FILLING AND EQUALIZING LINESSCOPE OVERVIEW:THIS SCOPE OF WORK IS TO FABRICATE AND INSTALL NEW END CONNECTIONFITTINGS FOR THE 1½-INCH FILLING LINE AND 1-INCH EQUALIZING LINE OF THECO# STORA GE TANK. THE NEW FITTINGS SHALL MATCH THE EXISTING INSTALLEDCONNECTIONS AT SITE ON ONE END AND INTERFACE WITH STANDARD CO# FILLINGEQ	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503287
DATE : 18.12.2025
REQ No : 1032506342
REQ TITLE : JAPS L1-STATION
DELIVERY LOCATION
CLOSING DATE : 24.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>UIPMENT AVAILABLE IN THE MARKET ON THE OTHER. WORK INCLUDES MATERIALSUPPLY, FABRICATION, INSTALLATION, TESTING, AND HANDOVER UP TO R</p> <p>EADINESSFOR THIRD-PARTY CO# TOP-UP.SCOPE OF WORK:SITE VERIFICATION:1.#CONTRACTOR SHALL VISIT THE SITE PRIOR TO FABRICATION TO CONFIR</p> <p>M:2.#ACTUAL DIMENSIONS, CONFIGURATION, AND ORIENTATION OF EXISTINGFITTINGS.3.#MATERIAL SPECIFICATIONS AND THICKNESS.4.#ACCESSIBILITY FOR INSTALLATION.5.#NO WORK MAY BEGIN WITHOUT ON-SITE CONFIRMATION.FABRICATION OF FITTINGS:THE CONTRACTOR SHALL FABRICATE THE FOLLO</p> <p>WING:1.#FILLING LINE END CONNECTION FITTING # 1½ INCH (1 EACH)FABRICATE AN END CONNECTION FITTING IDENTICAL TO THE EXISTING FITTINGI NSTALLED AT SITE.2.#EQUALIZING LINE END CONNECTION FITTING # 1 INCH (1 EACH)FABRICATE AN END CONNECTION FITTING IDENTICAL TO THE EXI</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503287

DATE : 18.12.2025

REQ No : 1032506342

REQ TITLE : JAPS L1-STATION

DELIVERY LOCATION

CLOSING DATE : 24.12.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>STING FITTINGINSTALLED AT SITE.3.#NEW FILLING LINE ADAPTER FITTING # 1½ INCH (1 EACH)ONE END COMPATIBLE WITH THE EXISTING FILLING LINE CONNECTION INSTALLEDAT SITE.OTHER END COMPATIBLE WITH STANDARD CO# FILLING FACILITIES AVAILABLE INTHE MARKET.4.#NEW EQUALIZING LINE ADAPTER FITTING # 1 INCH (1 EACH)ONE END IS COMPATIBLE WITH THE EXISTING EQUALIZING LINE CONNECTIONINSTALLED AT SITE.OTHER END COMPATIBLE WITH STANDARD CO# FILLING FACILITIES AVAILABLE INTHE MARKET.ALL FABRICATED FITTINGS SHALL MEET THE MATERIAL GRADE REQUIREME</p> <p>NTSSUITABLE FOR CO# SERVICE AND FOLLOW RELEVANT PRESSURE RATING AND SAFETYSTANDARDS. INSTALLATION WORK:CONTRACTOR SHALL INSTALL THE FABRICATED FITTINGS ON THE FILLING ANEQUALIZING LINES.ALL INSTALLATION WORK SHALL BE PERFORMED DOWNSTREAM OF THE ISOLATIONVALVE ONL</p> <p>Y, AS THE CO# STORAGE TANK IS IN A CHARGED</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503287
DATE : 18.12.2025
REQ No : 1032506342
REQ TITLE : JAPS L1-STATION
DELIVERY LOCATION
CLOSING DATE : 24.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONDITION.TESTING AND VERIFICATION:CONTRACTOR MUST ENSURE:PROPER FIT-UP AND ALIGNMENT OF INSTALLED FITTINGS.LEAK CHECKS AND INTEGRITY VERIFICATION AFTER INSTALLATION.READINESS OF CONNECTION POINTS FOR THIRD-PARTY CO# TOP-UP.DELIVERABLES:FABRICATED AND INSTALLED FITTINGS (AS LISTED ABOVE).INSPECTION REPORTS AND MATERIAL CERTIFICATES.INSTALLATION COMPLETION REPORT.EXCLUSIONS:CO# TOP-UP ACTIVITIES ARE NOT PART OF THE CONTRACTOR#S SCOPE.NOTE:THIS SCOPE OF WORK IS INTENDED TO OUTLINE THE GENERAL TASKS ANDREQUIREMENTS FOR FABRICATION AND INSTALLATION OF END CONNECTIONFITTINGS.CONTACT PERSON FROM DEWA1. SYED SHOWKAT ALI - SYEDS.ALI@DEWA.GOV.AE / 048140513 OR2. MUHAMMAD SHAMIM KHAN- MUHAMMAD.KHAN@DEWA.GOV.AE / 043226023						
3		ITEM-00001	FABRICATION AND INSTALLATION OF END	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503287

DATE : 18.12.2025

REQ No : 1032506342

REQ TITLE : JAPS L1-STATION

DELIVERY LOCATION

CLOSING DATE : 24.12.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONNECTION FITTINGS FOR CO# STORAGETANK FILLING AND EQUALIZING LINE SCOPE OVERVIEW: THIS SCOPE OF WORK IS TO FABRICATE AND INSTALL NEW END CONNECTION FITTINGS FOR THE 1½-INCH FILLING LINE AND 1-INCH EQUALIZING LINE OF THE CO# STORAGETANK. THE NEW FITTINGS SHALL MATCH THE EXISTING INSTALLED CONNECTIONS AT SITE ON ONE END AND INTERFACE WITH STANDARD CO# FILLING EQUIPMENT AVAILABLE IN THE MARKET ON THE OTHER. WORK INCLUDES MATERIAL SUPPLY, FABRICATION, INSTALLATION, TESTING, AND HANDOVER UP TO READINESS FOR THIRD-PARTY CO# TOP-UP. SCOPE OF WORK: SITE VERIFICATION: 1.# CONTRACTOR SHALL VISIT THE SITE PRIOR TO FABRICATION TO CONFIRM: 2.# ACTUAL DIMENSIONS, CONFIGURATION, AND ORIENTATION OF EXISTING FITTINGS. 3.# MATERIAL SPECIFICATIONS AND THICKNESS. 4.# ACCESSIBILITY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503287

DATE : 18.12.2025

REQ No : 1032506342

REQ TITLE : JAPS L1-STATION

DELIVERY LOCATION

CLOSING DATE : 24.12.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FOR INSTALLATION.5.#NO WORK MAY BEGIN WITHOUT ON-SITE CONFIRMATION.FABRICATION OF FITTINGS:THE CONTRACTOR SHALL FABRICATE THE FOLLO</p> <p>WING:1.#FILLING LINE END CONNECTION FITTING # 1½ INCH (1 EACH)FABRICATE AN END CONNECTION FITTING IDENTICAL TO THE EXISTING FITTINGI NSTALLED AT SITE.2.#EQUALIZING LINE END CONNECTION FITTING # 1 INCH (1 EACH)FABRICATE AN END CONNECTION FITTING IDENTICAL TO THE EXI</p> <p>STING FITTINGINSTALLED AT SITE.3.#NEW FILLING LINE ADAPTER FITTING # 1½ INCH (1 EACH)ONE END COMPATIBLE WITH THE EXISTING FILLING LI NE CONNECTION INSTALLEDAT SITE.OTHER END COMPATIBLE WITH STANDARD CO# FILLING FACILITIES AVAILABLE INTHE MARKET.4.#NEW EQUALIZING LI</p> <p>NE ADAPTER FITTING # 1 INCH (1 EACH)ONE END IS COMPATIBLE WITH THE EXISTING EQUALIZING LINE CONNECTIONINSTALLED AT SITE.OTHER END CO MPATIBLE WITH STANDARD CO# FILLING FACILITIES AVAILABLE INTHE MARKET.ALL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503287

DATE : 18.12.2025

REQ No : 1032506342

REQ TITLE : JAPS L1-STATION

DELIVERY LOCATION

CLOSING DATE : 24.12.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FABRICATED FITTINGS SHALL MEET THE MATERIAL GRADE REQUIREMENTS SUITABLE FOR CO# SERVICE AND FOLLOW RELEVANT PRESSURE RATING AND SAFETY STANDARDS. INSTALLATION WORK: CONTRACTOR SHALL INSTALL THE FABRICATED FITTINGS ON THE FILLING AND EQUALIZING LINES. ALL INSTALLATION WORK SHALL BE PERFORMED DOWNSTREAM OF THE ISOLATION VALVE ONLY, AS THE CO# STORAGE TANK IS IN A CHARGED CONDITION. TESTING AND VERIFICATION: CONTRACTOR MUST ENSURE PROPER FIT-UP AND ALIGNMENT OF INSTALLED FITTINGS. LEAK CHECKS AND INTEGRITY VERIFICATION AFTER INSTALLATION. READINESS OF CONNECTION POINTS FOR THIRD-PARTY CO# TOP-UP. DELIVERABLES: FABRICATED AND INSTALLED FITTINGS (AS LISTED ABOVE). INSPECTION REPORTS AND MATERIAL CERTIFICATES. INSTALLATION COMPLETION REPORT. EXCLUSIONS: CO# TOP-UP						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503287
DATE : 18.12.2025
REQ No : 1032506342
REQ TITLE : JAPS L1-STATION
DELIVERY LOCATION
CLOSING DATE : 24.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ACTIVITIES ARE NOT PART OF THE CONTRACTOR#S SCOPE.NOTE:THIS SCOPE OF WORK IS INTENDED TO OUTLINE THE GENERAL TASKS ANDREQUIREMENTS FOR FABRICATION AND INSTALLATION OF END CONNECTIONFITTINGS.CONTACT PERSON FROM DEWA1. SYED SHOWKAT ALI - SYEDS.ALI@DEWA.GOV.AE / 048140513 OR2. MUHAMMAD SHAMIM KHAN- MUHAMMAD.KHAN@DEWA.GOV.AE / 043226023						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

JAPS L1-STATION FABRICATION AND INSTALLATION OF END CONNECTION FITTINGS FOR CO2 STORAGE TANK.

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503287
DATE : 18.12.2025
REQ No : 1032506342
REQ TITLE : JAPS L1-STATION
DELIVERY LOCATION
CLOSING DATE : 24.12.2025
CLOSING TIME : 10:00:00

3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material

4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP