

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503288
DATE : 18.12.2025
REQ No : 1032506291
REQ TITLE : 1032506291 HRSG 81,82,83,84
DELIVERY LOCATION
CLOSING DATE : 24.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORKL2 STATION, JEBEL ALI POWER STATIONTITLE: HRSG 81,82,83,84 HP&LP DRUM SILENCER REPAIR WORKQTY:1.#HP SILENCER REPAIR WORK 3 NOS.DURATION: 2 DAYS/ EACH.TENTATIVE SCHEDULE: DURING HRSG OUTAGEA.#SCOPE OF WORK.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE HE SUBMITS HIS BID.#TO GET A PTW, HWP CONTRACTOR MUST SUBMIT RISK ASSESSMENT FORMS ANDMETHOD STATEMENT PRIOR TO START THE WORK.#CHECK CONDITION SUITABLE TO CARRY OUT WORK. CONDUCT SITE SURVEY ANDSAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT.#IF WORKING ENVIRONMENT IS SAFE PROCEED THE FOLLOWING STEPS,#A SAFETY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED I</p>	3	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503288
DATE : 18.12.2025
REQ No : 1032506291
REQ TITLE : 1032506291 HRSG 81,82,83,84
DELIVERY LOCATION
CLOSING DATE : 24.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NMETHODS TO BE USED. RISK ASSESSMENT AND TOOLBOX TALK TO BE GIVEN TO THEEMPLOYEES.#MOBILIZE THE LABOR, EQUIPMENT, TOOLS, ETC. ON 48 HRS. NOTICE PERIOD.(3 TIMES IF REQUIRED).#SAFETY HARNESS FOR ALL TEAM DURING WORK.#AWARDING THE PO DOES NOT GUARANTEE THAT COMPLET E QUANTITY IN THE POWILL BE CARRIED OUT. ACTUAL QUANTITY OF REPLACEMENT WILL BE DECIDEDBASED ON INSPECTION AND PAYMENT SHALL BE BASE D ON ACTUAL WORK CARRIEDOUT.#SCOPE OF WORK FOR HP DRUM SAFETY VALVE SILENCER:O#REMOVAL INLET PIPE INSULATIONO#REMOVAL OF THE BOTTOM OUTER CASINGO#REMOVAL OF THE DIFFUSER FROM THE SILENCER.O#REPLACE THE INLET PIPE MATERIAL SA 106 GR B, OD 273 MM , THICKNESS9.27 MM , LENGTH 450 MM (TWO WELDING JOINT ONE DIFFUSER SIDE AND ONEPIPE SIDE)O#INSTALLATION AND WELDING OF THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503288
DATE : 18.12.2025
REQ No : 1032506291
REQ TITLE : 1032506291 HRSG 81,82,83,84
DELIVERY LOCATION
CLOSING DATE : 24.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BOTTOM OUTER CASING.O#PROPE R WPS HAS TO BE FOLLOWED DURING THE WELDING.O#NDT INSPECTION FOR THE WELD JOINTS.O# INSPECTION OF THE DIFFUSER BY DEWA PERSON.O#INLE T PIPE INSULATION FIXINGDEWA SCOPE.#PIPE.#SCAFFOLDING IF REQUIRED.#AIR, WATER AND ELECTRICITY.#INSULATIONCONTRACTOR SCOPE OF SUPP LY.#TOOLS, TACKLES, AND EQUIPMENT TO CARRY OUT THE JOB.#MANPOWER.#WELDING CONSUMABLES.#ITP, WPS, NDT PLAN, ERECTION PLAN & PWHT PRO CEDURES.#TEMPORARY SUPPORTSWARRANTY.#THE WARRANTY PERIOD FOR THE WORK SHALL BE ONE YEAR FROM THE DATE OFCOMPLETION OF WORK CERTIFIED BY DEWA.#IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THISCONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND ANDCARRY OUT THE NECESSARY REPAIR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503288
DATE : 18.12.2025
REQ No : 1032506291
REQ TITLE : 1032506291 HRSG 81,82,83,84
DELIVERY LOCATION
CLOSING DATE : 24.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WORK AND RECTIFY THE DEFECT WITHIN SHORTPERIOD WITHOUT AFFECTING THE PRODUCTION OF ELECTRI CITY AND WATER.FOR QUERIES CONTACT MR ARUN PHONE: 04-322-6104 # ARUNKUMAR.SETHURAMAN@DEWA.GOV.AE						
2		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORKL2 STATION, JEBEL ALI POWER STATIONTITLE: HRSG 81,82,83,84 HP&LP DRUM SILENCE R REPAIR WORKQTY:1.#LP SILENCER REPAIR WORK 3 NOS.DURATION: 2 DAYS/ EACH.TENTATIVE SCHEDULE: DURING HRSG OUTAGEA.#SCOPE OF WORK.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETYM EASURES ETC., BEFORE HE SUBMITS HIS BID.#TO GET A PTW, HWP CONTRACTOR MUST SUBMIT RISK ASSESSMENT FORMS ANDMETHOD STATEMENT PRIOR T O START THE WORK.#CHECK CONDITION	3	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503288
DATE : 18.12.2025
REQ No : 1032506291
REQ TITLE : 1032506291 HRSG 81,82,83,84
DELIVERY LOCATION
CLOSING DATE : 24.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SUITABLE TO CARRY OUT WORK. CONDUCT SITE SURVEY ANDSAFETY INSPECTION TO ASSESS THE WORKING ENVIRO NMENT.#IF WORKING ENVIRONMENT IS SAFE PROCEED THE FOLLOWING STEPS,#A SAFETY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED INM ETHODS TO BE USED. RISK ASSESSMENT AND TOOLBOX TALK TO BE GIVEN TO THEEMPLOYEES.#MOBILIZE THE LABOR, EQUIPMENT, TOOLS, ETC. ON 48 H RS. NOTICE PERIOD.(3 TIMES IF REQUIRED).#SAFETY HARNESS FOR ALL TEAM DURING WORK.#AWARDING THE PO DOES NOT GUARANTEE THAT COMPLETE QUANTITY IN THE POWILL BE CARRIED OUT. ACTUAL QUANTITY OF REPLACEMENT WILL BE DECIDEDBASED ON INSPECTION AND PAYMENT SHALL BE BASED ON ACTUAL WORK CARRIEDOUT.#SCOPE OF WORK FOR HP DRUM SAFETY VALVE SILENCER:O#REMOVAL INLET PIPE INSULATIONO#REMOVAL OF THE BOTTOM OU						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503288
DATE : 18.12.2025
REQ No : 1032506291
REQ TITLE : 1032506291 HRSG 81,82,83,84
DELIVERY LOCATION
CLOSING DATE : 24.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TER CASINGO#REMOVAL OF THE DIFFUSER FROM THE SILENCER.O#REPLACE THE INLET PIPE MATERIAL SA 106 GR B, OD 273 MM , THICKNESS9.27 MM , LENGTH 450 MM (TWO WELDING JOINT ONE DIFFUSER SIDE AND ONEPIPE SIDE)O#INSTALLATION AND WELDING OF THE BOTTOM OUTER CASING.O#PROPER WPS HAS TO BE FOLLOWED DURING THE WELDING.O#NDT INSPECTION FOR THE WELD JOINTS.O# INSPECTION OF THE DIFFUSER BY DEWA PERSON.O#INLET PIPE INSULATION FIXINGDEWA SCOPE.#PIPE.#SCAFFOLDING IF REQUIRED.#AIR, WATER AND ELECTRICITY.#INSULATIONCONTRACTOR SCOPE OF SUPPLY</p> <p>#TOOLS, TACKLES, AND EQUIPMENT TO CARRY OUT THE JOB.#MANPOWER.#WELDING CONSUMABLES.#ITP, WPS, NDT PLAN, ERECTION PLAN & PWHT PROCE</p> <p>DURES.#TEMPORARY SUPPORTSWARRANTY.#THE WARRANTY PERIOD FOR THE WORK SHALL BE ONE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503288
DATE : 18.12.2025
REQ No : 1032506291
REQ TITLE : 1032506291 HRSG 81,82,83,84
DELIVERY LOCATION
CLOSING DATE : 24.12.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			YEAR FROM THE DATE OF COMPLETION OF WORK CERTIFIED BY DEWA. #IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THIS CONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND AND CARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN SHORT PERIOD WITHOUT AFFECTING THE PRODUCTION OF ELECTRICITY AND WATER.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

HRSG 81,82,83,84 HP AND LP DRUM SILENCER REPAIR WORK AT L-2 STATION

STANDARD TERMS & CONDITIONS

- Prices should be 'DDP' delivery duty paid at DEWA stores.
- Quotation to be submitted only in local currency U.A.E Dirhams
- DEWA Standard payment terms is '30 days credit' from the date of acceptance of material

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332503288
DATE : 18.12.2025
REQ No : 1032506291
REQ TITLE : 1032506291 HRSG 81,82,83,84
DELIVERY LOCATION
CLOSING DATE : 24.12.2025
CLOSING TIME : 10:00:00

- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6)Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by theSupplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.
- If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
- The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP