

RFQ NUMBER : 2332503315

DATE : 18.12.2025

REQ No : 1032505940

REQ TITLE : Sea Water Booster Pump

DELIVERY LOCATION

CLOSING DATE : 24.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	REFURBISHMENT OF DN 44 INCH (1110 MM)	3	EA				
			BUTTERFLY DISCHARGE MOV OF SWBPDESAL						
			UNITS # 6, 7 & 8 AT D-STATION PH2CONTRACTOR#S						
			SCOPE OF WO						
			RK- (INCLUDES BUT NOT LIMITED TO THE						
			FOLLOWING)1.1 FOR WORK AT SITE1.1.1						
			PRELIMINARY:(I) CLEANING OF VALVE BODY, LINE						
			FLANGES & BONN						
			ET FLANGE, REMOVAL OFSTUDS FROM SIDE						
			FLANGES, LAPPING/RECTIFYING GASKET FACES IF						
			REQUIRED, AND ANY OTHER ALLIED WORK SHALL						
			BE PART OF						
			THE CONTRACTOR#S SCOPE.(II) SUBMISSION OF						
			DETAILED JOB REPORT.(III) INSPECTION OF						
			ACTUATOR CONDITION PRIOR TO DISMANTLING,						
			INCLUDIN						
			GCHECKING FOR ABNORMAL NOISE, EXCESSIVE						
			BACKLASH, OR SIGNS OF						
			GEARWEAR/FAILURE.1.1.2 DISMANTLING:(I)						
			REMOVAL OF HAND-WHEEL & ACCESSO						
			RIES.(II) DETACHING OF ACTUATOR FROM VALVE						
			BODY.(III) OPENING AND INSPECTION OF						
			ACTUATOR INTERNAL COMPONENTS,						



RFQ NUMBER : 2332503315

DATE : 18.12.2025

REQ No : 1032505940

REQ TITLE : Sea Water Booster Pump

DELIVERY LOCATION

CLOSING DATE : 24.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INCLUDINGGEARS, COUPLI						
			NGS, AND MECHANICAL DRIVE TRAIN.(IV)						
			DETACHING VALVE FROM BONNET AND REMOVAL						
			OF BOTTOM FLANGE, IF ANY.(V) ASSISTANCE IN						
			INSPECTION O						
			F VALVE INTERNALS/INDIVIDUAL PARTS						
			AFTERREMOVAL, SUCH AS:DISC / BUSH / BEARING /						
			SHAFT (FOR BUTTERFLY/GATE VALVES).(VI)						
			CLEANING & R						
			UST REMOVAL OF ALL PARTS AFTER						
			DISMANTLING.1.1.3 REPAIR, RECONDITIONING &						
			ASSEMBLY:(I) INSPECTION OF SEAT RING,						
			REMOVAL OF SCORING/C						
			UT MARKS AS REQUIRED TOACHIEVE THE DESIRED						
			LEAKAGE CLASSIFICATION.(II)						
			RECONDITIONING/WELD REPAIRING OF SCORED						
			OR DAMAGED SURFACES A						
			NDRECOATING OF INTERNAL SURFACES OF VALVE						
			BODY AND DISC.(III) REPLACEMENT OF WORN-OUT						
			SEAT RING, SHAFT BUSHES, BEARINGS, SHAFTEND						
			SE						
			ALS, O-RINGS, GLAND PACKING, GASKETS, ETC.(IV)						
			REPLACEMENT OF DAMAGED, DEFORMED, OR						



RFQ NUMBER : 2332503315

DATE : 18.12.2025

REQ No : 1032505940

REQ TITLE : Sea Water Booster Pump

DELIVERY LOCATION

CLOSING DATE : 24.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CORRODED VALVE PARTS.(V) REPLACEMENT OF						
			CORRODED						
			STUDS & BOLTS WHEREVER NECESSARY.(VI)						
			SERVICING OF HAND-WHEEL ASSEMBLY.(VII)						
			ACTUATOR REFURBISHMENT,						
			INCLUDING:INSPECTION AND CLEAN						
			ING OF ACTUATOR GEARS, BEARINGS, AND						
			MECHANICALDRIVE COMPONENTS.REPLACEMENT						
			OF DAMAGED OR WORN ACTUATOR GEARS AND						
			BEARINGS.REPLACEME						
			NT OF DEFECTIVE MECHANICAL PARTS, LIMIT						
			SWITCHES, COUPLINGS, ORSEALS INSIDE THE						
			ACTUATOR.REASSEMBLY AND CALIBRATION OF						
			ACTUATOR AFTE						
			R REPAIRS.(VIII) ASSEMBLING BACK THE						
			ACTUATOR AND VALVE WITH REPLACEMENT OF						
			VALVEFLANGE GASKETS.(IX) ANTI-CORROSIVE						
			PAINTING OF EXTE						
			RNAL VALVE BODY.(X) MOUNTING OF HAND-WHEEL						
			& ACCESSORIES.(XI) SANDBLASTING, COATING,						
			AND PAINTING. AFTER SANDBLASTING, IF						
			ANYCRACKS						
			ARE NOTICED, THE CONTRACTOR SHALL BUILD UP						



RFQ NUMBER : 2332503315

DATE : 18.12.2025

REQ No : 1032505940

REQ TITLE : Sea Water Booster Pump

DELIVERY LOCATION

CLOSING DATE : 24.12.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE CRACKS WITHSUITABLE WELDING						
			ELECTRODES AND PERFORM REQUIRED						
			MACHINING.THE CONTRACTOR						
			SHALL ENSURE CAREFUL HANDLING OF VALVES						
			AND ACTUATORS TOAVOID ANY DAMAGE TO						
			FLANGES OR EQUIPMENT DURING						
			MAINTENANCE.1.1.4 TESTING:(I						
) LEAKAGE/PASSING THROUGH THE VALVE WILL BE						
			TESTED, WHEREVER REQUIRED,BY						
			HYDRAULIC/AIR PRESSURE AT THE SPECIFIED						
			DIFFERENTIAL PRESSU						
			RE, ANDLEAKAGE RATE SHALL BE						
			RECORDED.PROPER ENGAGEMENT OF NEWLY						
			INSTALLED GEARS (IF REPLACED)PRIOR TO						
			SUBMISSION OF THE BID. THE BI						
			DDERS ARE, THEREFORE, ADVISED TOVISIT THE						
			SITE IN JEBEL ALI POWER STATION #D# ON PRIOR						
			APPOINTMENT.UNDERSTAND THE SCOPE OF						
			WORK AND						
			ASSESS THE QUANTUM OF JOB.						
			CONTACTENGINEER NAME: ALI. OFFICE NO:						
			043226536						





RFQ NUMBER : 2332503315

DATE : 18.12.2025

REQ No : 1032505940

REQ TITLE : Sea Water Booster Pump

TOTAL AMOUNT:

DELIVERY LOCATION

CLOSING DATE : 24.12.2025

CLOSING TIME : 10:00:00

TOTAL AMOUNT IN WORDS:

SPECIAL NOTES / INSTRUCTIONS:

Sea Water Booster Pump Discharge MOV refurbishment for D station PH2

Desal 6, 7 <(>&<)> 8

for more info ali.alabdoli@dewa.gov.ae, 043226536

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6)Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider





RFQ NUMBER : 2332503315

DATE : 18.12.2025

REQ No : 1032505940

REQ TITLE : Sea Water Booster Pump

DELIVERY LOCATION

shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS:

SUPPLIER'S SIGNATURE AND STAMP